



California Regional Water Quality Control Board

San Francisco Bay Region



Terry Tamminen
Secretary for
Environmental
Protection

1515 Clay Street, Suite 1400, Oakland, California 94612
(510) 622-2300 • Fax (510) 622-2460
[http:// www.waterboards.ca.gov/sanfranciscobay](http://www.waterboards.ca.gov/sanfranciscobay)

Arnold Schwarzenegger
Governor

File No. 2159.5022 (GK)

Ms. Beverly James, Manager-Engineer
Novato Sanitary District
500 Davidson Street
Novato, CA 94945

Dear Ms. James:

**SUBJECT: TRANSMITTAL OF FINAL ORDER NO. R2-2004-0093
FOR NOVATO SANITARY DISTRICT, NOVATO, MARIN COUNTY**

Dear Ms. James,

Attached is a copy of the Final Order No. R2-2004-0093 adopted by the Water Board on November 17, 2004. The requirements of this Order are effective starting on February 1, 2005.

Please note that we made minor modifications to the Order, which include (1) modifying Finding No. 68 to make it sequential, (2) modifying the Self-Monitoring Program (SMP) to remove the previous case manager's name, (3) modifying the SMP to clarify grab samples can be taken for enterococcus during blending events, and (4) several formatting changes. These minor modifications are made pursuant to Provision 19 of the Order in accordance with 40CFR122.63.

If you have any questions regarding this letter, please contact Gina Kathuria at (510) 622-2378 or email at gkathuria@waterboards.ca.gov.

Sincerely,

Bruce H. Wolfe
Executive Officer

Attachment: Order No. R2-2004-0093

Copy to: Doug Eberhardt
U.S. EPA, Region 9
Permits and Standards (WTR-5)
75 Hawthorne Street
San Francisco, CA 94105

Lee Solomon
Tetra Tech, 10306 Eaton Place, Suite 340
Fairfax, VA 22030

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

SAN FRANCISCO BAY REGION

ORDER NO: R2-2004-0093

NPDES PERMIT NO. CA0037958

REISSUING WASTE DISCHARGE REQUIREMENTS FOR:

NOVATO SANITARY DISTRICT

NOVATO

MARIN COUNTY

Table of Contents

ORDER NO: R2-2004-0093	1
FINDINGS	1
Purpose of Order.....	1
Facility Description	1
Discharge Description	2
Treated Wastewater Reclamation.....	3
Storm Water Discharge	3
Sludge Handling and Disposal	4
Pretreatment and Pollution Prevention Programs.....	4
Treatment Plant Upgrade.....	5
Regional Monitoring Program.....	6
APPLICABLE PLANS, POLICIES, AND REGULATIONS	6
Beneficial Uses.....	6
Shallow Water Discharge Prohibition and Exception	7
Dilution and Assimilative Capacity.....	7
BASIS FOR EFFLUENT LIMITATIONS	7
General Basis.....	7
Salinity.....	8
Effluent Limits.....	8
Impaired Water Bodies and TMDLs	9
Antibacksliding and Antidegradation.....	10
Interim Limits and Compliance Schedules.....	11
Specific Basis for Effluent Limits	12
Specific Pollutants	15
Whole Effluent Acute Toxicity	21
Whole Effluent Chronic Toxicity	21
Bacteriological Limits	21
Effluent and Receiving Water Pollutant Monitoring for the SIP	21
Self Monitoring Program.....	22
Optional Mass Offset.....	22
NPDES Permit, Notification and Public Hearing.....	22
A. DISCHARGE PROHIBITIONS.....	23
B. EFFLUENT LIMITS	24
Toxicity Testing.....	26
Toxic Substances.....	27
C. RECEIVING WATER LIMITS	28
D. BIOSOLIDS/SLUDGE REQUIREMENTS.....	29
E. PROVISIONS	30
1. Permit Compliance and Rescission of Previous Waste Discharge Requirements.....	30
2. Copper Study and Schedule - Regional Site-Specific Objective Study for Copper	30
3. Cyanide Compliance Schedule and Cyanide SSO Study.....	31
4. Pollutant Prevention and Minimization Program (PMP)	31

5.	<i>Pretreatment</i>	33
6.	<i>Whole Effluent Acute Toxicity</i>	34
7.	<i>Whole Effluent Chronic Toxicity</i>	34
8.	<i>Mercury Mass Loading Reduction</i>	36
9.	<i>Bacteriological Studies</i>	37
10.	<i>Reclamation pond operation</i>	37
11.	<i>Compliance schedule for conventional effluent limitations at Ignacio Plant</i>	38
12.	<i>303(d)-listed Pollutants Site-Specific Objective and TMDL Status Review</i>	38
13.	<i>Optional Mass Offset</i>	38
14.	<i>Sanitary Sewer Management Plan</i>	38
15.	<i>Blending Monitoring Study</i>	39
16.	<i>Implementation and Enforcement of Prohibition A.5</i>	39
16.	<i>Wastewater Facilities, Review and Evaluation, and Status Reports</i>	41
17.	<i>Operations and Maintenance Manual, Review and Status Reports</i>	41
18.	<i>Contingency Plan, Review and Status Reports</i>	42
19.	<i>Self-Monitoring Program</i>	42
20.	<i>Standard Provisions and Reporting Requirements</i>	42
21.	<i>Change in Control or Ownership</i>	42
22.	<i>Permit Reopener</i>	43
23.	<i>NPDES Permit Effective Date</i>	43
24.	<i>Order Expiration and Reapplication</i>	43

List of Tables

Table 1.	Results of RPA and final limit calculations.....	13
Table 2.	RPA results for individual PAHs.....	14
Table 3.	Final and interim effluent limitations for 4,4'-DDE, 4,4'-DDD, dieldrin and heptachlor epoxide.....	20
Table 4.	Conventional Pollutant Effluent Limitations for Wet Weather Discharge (November 1 through April 30).....	24
Table 5.	Conventional Pollutant Effluent Limitations for Dry Weather Discharge (between May 1 and October 31).....	24
Table 6.	Interim Performance Based Conventional Pollutants Effluent Limitations for Discharges from Ignacio Treatment Plant (E-001) between May 1 and October 31, annually.....	24
Table 7.	Effluent limitations for toxic substances in combined effluent.....	27

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

SAN FRANCISCO BAY REGION

ORDER NO: R2-2004-0093
NPDES PERMIT NO. CA0037958

REISSUING WASTE DISCHARGE REQUIREMENTS FOR:

NOVATO SANITARY DISTRICT
NOVATO, MARIN COUNTY

FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region (the Board) finds that:

1. On November 24, 2003, the Novato Sanitary District (the Discharger) applied to the San Francisco Bay Regional Water Quality Control Board (the Board) for reissuance of its National Pollutant Discharge Elimination System (NPDES) Permit No. CA0037958.

Purpose of Order

2. This Order serves as the NPDES Permit regulating discharge of treated wastewater into San Pablo Bay, a water of the State and the United States. This discharge was previously regulated by the Board's Order No. 99-036 and the Board's April 16, 2003, Order No. R2-2003-0029 amending Order No. 99-036 (together the existing Permit).

Facility Description

3. The Discharger owns and operates a wastewater collection system, two municipal wastewater treatment facilities (the Novato and Ignacio plants, collectively the WWTPs), and one combined effluent discharge outfall (E-003) to the intertidal mud flats of San Pablo Bay (the subject discharge), adjacent to the former Hamilton Air Force Base. The WWTPs collect sanitary waste from a primarily residential service area serving the City of Novato and adjacent areas with a current population of about 60,000. The Discharger presently discharges an average dry weather flow (ADWF) of 5.4 million gallons per day (MGD), from the WWTPs into San Pablo Bay.
4. A location map showing the WWTPs and the combined outfall is included as Attachment 1 to this Order.

Collection System

5. The Discharger's wastewater collection system collects and transports wastewater flows to the WWTPs through a series of gravity sewers and interceptors, pump stations, and force mains, designed to handle peak wet weather flows. The combined conveyance and collection systems include about 200 miles of sewer lines and 35 wastewater pump stations. The

discharger has an ongoing program preventive maintenance and capital improvement programs for these sewer lines and pump stations to ensure adequate capacity and reliability of the collection system.

Sanitary Sewer Management Plan

6. On October 15, 2003, the Board adopted Order No. RB2-2003-0095 establishing a collaborative effort with the Bay Area Clean Water Agencies (BACWA) to develop guidance for sanitary sewer management plants (SSMPs) aimed at reducing or eliminating sanitary sewer overflows (SSOs), and for uniform, electronic reporting of SSOs to the Board to facilitate the Board's assessment of the problem regionally. This Order requires the Discharger to fully participate in the BACWA effort, to develop and implement an SSMP once the guidance is available, and to report SSOs electronically once the reporting system is developed.

Treatment Plant Description

7. The Ignacio Treatment Plant (E-001) utilizes primary clarification, biofiltration, secondary clarification, nitrification, gravity filtration and disinfection with chlorine. All flows at the Ignacio plant receive full secondary treatment.
8. The Novato Treatment Plant (E-002) utilizes primary clarification, activated sludge treatment, secondary clarification, nitrification, gravity filtration, and disinfection with chlorine. The treatment processes vary depending on influent flow:

DDWF, 4.53 MGD, and wet weather flows up to 9 MGD	Treatment with all unit processes
---	-----------------------------------

Wet weather flows between 9 MGD and 16 MGD	Primary treatment plus gravity filtration and disinfection
--	--

Wet weather flows above 16 MGD	Gravity filtration plus disinfection
--------------------------------	--------------------------------------

Discharge Description

9. During the discharge season, September 1 through May 31 annually, effluent from both WWTPs is dechlorinated and discharged from the combined outfall (E-003) through a multi-port diffuser about 950 feet offshore at Latitude 122 degrees 29 minutes 24 seconds, Longitude 38 degrees 03 minutes 36 seconds. The subject discharge is in the intertidal zone adjacent to the former Hamilton Air Force Base. During the discharge prohibition period, June 1 through August 31 annually, the effluent is held in reclamation ponds for sprinkler irrigation on Discharger-controlled pasturelands. The combined outfall is a shallow water discharge, and discharge is prohibited from June 1 through August 31, annually (the summer prohibition), during which period the effluent is collected in ponds and used for reclamation.
10. The discharge diffuser is located in the intertidal zone and is submerged at the +1 foot Mean Lower Low Water (MLLW) tidal elevation and above. At lower tidal elevations, the outfall is exposed and the distance from the end of the diffuser to the San Pablo Bay water line can

range from 1000 to 3500 feet. At these times, the discharge does not receive an initial dilution of 10:1, and therefore the Board has classified this as a shallow-water discharge.

11. The attached Fact Sheet (incorporated here by reference) describes the subject discharge in detail, based on information contained in the Discharger's Self-Monitoring Reports. The data are representative of the effluent during the discharge season from October 1999 through April 2004 (the subject discharge data).
12. Process diagrams for the WWTPs are included as Attachment 2 to this Order.
13. The United States Environmental Protection Agency (the U.S. EPA) and the Board have classified this discharge as a major discharge.

Treated Wastewater Reclamation

14. Board Order No. 92-065 contains the reclamation requirements for the Discharger's reclamation program. Order No. 92-065 also requires the Discharger to maintain a wildlife management pond in addition to the storage ponds and spray irrigation.
15. From June 1 through August 31, the combined effluent is discharged to storage ponds for sprinkler irrigation of 820 acres of Discharger-controlled pasturelands used for beef cattle grazing and irrigated hay production. Although the discharge prohibition lasts for 3 months, the Discharger typically reclaims wastewater and irrigates five or more months per year. The Discharger, together with the North Marine Water District (NMWD), has filed a Notice of Intent for, the construction and operation of a recycled water treatment facility, and is therefore subject to the Board's January 17, 1996, *General Water Reuse Requirements For: Municipal Wastewater And Water Agencies* (Board Order No. 96-011).
16. During the wet weather discharge period (November 1 through April 30), treated wastewater from the storage ponds may be discharged directly through the combined outfall, if it meets the requirements of the Discharger's *Reclamation Pond Wet Season Discharge Sediment Control and Monitoring Plan*. This Plan was approved by the Executive Officer in October 1999 and is adequate to prevent entrainment of pond sediments into the discharge.
17. Water held in the reclamation ponds before being discharged through the combined outfall during the dry weather discharge months (May, September, and October) may be discharged if it meets all the requirements in this Order, as described in the Provisions, below. Pre-discharge monitoring of water held in the reclamation ponds is required during the dry weather discharge period (May 1 – 31 and September 1 – October 31, annually).

Storm Water Discharge

18. The Code of Federal Regulations contains the U.S. EPA's stormwater discharge regulations (40 CFR Parts 122, 123, and 124). Those regulations regulate stormwater discharges from specific categories of industrial activity, including municipal wastewater treatment facilities (Publicly Owned Treatment Works – POTWs). They require POTWs to obtain an NPDES permit and to implement Best Available Technology Economically Achievable and Best Conventional Pollutant Control Technology to control pollutants in industrial storm water discharges.

19. The State Water Resources Control Board (the State Board) reissued its statewide NPDES permit for storm water discharges associated with industrial activities (NPDES General Permit CAS000001 – the General Permit) on April 17, 1997. The General Permit applies to POTWs.
20. The Discharger is not subject to stormwater regulation under the U.S. EPA's regulations or the General Permit because all stormwater or rainwater coming into contact with equipment or sewage at the WWTPs, and the pump stations serving the WWTPs, is collected and directed to the WWTPs' headworks for treatment.
21. The Marin County Storm Water Pollution Prevention Program (MCSTOPP) is a joint project of eleven cities and towns and the County of Marin. The Discharger participates in MCSTOPP and works with the City of San Rafael and the Central Marin Sanitation Agency who have enforcement authority under the City of San Rafael's storm water ordinance. The storm water program strives to reduce the discharge of pollutants to creeks, wetlands and San Francisco Bay. The MCSTOPP is cooperating with the Marin County Flood Control District to implement innovative watershed preservation measures for the protection of beneficial uses of creeks and wetlands. These measures include using best management practices, public education, enforcement, and an ongoing pollution prevention program.

Sludge Handling and Disposal

22. The Novato plant has primary and secondary anaerobic digesters for sludge digestion, followed by storage ponds for thickening. The Ignacio plant has a primary anaerobic digester, followed by storage ponds for thickening. The thickened sludge from both plants is applied on a 14.4 acre dedicated land disposal site at the reclamation area.
23. Sludge storage and disposal are subject to regulation by the U.S. EPA pursuant to Title 40, Code of Federal Regulations, Part 503 (40 CFR Part 503), as further described in the Sludge Management Practices section, below.

Pretreatment and Pollution Prevention Programs

24. The Discharger has both a formal pretreatment program and a pollution prevention program.
 - a. Section 2.4.5 of the SIP specifies under what situations and for which priority pollutant(s) (i.e., reportable priority pollutants) the Discharger shall be required to conduct a Pollutant Minimization Program in accordance with Section 2.4.5.1.
 - b. There may be some redundancy between the Pollution Prevention Program and the Pollutant Minimization Program requirements.
 - c. Where the two programs' requirements overlap, the Discharger is allowed to continue/modify/expand its existing Pollution Prevention Program to satisfy the Pollutant Minimization Program requirements.
 - d. For constituents identified under Effluent Limitations, Section B, the Discharger will conduct appropriate source control or pollutant minimization measures that are consistent with its approved Pretreatment and Pollution Prevention Programs. For constituents with compliance schedules under this permit, the applicable source control/pollutant minimization requirements of Section 2.1 of the SIP will also apply.

- e. These efforts currently focus on copper, mercury, 4,4'-DDE, dieldrin, and heptachlor epoxide. These programs' activities include:
 - i. Copper-related (pretreatment program and pollution prevention program):
 - Zero discharge requirement for industrial metal finisher;
 - ii. Copper-related (pollution prevention program):
 - Vehicle services outreach encouraging zero discharge;
 - Automotive shop inspections;
 - Evaluating corrosion as a source of copper and zinc;
 - Water supply corrosion control (55% copper reduction achieved);
 - iii. Mercury-related (pollution prevention program):
 - BMPs, surveys, and inspections of dental offices;
 - Inspections of medical clinics and laboratories;
 - Fluorescent lamp collection and recycling;
 - Thermometer collection and recycling;
 - Battery collection and recycling;
 - Semi-annual newsletter concerning proper disposal of mercury-containing products;
 - Recognition of a mercury-free hospital in the service area;
 - iv. 4,4'-DDE, dieldrin and heptachlor epoxide-related (pollution prevention program):
 - Household hazardous waste collection program
 - Small business collection service
25. The Board's October 15, 2003, Resolution R2-2003-0096 supports collaboration between the Board and BACWA to promote P2 Program development, consistency, and excellence. Resolution R2-2003-0096 contains eleven guiding principles, including promoting watershed, cross-program and cross-media approaches to pollution prevention, and jointly developing assessment tools for individual Discharger's program performance that may include peer reviews, self-audits or other tools. The guiding principles will be used to develop tools such as "P2 menus" for specific pollutants, and to provide guidance in improving P2 program efficiency and accountability.
26. The Discharger has implemented and is maintaining a U.S. EPA approved pretreatment program in accordance with Federal Pretreatment Regulations (40 CFR 403), with Provision 6 of this Order, and the requirements specified in Attachment H, "Pretreatment Requirements."

Treatment Plant Upgrade

27. The Ignacio Treatment Plant is currently unable to attain the standard technology-based effluent limitations for biochemical oxygen demand (BOD₅, 20°C - BOD) and total suspended solids (TSS). The Discharger anticipates future growth in its service area, and is implementing a strategic plan to accommodate that growth and to comply with the BOD and TSS limitations by either upgrading or replacing the Ignacio plant. The implementation schedule for this strategic plan is contained in the Discharger's April 28, 2004 letter *Workplan for Ignacio Treatment Plant, NPDES Permit No. CA0037958* (Attachment G,

hereby incorporated by reference). The strategic plan may ultimately include capital improvements to the Ignacio Treatment Plant or consolidation and augmentation of treatment capacity at one or the other of the existing treatment plants, with the remaining plant being decommissioned. Therefore, this Order continues the previous NPDES Permit's interim performance-based effluent limits for the Ignacio Plant's BOD and TSS, and the March 31, 2008, compliance schedule for the final limits. This Order contains a Provision requiring an implementation schedule for attainment of the final BOD and TSS limits by March 31, 2008, together with periodic progress reports.

Regional Monitoring Program

28. Board Resolution No. 92-043 requires major NPDES permit holders in the Region to participate in a collaborative effort to report on the water quality of the San Francisco Bay. This effort is carried out through the San Francisco Estuary Institute and is known as the San Francisco Bay Regional Monitoring Program for Trace Substances (the Regional Monitoring Program – the RMP). This Order specifies that the Discharger shall continue to participate in the RMP, including collection of data on pollutants and toxicity in water, sediment and biota of the estuary, in lieu of the more intensive monitoring that would be required to adequately characterize the discharge's impact to the receiving water.

APPLICABLE PLANS, POLICIES, AND REGULATIONS

29. The attached Fact Sheet describes the regulatory basis of this Order in more detail, including the Board's June 21, 1995 revised *Water Quality Control Plan, San Francisco Bay Basin (Region 2)* (the Basin Plan), the State Water Resource Control Board's March 2, 2000 *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (the State Implementation Plan or SIP) as subsequently approved by the Office of Administrative Law and the U.S. EPA, the U.S. EPA's May 18, 2000 *Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California* (the California Toxics Rule – the CTR), the U.S. EPA's National Toxics Rule [Federal Register Volume 57, 22 December 1992, page 60848] as promulgated and subsequently amended (the NTR). The Basin Plan identified beneficial uses and water quality objectives (WQOs) for waters of the State in the Region, and the CTR and NTR contain water quality criteria (WQCs) that apply to those waters.

Beneficial Uses

30. The Basin Plan identifies the following beneficial uses for San Pablo Bay:

- Commercial and Sport Fishing
- Estuarine Habitat
- Industrial Service Supply
- Fish Migration
- Navigation
- Preservation of Rare and Endangered Species
- Water Contact Recreation
- Non-contact Recreation
- Shell Fish Harvesting
- Fish Spawning

- Wildlife Habitat.

Shallow Water Discharge Prohibition and Exception

31. Basin Plan Section 4, Table 4-1 prohibits the discharge of wastewater that does not receive a minimum initial dilution of at least 10:1, or into any nontidal water, dead-end slough, similar confined waters, areas or any immediate tributaries thereof (the discharge prohibition). The Basin Plan states that the Board may consider exceptions to the above prohibition, including exceptions for discharges which are part of a reclamation project, or which have demonstrated net environmental benefits as a result of the discharge.
32. The discharge prohibition applies to the WWTPs' discharge because it does not receive an initial dilution of at least 10:1 at all times, as described in the findings above.
33. The previous NPDES Permit granted a partial exception to the discharge prohibition, i.e. maintaining a discharge prohibition between from June 1 through August 31, annually. The partial exception was granted because the Discharger operates a significant reclamation program, and operates a pond for wildlife habitat as mitigation for past wetland fill. This Order continues that exception and discharge prohibition, subject to the conditions listed in Discharge Prohibitions, below.

Dilution and Assimilative Capacity

34. The Discharger conducted a dye study and modeling effort (the dilution studies) for the area immediately adjacent to the outfall as part of an application for an exemption to the Basin Plan's shallow water discharge prohibition. The Discharger has not requested a dilution credit at this time. The dilution studies and current ambient receiving water data do not fully address the effects of other discharges in the area upon the receiving water. Also, the receiving water is listed as impaired by mercury, a bioaccumulative pollutant, as described in the section Impaired Water Bodies and TMDLs, below, and the Board finds that there is no additional assimilative capacity available for mercury in the receiving water. Therefore, this Order does not grant dilution credit, and the effluent limitations contained in this permit are calculated assuming no dilution, as detailed in the attached Fact Sheet.

BASIS FOR EFFLUENT LIMITATIONS

General Basis

35. *Federal Water Pollution Control Act.* Effluent limitations and toxic effluent standards contained in this Order are established pursuant to sections 301 through 305, and 307 of the Federal Water Pollution Control Act and amendments thereto as applicable to the discharges herein.
36. *Applicable Water Quality Objectives.* The WQOs, WQCs, effluent limitations, and calculations contained in this Order are based on the statutes, documents, and guidance detailed in the attached Fact Sheet.

Salinity

37. *Basin Plan Salinity Policy.* The Basin Plan states that the salinity characteristics of the receiving water (freshwater, salt water, or estuarine) shall be considered in determining the applicable WQOs. It is appropriate to determine the receiving water's salinity using the Basin Plan's definitions for constituents for which the Basin Plan specifies WQOs. Freshwater objectives (adjusted for the receiving water's ambient hardness) apply to discharges to waters both outside the zone of tidal influence, and with salinities lower than 5 parts per thousand (ppt) at least 75 percent of the time in a normal water year. Marine (saltwater) objectives apply to discharges to waters with salinities greater than 5 ppt at least 75 percent of the time in a normal water year. For discharges to waters with salinities in between these two categories, or to tidally influenced freshwaters that support estuarine beneficial uses, the objectives shall be the lower of the marine or hardness-adjusted freshwater objectives for each substance [Basin Plan, page 4-13].
38. *CTR Receiving Water Salinity Policy.* The CTR states that the receiving water's salinity characteristics shall be considered in determining the applicable WQCs. It is appropriate to determine the receiving water's salinity using the CTR's definitions for constituents with WQCs specified in the CTR. Freshwater criteria (adjusted for the receiving water's ambient hardness) apply to discharges to waters with salinities equal to or less than 1 ppt at least 95 percent of the time in a normal water year. Saltwater criteria apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to waters with salinities in between these two categories, or tidally influenced freshwaters that support estuarine beneficial uses, the criteria shall be the lower of the saltwater or the hardness-adjusted freshwater criteria for each substance with WQCs specified in the CTR.
39. *Receiving Water Salinity.* The receiving waters for the subject discharge are the waters of San Pablo Bay. The Basin Plan specifically identifies San Pablo Bay as estuarine [Basin Plan Table 2-6, pg. 2-21]. Therefore, the applicable WQCs or WQOs are the lower of the marine or adjusted freshwater WQOs or WQCs.
40. *Receiving Water Hardness.* Hardness-dependant WQOs/WQCs were adjusted using a hardness of 138 milligrams per liter (mg/l). This value is based on an analysis of RMP data points collected for San Pablo Bay as detailed in the attached Fact Sheet.

Effluent Limits

41. *Technology-Based Effluent Limits.* This Order contains technology-based limits for conventional pollutants, consistent with the Basin Plan and Title 40 CFR, Part 133.102, to ensure that full secondary treatment is achieved by the WWTPs. During the dry-weather discharge season (May, September, and October, annually), the technology-based limits are more stringent than those contained in the Basin Plan and 41 CFR 125. The Fact Sheet describes the basis for these more stringent technology-based limits. These conventional effluent limits are the same as those in the prior permit for the following pollutants:
- BOD/Carbonaceous BOD (CBOD),
 - BOD percent removal,
 - TSS,
 - TSS percent removal,

- pH,
- Oil and grease, and
- Total chlorine residual.

The Basin Plan Amendment adopted by the Board on January 21, 2004, (the Amendment) removed the settleable matter effluent limitations for secondary sewage treatment plants because it was not an appropriate indicator of sewage treatment plants' performance. Although the Amendment does not become effective until it is approved by the Office of Administrative Law, this Order does not impose settleable matter limits, based on the same rationale as the Amendment's removal of them. Should this change not be approved by the Office of Administrative Law, the Board will amend this Order to reinstate the settleable matter limits, as appropriate.

42. *Water Quality Based Effluent Limitations.* Toxic substances are regulated by water quality based effluent limitations (WQBELs) derived from Basin Plan [Tables 3-3 and 3-4], the CTR and the NTR, best professional judgment (BPJ), or a combination of these sources, as further defined in the attached Fact Sheet. Further details about the effluent limitations contained in this Permit are given below and in the attached Fact Sheet.
43. *Ammonia.* This Order discontinues the previous NPDES permit's 4 mg/L annual average ammonia effluent limitation because the 6 mg/L monthly average ammonia effluent limitation adequately protects the receiving water.
44. *Receiving Water Ambient Background Data.* The RPA uses ambient background data from the RMP San Pablo Bay Station BD20 (the San Pablo Bay RMP station) from 1990 through 2000 as the most representative currently available background data. However, a data gap remains as to the ambient background conditions for the discharge into the intertidal mudflats of San Pablo Bay. San Pablo Bay station RMP data were used for this permit reissuance because this is the best available information representing ambient background condition for this discharge. The Discharger's outfall is located in the mudflats along the western edge of San Pablo Bay; and the San Pablo Bay RMP station is located in the center of San Pablo Bay. Therefore, there is significant distance from the discharge outfall to the RMP Station. For future permit reissuance, the Board may require better characterization of ambient background conditions near the outfall if such data are needed.
45. *Applicable Water Quality Objectives.* Page 3-4 of the Basin Plan contains a narrative objective for toxicity in order to protect beneficial uses:

“All waters shall be maintained free of toxic substances in concentrations that are lethal to or produce other detrimental responses in aquatic organisms”.

The Basin Plan also directs that ambient conditions shall be maintained until site-specific objectives are developed. Effluent limitations and provisions contained in this Order are designed to implement this objective, based on available information.

Impaired Water Bodies and TMDLs

46. On June 6, 2003, the U.S. EPA approved a revised list of impaired waterbodies prepared by the State in accordance with Section 303(d) of the federal Clean Water Act (the 2002 303(d) list) identifying specific water bodies where it is not expected that water quality standards

will be met after implementation of technology-based effluent limits on point sources. The 2002 303(d) list includes San Pablo Bay as impaired by:

- chlordane,
- DDT,
- diazinon,
- dieldrin,
- dioxin compounds,
- exotic species,
- furan compounds,
- mercury,
- nickel,
- PCBs,
- dioxin-like PCBs, and
- selenium.

47. Section 2.1.1 of the SIP states that for 303(d) listed bioaccumulative compounds, the Board should consider whether there is additional assimilative capacity, or if mass loadings should be limited to current levels. The Board finds that mass loading limits are warranted for certain 303(d)-listed bioaccumulative compounds (i.e., mercury) in the receiving water. Mass loading limits will ensure that the subject discharge does not contribute further to impairment of the narrative objective for bioaccumulation.
48. The Discharger is a member of the Bay Area Clean Water Agencies (BACWA), and is participating in a discharger-funded regional effort to develop site-specific, aquatic-life-based saltwater WQOs (site specific SSOs) for copper and nickel in San Pablo Bay and other San Francisco Bay segments north of the Dumbarton Bridge, as described in the attached Fact Sheet.
49. The Board plans to adopt Total Maximum Daily Loads (TMDLs) within the next ten (10) years for San Pablo Bay for the 303(d)-listed pollutants described above, except for dioxin and furan compounds. For dioxins and furans, the Board intends to consider this matter further after the U.S. EPA completes its national health reassessment. Future reviews of the 303(d) list for San Pablo Bay may result in revision of the schedules, provide schedules for other pollutants, or both.
50. The TMDLs will establish waste load allocations (WLAs) for point sources and load allocations (LAs) for nonpoint sources, and will result in achieving the water quality standards for the receiving water. Final effluent WQBELs for 303(d)-listed pollutants in this discharge will be based on WLAs contained in the respective TMDLs.

Antibacksliding and Antidegradation

51. The limitations in this Order comply with the prohibition contained in Clean Water Act Section 402(o) against establishment of less stringent WQBELs (antibacksliding) because:
 - a. For impairing pollutants, the revised final limitations will be consistent with TMDLs and WLAs, once they are established;

- b. For non-impairing pollutants, the final limitations are or will be consistent with current State WQOs/WQCs;
- c. Antibacksliding does not apply to interim limitations established under previous Orders;
- d. If antibacksliding policies apply to interim limitations under 402(o)(2)(c), a less stringent limitation is necessary because of events over which the Discharger has no control, and for which there is no reasonable available remedy, or
- e. if new information is available that was not available during previous permit issuance.

The IPBLs in this Order comply with antidegradation requirements and meet the requirements of the SIP because they hold the Discharger to performance levels that will not cause or contribute to water quality impairment or further water quality degradation. The pollutant-specific discussions below and in the attached Fact Sheet contain more detailed discussions of antidegradation and antibacksliding, where appropriate.

Interim Limits and Compliance Schedules

52. Section 2.1.1 of the SIP states:

“ the compliance schedule provisions for the development and adoption of a TMDL only apply when: ... (b) the Discharger has made appropriate commitments to support and expedite the development of the TMDL. In determining appropriate commitments, the RWQCB should consider the discharge’s contribution to current loadings and the Discharger’s ability to participate in TMDL development.”

Also, both the SIP and the Basin Plan require the Discharger to demonstrate the infeasibility of achieving immediate compliance with new limits to qualify for a compliance schedule. The attached Fact Sheet describes these requirements in more detail.

53. The Discharger is eligible for compliance schedules, partly because it has agreed to assist the Board in TMDL development through active participation in and contribution to BACWA. The Board’s September 19, 2001, Resolution No. 01-103 authorizes the Executive Officer of the Board to enter into a Memorandum of Understanding with BACWA and other parties to accelerate the development of Water Quality Attainment Strategies, including TMDLs, for the San Francisco Bay-Delta and its tributaries.
54. The Discharger’s July 22, 2004, *Infeasibility Analyses* (the feasibility study) asserts it is infeasible to immediately comply with the WQBELs calculated according to SIP Section 1.4 for copper, mercury, cyanide, 4,4’-DDE, dieldrin, and heptachlor epoxide.
- a. Board staff statistically analyzed recent WWTP copper and mercury performance data to validate the assertion of infeasibility to immediately comply with the final WQBELs calculated for them (see Section VI.6.d of the attached Fact Sheet). Based on that statistical analysis, the Board concurs with the Discharger’s assertion of infeasibility to immediately comply with the final WQBELs for copper and mercury. Therefore, pursuant to SIP requirements, this Order continues the existing compliance schedules for copper and mercury and establishes interim numeric limitations and interim requirements

to control these metals, based on the specific bases described in the specific pollutant findings, below, and in the Provisions, below.

- b. This Order establishes an interim performance-based mercury mass limit in addition to the interim mercury concentration limits, to maintain the discharge's current mass loadings of mercury, a 303(d)-listed bioaccumulative pollutant, into San Pablo Bay. This interim performance-based mass limitation is based on the existing permit.
- c. Pursuant to the SIP, this Order establishes numeric interim limits for copper, cyanide, mercury, 4,4'-DDE, dieldrin, and heptachlor epoxide.
- d. Specific bases for these interim limits are described in the findings for each pollutant and in the attached Fact Sheet. The Board may take appropriate enforcement actions if interim limits and requirements are not met.
- e. This Order requires continued monitoring for cyanide and selected semivolatiles as a condition of establishing the interim numeric interim limits for them.

55. The Board will implement the following strategy to collect water quality data and develop TMDLs:

- a. The Board will require dischargers to characterize the pollutant loads from their facilities into 303(d)-listed water bodies. Where current analytical techniques cannot detect 303-(d)-listed pollutants at their respective levels of concern or WQOs, the Dischargers may collectively assist in developing and implementing analytical techniques that will. The Board will use the results of these efforts to develop TMDLs, to update or revise the 303(d) list, or to develop modified WQOs for the impaired water bodies, including San Pablo Bay.
- b. The Board has received, and anticipates continuing to receive, resources from federal and state agencies for the development of TMDLs. The Board intends to supplement these resources by allocating development costs among dischargers through appropriate funding mechanisms to ensure timely development of TMDLs.

Specific Basis for Effluent Limits

Reasonable Potential Analysis

56. Title 40 CFR Section 122.44(d)(1)(i) requires NPDES permits to include limits for all pollutants which have the reasonable potential to cause or contribute to an exceedance of an applicable water quality standard (that have reasonable potential). Board staff conducted a Reasonable Potential Analysis (RPA) using procedures in Section 1.3 of the SIP. Pursuant to Section 1.3 of the SIP, the RPA does not include dilution for any pollutant.

- a. The RPA identifies the observed maximum effluent concentration (MEC) and maximum receiving water ambient background concentration (B) for each pollutant, based on effluent concentration and receiving water monitoring data, respectively.
- b. There are three triggers used in determining reasonable potential:

- i. The first trigger is activated if the MEC is greater than the lowest applicable WQO ($MEC \geq WQO$), which has been adjusted for pH and translator data, if appropriate. If the MEC is greater than the adjusted WQO, then that pollutant has reasonable potential, and a WQBEL is required.
- ii. The second trigger is activated if the observed maximum ambient background concentration (B) is greater than the adjusted WQO ($B > WQO$), and either:
 - a) the MEC is less than the adjusted WQO ($MEC < WQO$), or
 - b) the pollutant was not detected in any of the effluent samples and all of the detection levels are greater than or equal to the adjusted WQO.

If B is greater than the adjusted WQO, then a WQBEL is required.
- iii. The third trigger is activated under certain circumstances if a review of other information determines that a WQBEL is required to protect beneficial uses, even if both MEC and B are less than the WQO.

Translators

57. This Order employs site-specific translators for the nickel and copper WQCs used in the RPA. The translators are derived from data presented in the Discharger's attached July 23, 2004, *Novato Sanitary District Copper and Nickel Translator Calculation*, (Attachment F, incorporated here by reference). The attached Fact Sheet describes the translator data and derivation methods in more detail, and the site-specific translators are described in Table 1 and in pollutant-specific findings, below.

Reasonable Potential Analysis Results

58. Table 1, below, depicts the RPA results. The pollutant-specific findings, below, provide more detail on the RPA results, WQBELs, feasibility determinations, and interim limits and compliance schedules, as appropriate. The Fact Sheet includes the complete set of RPA tables as attachments.

Table 1. Results of RPA and final limit calculations.

Constituent	Water Quality Objective, $\mu\text{g/L}$	MEC, $\mu\text{g/L}$	Basis for Reasonable Potential	Final WQBELs, $\mu\text{g/L}$		Immediate Attainment Feasible?	IPBLs, $\mu\text{g/L}$	
				MDEL	AMEL		Daily Max.	Monthly Avg.
Copper	6.4 ^[2]	13	$MEC > C$	6.4	4.4	N	19	
Lead	4.8	3	$B (6.5) > C$	8.8	3.5	Y		
Mercury ^[1]	0.025	0.046	$MEC > C$	0.039	0.021	N		0.087
Nickel ^[1]	23.7 ^[2]	6.5	$B (30) > C$	36.1	23.6	Y		
Cyanide	1	7.3	$MEC > C$	1	0.61	N	9.2	
TCDD TEQ ^[1]	1.4×10^{-8}	[3]	Trigger 3	[4]	[4]	[4]	[4]	[4]
4,4'-DDE ^[1]	0.00059	[3]	$B (0.001159) > C$	0.00059	0.00029	[5]	0.05 [6]	
4,4'-DDD ^[1]	0.00084	[3]	$B (0.001159) > C$	0.00084	0.0017	[5]	0.05 [6]	

Dieldrin ^[1]	0.00014	[3]	B (0.000237) > C	0.00028	0.00014	[5]	0.01 [6]	
Heptachlor Epoxide	0.00011	[3]	B (0.000121) > C	0.00022	0.00011	[5]	0.01 [6]	

Footnotes for Table 1.

1. Indicates constituents on 303(d) list, dioxin applies to Toxicity Equivalent Factors (TEQ) of 2,3,7,8-TCDD.
2. WQOs derived from CTR saltwater criteria (copper, 3.1 µg/L; nickel 7.1 µg/L) and site-specific translators (copper: 0.73 acute, 0.39 chronic; nickel 0.65 acute, 0.27 chronic).
3. All effluent data ND with detection limits greater than governing WQO/WQC.
4. Dioxin final limits will be based on WLAs contained in the dioxin TMDL. Attainment feasibility will be determined after WLAs and final QBELs are set.
5. All effluent data ND with detection limits above final QBELs, and attainability could not be determined.
6. IPBLs set to minimum levels (MLs) depicted on SIP page 4 – 4.

59. *Polynuclear Aromatic Hydrocarbons (PAHs)*. The RPA above was conducted on individual PAHs as required by the SIP and CTR using CTR criteria for the protection of human health. The Basin Plan has a saltwater objective for total PAHs of 15 µg/L as 24-hour average for the protection of aquatic life. A separate RPA was therefore performed on the total PAHs. However, effluent monitoring data for all 16 PAHs are non-detect. This Order requires the Discharger to continue characterizing the effluent for individual PAH constituents. Upon completion of the required effluent monitoring, the Board will use the gathered data to complete the RPA for all individual PAH constituents (as listed in the CTR) as well as on the total PAHs and determine if a water quality-based effluent limitation is required. Table 2., below lists the RPA conducted with the currently available data.

Table 2. RPA results for individual PAHs

CTR #	Constituent	WQO ^[1] (µg/L)	MEC (µg/L)	Maximum Ambient Background Conc. (µg/L)	RP ^[3]
56	Acenaphthene	2,700	<0.17	0.007	No
57	Acenaphthylene	No Criteria	<0.03	0.0004	No
58	Anthracene	110,000	<0.03	0.00002	No
60	Benzo(a)Anthracene	0.049	<0.12	0.00033	No
61	Benzo(a)Pyrene	0.049	<0.09	0.00032	No
62	Benzo(b)Fluoranthene	0.049	<0.11	0.00053	No
63	Benzo(ghi)Perylene	No Criteria	<0.06	0.000864	No
64	Benzo(k)Fluoranthene	0.049	<0.16	0.000326	No
73	Chrysene	0.049	<0.14	0.00043	No
74	Dibenzo(a,h)Anthracene	0.049	<0.04	0.000032	No
86	Fluoranthene	370	<0.03	0.002	No
87	Fluorene	14,000	<0.02	0.01	No
92	Indeno(1,2,3-cd) Pyrene	0.049	<0.04	0.000473	No

CTR #	Constituent	WQO ^[1] (µg/L)	MEC (µg/L)	Maximum Ambient Background Conc. (µg/L)	RP ^[3]
94	Naphthalene	No Criteria	<0.05	0.0012	No
99	Phenanthrene	No Criteria	<0.03	0.0014	No
100	Pyrene	11,000	<0.03	0.0016	No
	Total PAH	15	0 ^[2]	0.22	No

Footnotes for Table 2:

- [1] WQOs for individual PAHs are based on the numeric WQO for CTR protection of human health through consumption of organisms only; WQO for total PAH is from Basin Plan for the protection of aquatic life.
- [2] When data are non-detect, 0 is used to replace the MEC for calculating the MEC of total PAHs.
- [3] “No” since effluent data are all non-detect, minimum detection limits <WQOs, and background <WQOs.

60. *Other Constituents with Limited Data.* The Discharger has performed effluent sampling and analysis for various organic constituents listed in the CTR, and reasonable potential cannot be determined for some of them for various reasons. In some cases, the WQOs/WQCs are lower than current analytical methods can reliably measure, or ambient background concentration data are not available. The Discharger will continue to use analytical methods with the best feasible detection limits to monitor for these constituents. If detection limits improve such that it becomes possible to evaluate compliance with applicable WQCs, Board staff will conduct another RPA to determine whether additional QBELs or continued monitoring are needed.

61. *Effluent Monitoring.* This Order does not contain effluent limits for constituents without reasonable potential, but Provision 2, below, requires continued monitoring. If concentrations of any of these constituents increase to the extent that they have reasonable potential or otherwise impact or threaten to impact water quality, the Discharger will be required to investigate the source of the increases and establish remedial measures.

Specific Pollutants

62. Copper

- a. *RPA Results* This Order establishes effluent limits for copper because the 16.34 µg/L maximum effluent concentration in the data set (the MEC) exceeds the governing WQO of 6.6 µg/L, demonstrating reasonable potential by Trigger 1, above. The governing WQO is based on the CTR’s WQO of 3.1 µg/L for chronic saltwater protection as modified by using the site-specific chronic copper translator of 0.39. The attached Fact Sheet contains further details about the site specific translator.
- b. *QBELs* The copper QBELs calculated according to SIP procedures are 6.4 µg/L as a daily maximum (MDEL) and 4.4 µg/L as a monthly average (AMEL). These QBELs are calculated without dilution.

- c. *Immediate Compliance Infeasible* The feasibility study asserts the Discharger cannot immediately comply with these WQBELs. Based on the Board staff's statistical analysis the Discharger's effluent data from October 1999 through April 2004, the Board determined that the assertion of infeasibility is substantiated for copper (see the attached Fact Sheet for detailed results of the statistical analysis).
- d. *Interim Performance Based Effluent Limits (IPBLs)* Because it is infeasible for the Discharger to immediately comply with the copper WQBELs, an IPBL is required. The IPBL is the more stringent of the previous NPDES permit limit or recent WWTP performance. Board staff's statistical analysis indicates the 99.87th percentile value of the WWTPs' recent copper effluent data is 19 µg/L, which is lower than the 22 µg/L IPBL developed for the previous NPDES Permit. Therefore, this Order establishes the copper IPBL as 19 µg/L, as a daily maximum.
- e. *Plant Performance and Attainability* During the period October 1999 through April 2004, the WWTPs' effluent MEC for copper was 16.34 µg/L. Since all effluent copper values were below the 19 µg/L IPBL, it is feasible for the WWTPs to comply with the IPBL.
- f. *Term of IPBL* The copper IPBL shall remain in force until March 31, 2008 or until the Board amends the limit based on additional data, site-specific objectives.

63. Lead

- a. *RPA Results* This Order establishes effluent limits for lead because the 6.5 µg/L maximum ambient background concentration exceeds the governing WQC of 4.8 µg/L, demonstrating reasonable potential by Trigger 2, above. The governing WQC is computed using CTR procedures. The attached Fact Sheet contains further details about the computation of the lead WQC.
- b. *WQBELs* The lead WQBELs calculated according to SIP procedures are 8.8 µg/L MDEL AMEL and 3.5 µg/L AMEL. These WQBELs are calculated without dilution.
- c. *Plant Performance and Attainability* Board staff statistically analyzed the effluent lead data for the period October 1999 through April 2004. The statistical analysis indicates the 99.87th percentile of recent plant performance is the same as the MEC, 3.0 µg/L. This value is below the 8.8 µg/L MDEL, and it is feasible for the WWTPs to comply with the WQBELs.

64. Mercury

- a. *RPA Results* This Order establishes limits for mercury because the 0.046 µg/L mercury MEC exceeds the governing WQO of 0.025 µg/L, demonstrating reasonable potential by Trigger 1, above. The governing WQO is based on the Basin Plan's 4-day average saltwater objective [Basin Plan Table 3-3, pg. 3-9].
- b. *WQBELs* The mercury WQBELs calculated according to SIP procedures are 0.039 µg/L MDEL and 0.021 µg/L AMEL. These WQBELs are calculated without dilution.
- c. *Immediate Compliance Infeasible* The feasibility study asserts the Discharger cannot immediately comply with the mercury WQBELs. Board staff statistically analyzed the

Discharger's effluent data from October 1999 through April 2004 and determined that the assertion of infeasibility is substantiated for mercury (see the attached Fact Sheet for detailed results of the statistical analysis).

- d. *IPBL* Due to the infeasibility of the Discharger immediately complying with the mercury WQBELs, this Order establishes a monthly average mercury IPBL of 0.087 µg/L. The 2001 mercury staff report identified two statistically derived IPBLs for mercury, 0.023 µg/L for advanced secondary treatment plants and 0.087 µg/L for secondary treatment plants. Since the Discharger operates secondary treatment plants, the appropriate mercury IPBL for its discharge is 0.087 µg/L, taken as a monthly average.
- e. *Interim Mercury Mass Emission Limit* In addition to the concentration-based mercury IPBL, this Order continues the existing permit's annual mercury mass loading limit of 0.655 kilograms per year (kg/yr) that the Board established in 1999 and the mass-based trigger of 0.020 kilograms per month (kg/mo) that the Board established in 2003. The mass-loading trigger is based on the 99.87th percentile of mercury mass loading data from December 1999 through November 2003, and the Board finds that a recalculation is not necessary as these data should be representative of current conditions. It requires additional actions if exceeded, as specified in Provision E.9. The attached Fact Sheet describes the mass limits' rationale and computation in greater detail.
- f. *Plant Performance and Attainability* During the period May 1999 through April 2004, the Discharger's combined effluent mercury concentrations ranged from 0.008 µg/L to 0.101 µg/L and averaged 0.021 µg/L. Although the mercury MEC exceeds the IPBL, Board staff's statistical evaluation of the Discharger's mercury data indicates that the concentration-based IPBL is attainable. During that same time period, the 12-month moving average mercury mass emissions ranged from 0.16 kg/yr (0.013 kg/mo) to 0.23 kg/yr (0.019 kg/mo). Based on these results, the annual average mass loading limit and trigger values should be attainable by the WWTPs. The attached Fact Sheet discusses these attainability evaluations in more detail.
- g. *Expected Final Mercury Limits* When the mercury TMDL is adopted, the final mercury WQBELs and the interim mass emission limitation will be revised to conform to the assigned WLAs. Until the TMDL is adopted, the Discharger will comply with the concentration- and mass-based IPBLs to cooperate in maintaining current ambient receiving water conditions.

65. Nickel

- a. *RPA Results* This Order establishes effluent limits for nickel because the 30 µg/L maximum ambient background concentration exceeds the governing WQC of 26.3 µg/L, demonstrating reasonable potential by Trigger 2, above. The governing WQC is computed using CTR procedures and a site-specific translator of 0.27. The attached Fact Sheet contains further details about the nickel site-specific translator and WQC computation.
- b. *WQBELs* The nickel WQBELs calculated according to SIP procedures are 32 µg/L MDEL and 21 µg/L AMEL. These WQBELs are calculated without dilution because this is a shallow-water discharge.

- c. *Plant Performance and Attainability* During the period October 1999 through April 2004, the 99.87th percentile of the WWTPs' effluent nickel performance was 6.0 µg/L, below the 32 µg/L AMEL. Therefore, it is feasible for the WWTPs to comply with the IPBL.

66. Cyanide

- a. *RPA Results.* This Order establishes cyanide WQBELs because the 7.3 µg/L cyanide MEC exceeds the 1 µg/L WQC, demonstrating reasonable potential by Trigger 1, above.
- b. *Cyanide Water Quality Criteria.* The NTR contains saltwater a Criterion Maximum Concentration (CMC) and a Criterion Chronic Concentration, both 1 µg/L, governing cyanide for the protection of aquatic life in marine waters. These CMC and CCC values are below the presently achievable reporting limits, currently ranging from about 3 to 5 µg/L.
- c. *WQBELs.* The cyanide WQBELs calculated according to SIP procedures are 1 µg/L MDEL and 0.61 µg/L AMEL.
- d. *Immediate Compliance Infeasible* The feasibility study asserts the Discharger cannot immediately comply with the cyanide WQBELs. The detected values of cyanide in the discharge ranged from 2.8 µg/L to 7.1 µg/L, all exceeding the MDEL. Therefore, the assertion of infeasibility is substantiated.
- e. *IPBL.* Since the Discharger cannot comply with the cyanide WQBELs, this Order establishes an IPBL for cyanide. The SIP specifies that the IPBL is the more stringent of the previous NPDES permit's limit or recent WWTP plant performance, unless antidegradation is satisfied. Statistical analysis of recent cyanide effluent data indicates a 99.87th percentile value of 9.2 µg/L. This Order establishes the 9.2 µg/L cyanide IPBL, taken as a daily maximum, even though it is higher than the previous NPDES Permit's 5µg/L limit, for the reasons outlined in the antidegradation discussion in section h., below. This limit is in compliance with antibacksliding for the reasons described in the findings above, as well as in compliance with antidegradation.
- f. *WWTP Performance and Attainability.* During the period November 1998 through December 2002, the MEC for cyanide was 7.3 µg/L. Board staff's evaluation of the subject discharge data indicates that it is feasible for the WWTP to comply with the 9.2 µg/L IPBL.
- g. *Term of IPBL.* The cyanide IPBL shall remain effective until January 31, 2010 or until the Board amends the limits based on additional data or cyanide SSOs.
- h. *Anti-degradation.* Anti-degradation is satisfied because the receiving waters are in attainment for cyanide, and the new IPBL is based on recent plant performance, so no increase in cyanide loading will result.
- i. *Participation in Ongoing Studies.* The Discharger has participated in regional discharger-funded studies to improve understanding of the relationship between chlorine dosage and cyanide formation, and for development of a cyanide SSO applicable to the receiving water. The collaborative cyanide study plan was submitted to the Board on October 29, 2001. The attached Fact Sheet describes these studies, their interim results, and strategies

for further studies in more detail. Provision E.4 requires the Discharger's continued participation in these collaborative studies.

- j. *Future cyanide RPA.* If detection limits improve such that the Discharger can measure cyanide levels at or below the WQCs, Board staff will conduct a revised RPA based on the new data. The Board may include a revised final limit based on the RPA and the study results in a future permit revision.

67. Dioxin TEQ.

- a. *RPA Results.* Dioxin TEQ monitoring show no detected values in the effluent, but the levels of detection are above the CTR criterion. The May 15, 2003, BACWA *San Francisco Bay Ambient Water Monitoring Interim Report* contains monitoring results from sampling events in 2002 and 2003 for priority pollutants not monitored by the RMP, including dioxin (the interim data). While these interim data were not used to evaluate for dioxin reasonable potential based on Trigger 2, above, they show elevated dioxin levels in San Francisco Bay at the Yerba Buena Island station. (Dioxin sampling and analysis was not performed at the San Pablo Bay RMP station). Based on these data and the 303(d) list's inclusion of dioxins and furans for San Pablo Bay, Board staff have determined that there is reasonable potential for dioxin under Trigger 3, above.
- b. *Dioxin Water Quality Criteria.* The CTR establishes a numeric human health WQC of 0.014 picograms per liter (pg/L, equal to 0.000001 $\mu\text{g/L}$) for 2,3,7,8-tetrachlorinated dibenzo-p-dioxin (2,3,7,8-TCDD), based on consumption of aquatic organisms.
 - i. The CTR preamble states that California NPDES permits should use toxicity equivalents (TEQs) where dioxin-like compounds have reasonable potential under narrative criteria. The preamble further states that the U.S. EPA intends to use the 1998 World Health Organization Toxicity Equivalence Factor scheme (WHO TEF) in the future, and encourages California to use it in State programs. The U.S. EPA intends to adopt revised water quality criteria guidance following their health reassessment of dioxin-like compounds.
 - ii. The 1998 WHO TEF scheme includes dioxin-like PCBs. Since the CTR's "Total PCBs" category already includes dioxin-like PCBs, including a specific standard for them, this Order's version of the TEF does not include dioxin-like PCBs. Board staff used TEQs to translate the narrative WQOs to numeric WQOs for the other 16 congeners.
 - iii. The final limits for dioxin TEQ will be based on the dioxin TMDL and applicable WLAs.
- c. *Dioxin Monitoring.* The detection limits historically used by the Discharger are insufficient to accurately determine the presence concentrations of dioxin congeners in its discharge. The SIP does not specify an ML for dioxin analysis. This Order requires additional dioxin monitoring to complement the Clean Estuary Project's special dioxin project, consisting of impairment assessment and a conceptual model for dioxin loading into the Bay.

68. 4,4'-DDE, 4,4'-DDD, Dieldrin, and Heptachlor Epoxide

- a. *RPA Results.* This Order establishes limits for 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide because the ambient background concentrations of those pollutants, (0.001159 g/L, 0.001159 g/L, 0.000237 µg/L, and 0.000121 g/L, respectively) exceed the governing WQCs, demonstrating reasonable potential by Trigger 2, above.
- b. *Water Quality Criteria.* The CTR's governing WQCs for 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide are the human health values of 0.00059 µg/L, 0.00084 µg/L, 0.00014 µg/L, and 0.00011 µg/L, respectively. These criteria are well below the MLs of 0.05 µg/L, 0.01 µg/L, and 0.01 µg/L, respectively identified in the SIP's Appendix 4.
- c. *WQBELs.* The WQBELs calculated according to SIP procedures are detailed in Table 3, below.

Table 3. Final and interim effluent limitations for 4,4'-DDE, 4,4'-DDD, dieldrin and heptachlor epoxide.

Pollutant	Final WQBELs		IPBLs, Monthly Average, µg/L*
	MDEL, µg/L	AMEL, µg/L	
4,4'-DDE	0.00059	0.00029	0.05
4,4'-DDD	0.00169	0.00084	0.05
Dieldrin	0.00029	0.00014	0.01
Heptachlor Epoxide	0.00022	0.00011	0.01

Footnote for Table 3:

* IPBLs are taken as monthly averages.

- d. *Immediate Compliance Infeasible.* All effluent samples for 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide were non-detect, with detection limits above the relevant WQCs. Therefore, it is infeasible for the Discharger to achieve immediate compliance. The Discharger will continue its existing pollution prevention efforts for these pollutants, as described in the feasibility study.
- e. *Interim Effluent Limitation.* The previous NPDES Permit does not contain effluent limits for 4,4'-DDE, 4,4'-DDD, dieldrin, or heptachlor epoxide. The SIP contains MLs for these compounds that are above the WQCs. The Discharger cannot accurately determine, and the Board cannot verify, compliance at levels below the MLs. Therefore, this Order sets the IPBLs at the lowest level at which the Discharger can demonstrate compliance, the individual MLs specified by the SIP, as depicted in Table 3, above.
- f. *WWTP Performance and Attainability.* None of these compounds was detected in samples collected from the WWTPs' effluent in the period October 1999 – April 2004. The lowest detection limits for those samples were all below the relevant MLs, indicating the Discharger can comply with the IPBLs.
- g. *Term of Interim Effluent Limits.* The 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide interim effluent limits shall remain effective until January 31, 2010, or until the Board amends the limits based on additional data, SSOs, or the TMDL's WLAs.

- h. *Anti-backsliding/Anti-degradation.* Anti-backsliding and anti-degradation provisions do not apply to the IPBLs for these compounds because there were no WQBELs for them in the previous permit.

Whole Effluent Acute Toxicity

69. The whole-effluent acute toxicity limits contained in this Order are unchanged from the previous NPDES Permit. Compliance evaluation is based on 96-hour flow-through bioassays. All bioassays shall be performed according to the most current U.S. EPA approved method in 40 CFR 136, currently "Methods for Measuring the Acute Toxicity of Effluents and Receiving Water, 5th Edition."

Whole Effluent Chronic Toxicity

70. This Permit includes the Basin Plan narrative toxicity objective as the applicable chronic toxicity effluent limit. The permit requirements for chronic toxicity are also consistent with the CTR and SIP requirements. The chronic toxicity monitoring requirements contained in this Permit are based on the Basin Plan narrative toxicity objective and BPJ, and consistent with U.S. EPA and State Board Task Force guidance, the CTR, and SIP requirements. They are implemented through monitoring and using numeric values as triggers to initiate accelerated monitoring and a chronic toxicity reduction evaluation (TRE) if needed.

Bacteriological Limits

71. This Order includes bacteriological effluent limits using enterococcus instead of the total coliform limits included in the previous NPDES Permit. These enterococcus limits are established subject to the Discharger performing, within one year of the effective date of this Permit, a study demonstrating that the enterococcus limits are fully protective of the water quality and beneficial uses of the receiving water. The requirement for this confirmatory study, and the consequences of not performing it, are further described in Effluent Limitations, below.

Effluent and Receiving Water Pollutant Monitoring for the SIP

72. Board finds that the effluent and ambient background monitoring data are insufficient to determine reasonable potential and calculate numeric WQBELs for some pollutants listed in the SIP.
73. The SIP states that each Board shall require major and minor POTWs and industrial dischargers in its region to conduct effluent monitoring for the 2,3,7,8-TCDD congeners whether or not an effluent limit is required for 2,3,7,8-TCDD. The monitoring is intended to assess the presence and amounts of the congeners being discharged to inland surface waters, enclosed bays, and estuaries. The State Board will use these monitoring data to develop strategies for a future approach to control these chemicals in multiple environmental media.
74. On August 6, 2001, the Board sent all the permitted dischargers a letter pursuant to Section 13267 of the California Water Code requiring the submittal of effluent and receiving water data on priority pollutants (the August 6, 2001 letter). This formal request for technical information addresses the insufficient effluent and ambient background data, and the dioxin study.

75. The Discharger has submitted workplans and sampling results for characterizing the levels of selected pollutants in the effluent and ambient receiving water pursuant to the August 6, 2001 letter.

Self Monitoring Program

76. The Self Monitoring Program (SMP) attached to this Order (included here by reference), requires monitoring at the individual WWTP outfalls (E-001 and E-002) for conventional pollutants, and at the combined outfall (E-003) for toxic pollutants, acute toxicity, and chronic toxicity. The SMP provides that sampling and analysis specified at E-003 may be physically collected at E-003, or may be reported as flow-weighted averages of the individual plants' results. The Board has determined that periodic performance monitoring is appropriate for major WWTPs like those operated by the Discharger. The SMP maintains the previous NPDES permit's TSS monitoring frequency of three (3) times per week as an effective and relatively inexpensive method to evaluate day-to-day performance. The SMP requires monthly monitoring during the discharge season for copper, lead, mercury, nickel, and cyanide to demonstrate compliance with effluent limits. The SMP also requires monitoring twice during each discharge season for 4,4-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide to demonstrate compliance with their IPBLs. The SMP also requires twice yearly monitoring for dioxins and furans using methods with lower detection limits. Until analytical methods improve and MLs are lowered, monitoring more frequently than twice yearly will not generate more useful data. Finally, the SMP requires the Discharger to conduct annual sampling pursuant to the requirements of the Board's August 6, 2001 letter requiring, under the authority of Section 13267 of the California Water Code, that the Discharger conduct further sampling to characterize select priority pollutants.

Optional Mass Offset

77. This Order contains requirements to prevent further degradation of the receiving water, including interim mass limits based on WWTP performance, provisions for aggressive source control, feasibility studies for wastewater reclamation, and WWTP optimization. After implementing these efforts, the Discharger may find that further net reductions of its total mass loadings of the 303(d)-listed pollutants to the receiving water can only be achieved through a mass offset program. This Order includes an optional provision for a mass offset program.

NPDES Permit, Notification and Public Hearing

78. *NPDES Permit.* This Order serves as an NPDES Permit, adoption of which is exempt from the provisions of Chapter 3 (commencing with Section 21100) of Division 13 of the Public Resources Code [California Environmental Quality Act (CEQA)] pursuant to Section 13389 of the California Water Code.
79. *Notification.* The Discharger and interested agencies and persons have been notified of the Board's intent to reissue requirements for the existing discharge and have been provided an opportunity to submit their written views and recommendations. Board staff prepared a Fact Sheet and Response to Comments, which are hereby incorporated by reference as part of this Order.

80. *Public Hearing.* The Board, in a public meeting, heard and considered all comments pertaining to the discharge.

IT IS HEREBY ORDERED, pursuant to the provisions of Division 7 of the California Water Code, regulations, and plans and policies adopted thereunder, and to the provisions of the Clean Water Act and regulations and guidelines adopted thereunder, that the Discharger shall comply with the following:

A. DISCHARGE PROHIBITIONS

1. Discharge of wastewater at any point where it does not receive a minimum initial dilution of 10:1, or into dead-end slough and similar confined waters is prohibited, except as specified here. Based on findings above, an exception to this Prohibition is granted for the discharge of treated effluent during the period from September 1 through May 31 annually, provided the Discharger continues to work to reuse the maximum feasible amount of treated wastewater and to minimize discharges to San Pablo Bay. Discharge of treated wastewater at a location or in a manner different than that described in the findings of this Order is prohibited.
2. The bypass or overflow of untreated or partially treated wastewater to waters of the State, at the WWTPs, is prohibited, except as provided for bypasses under the conditions stated in 40 CFR 122.41(m)(4) and in Provision A.13.

The discharge of blended wastewater, that is biologically treated wastewater blended with wastewater that have been diverted around biological treatment units or advanced treatment units, is allowable only 1) during wet weather, and 2) when the discharge complies with the effluent and receiving water limitations contained in this Order. Furthermore, the Discharger shall operate the facility as designed and in accordance with the Operation and Maintenance Manuals developed for the facility. This means that the Discharger shall optimize storage and use of equalization units, and shall fully utilize the biological treatment units, and advanced treatment units if applicable. The Discharger shall report these incidents of blended effluent discharges in routine monitoring reports, and shall conduct monitoring of this discharge as specified elsewhere in this Order.

3. The average dry weather flow discharge shall not exceed 6.55 MGD, apportioned as follows: Novato Plant 4.53 MGD, Ignacio Plant 2.02 MGD. The average dry weather flow shall be determined over three consecutive dry weather months each year.
4. Discharge to San Pablo Bay is prohibited during the dry weather period from June 1 through August 31, unless it is pursuant to a specific request made by the Discharger and approved by the Executive Officer. This request may be submitted by telephone or in writing, and must fully explain the need for discharges during this period (e.g., high flows related to late spring or early fall storm events or, when reclamation is not feasible).
5. The discharge of untreated or partially treated wastewater from the collection system or pump stations to any surface water stream, natural or man-made, or to any drainage system intended to convey storm water runoff to surface waters, is prohibited. The discharge of chlorine, or any other toxic substance used for disinfection and cleanup of wastewater spills, to any surface water body is prohibited.

B. EFFLUENT LIMITS

The term "effluent" in the following limits means the fully treated wastewater effluent from the Discharger's wastewater treatment facilities, as discharged to San Pablo Bay. The effluent discharged to San Pablo Bay shall not exceed the following limits:

1. a. The effluent from the Ignacio plant (E-001) and the Novato plant (E-002), monitored separately and individually, and discharged through a common outfall to San Pablo Bay between November 1 and April 30, annually, shall not exceed the limits depicted in Table 4, below:

Table 4. Conventional Pollutant Effluent Limitations for Wet Weather Discharge (November 1 through April 30)

<i>Constituent</i>	<i>Units</i>	<i>Monthly Average</i>	<i>Weekly Average</i>	<i>Daily Maximum</i>
Biochemical Oxygen Demand (BOD ₅ , 20°C)	mg/L	30	45	--
Total Suspended Solids	mg/L	30	45	--
Oil & Grease	mg/L	10	--	20

- b. When discharge occurs between May 1 and October 31, annually, the effluent limits depicted in Table 5, below, apply to effluent from the Ignacio plant (E-001) and the Novato plant (E-002), monitored separately and individually, with the exception described in 1.c.:

Table 5. Conventional Pollutant Effluent Limitations for Dry Weather Discharge (between May 1 and October 31).

<i>Constituent</i>	<i>Units</i>	<i>Monthly Average</i>	<i>Weekly Average</i>	<i>Daily Maximum</i>
Biochemical Oxygen Demand (BOD ₅ , 20°C)	mg/L	15	30	- -
Oil and Grease	mg/L	5	--	15
Total Suspended Solids	mg/l	10	20	- -

- c. Between May 1 and October 31, annually, the interim conventional effluent limits depicted in Table 6, below, apply to E-001 separately, when discharge occurs. After March 31, 2008, the BOD and TSS limits for E-001 will be those listed in Table 5, above. The Discharger must comply with the conditions of Provision E.11, below, to continue to receive the interim conventional effluent limits for BOD and TSS.

Table 6. Interim Performance Based Conventional Pollutants Effluent Limitations for Discharges from Ignacio Treatment Plant (E-001) between May 1 and October 31, annually.

<i>Constituent</i>	Units	Interim limits ending March 31, 2008.		
		Monthly Average	Weekly Average	Daily Maximum
Biochemical Oxygen Demand (BOD ₅ , 20°C)	mg/L	22	--	44
Total Suspended Solids	mg/L	23	--	46

2. The subject discharge shall not have pH of less than 6.5 nor greater than 8.5. If the Discharger monitors pH continuously, the Discharger shall be in compliance with the pH limitation provided that both of the following conditions are satisfied: (i) The total time during which the pH values are outside the required range of pH values shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) No individual excursion from the range of pH values shall exceed 60 minutes.
3. Bacteriological Limits:
 - a. Treated wastewater from each WWTP, considered individually (E-001 and E-002) shall meet the following bacteriological limits at some point in the treatment process prior to discharge to San Pablo Bay through E-003:
 - i. 30-day geometric mean of less than 35 enterococcus MPN per 100mL; and
 - ii. No single effluent sample exceeding 276 MPN per 100mL, as verified by a follow-up sample taken within 24 hours.
 - b. Within one year of the effective date of this Permit, the Discharger will propose and perform, upon the Executive Officer's approval, a study demonstrating that the enterococcus limits are fully protective of the water quality and beneficial uses of the receiving water. If this confirmatory study is not performed by one year from the effective date of this Permit, or if it indicates the enterococcus limits are not fully protective of the water quality and beneficial uses of the receiving water, then the previous NPDES permit's total coliform-based bacteriological limits will be reapplied.
4. *85 Percent Removal* The arithmetic mean of the biochemical oxygen demand (BOD₅, 20°C) and total suspended solids values (TSS), by concentration, for effluent samples collected in each calendar month shall not exceed 15 percent of the arithmetic mean of the respective values, by concentration, for influent samples collected at approximately the same times during the same period for each of the two treatment plants measured separately (85 per cent removal). This 85 per cent removal standard applies to each treatment plant individually (E-001 and E-002).
5. *Chlorine Residual:* The effluent discharged from E-003 shall not contain a chlorine residual concentration greater than 0.0 mg/l at any time except during the non-discharge season when effluent is discharged to the reclamation storage ponds. This concentration requirement is defined as below the limit of detection in standard test methods defined in the latest edition of *Standard Methods for the Examination of Water and Wastewater*. The Discharger may elect to use a continuous on-line monitoring system(s) for measuring flows, chlorine and sodium bisulfite dosage (including a safety factor) and concentration to demonstrate that chlorine residual exceedences are false positives. If adequate evidence is provided, Board staff will

conclude that these false positive chlorine residual exceedences are not violations of this permit limit.

6. *Ammonia* The ammonia in the combined effluent shall not exceed 6.0 mg/L as a monthly average.

Toxicity Testing

7. Whole Effluent Acute Toxicity:

- a. Representative samples of the subject discharge (E-003) shall meet the following limits for acute toxicity. Bioassays shall be conducted in compliance with Provision E.6.
 - i. The survival of bioassay test organisms in 96-hour bioassays of undiluted effluent shall be:
 - a) An eleven (11)-sample median value of not less than 90 percent survival; and
 - b) An eleven (11)-sample 90th percentile value of not less than 70 percent survival.
 - b. These acute toxicity limits are further defined as follows:
 - i. *11-sample median limit*: Any bioassay test showing survival of 90 percent or greater is not a violation of this limit. A bioassay test showing survival of less than 90 percent represents a violation of this effluent limit, if five or more of the past ten or fewer bioassay tests also show less than 90 percent survival.
 - ii. *90th percentile limit*: Any bioassay test showing survival of 70 percent or greater is not a violation of this limit. A bioassay test showing survival of less than 70 percent represents a violation of this effluent limit, if one or more of the past ten or fewer bioassay tests also show less than 70 percent survival.
- c. Bioassays shall be performed using the most up-to-date U.S. EPA protocol and the most sensitive species as specified in writing by the Executive Officer based on the most recent screening test results. Bioassays shall be conducted in compliance with "Methods for Measuring The Acute Toxicity of Effluents and Receiving Water To Freshwater and Marine Organisms", currently 5th Edition (EPA-821-R-02-012), with exceptions granted to the Discharger by the Executive Officer and the Environmental Laboratory Accreditation Program (ELAP) upon the Discharger's request with justification. The Discharger shall implement future updated methods within the shortest time practicable.

8. Chronic Toxicity

- a. Representative samples of the subject discharge (E-003) shall meet the following requirements for chronic toxicity. Compliance with the Basin Plan narrative chronic toxicity objective shall be demonstrated according to tiered requirements specified in Provision F.8, below.

Toxic Substances

9. The discharge of combined effluent (E-003) containing constituents in excess of the following limitations is prohibited:

Table 7. Effluent limitations for toxic substances in combined effluent.

Constituent ^[1]	Unit	MDEL ^[4]	AMEL ^[4]	Interim Monthly Average ^[4]	Interim Daily Maximum ^[4]	Compliance Deadline for MDEL and AMEL
Copper	µg/L	6.4	4.4	--	19	3/31/2008
Lead	µg/L	8.8	3.5	--	--	--
Mercury ^[2]	µg/L	--	--	0.087		3/31/2010
Nickel	µg/L	32	21	--	--	--
Cyanide ^[3]	µg/L	--	--	--	9.2	1/31/2010
4,4'-DDE	µg/L	--	--	--	0.05	1/31/2010
4'4'-DDD	µg/L	--	--	--	0.05	1/31/2010
Dieldrin	µg/L	--	--	--	0.01	1/31/2010
Heptachlor Epoxide	µg/L	--	--	--	0.01	1/31/2010

Footnotes for Table 7:

- [1] (a) Compliance with these limits is intended to be achieved through wastewater treatment and, as necessary, pretreatment and source control.
- (b) All analyses shall be performed using current U.S. EPA methods, or equivalent methods approved in writing by the Executive Officer
- (c) Limits apply to the average concentration of all samples collected during the averaging period (Daily = 24-hour period; Monthly = calendar month).
- [2] Effluent mercury monitoring shall be performed using ultraclean sampling and analysis techniques to the maximum extent practicable.
- [3] Cyanide: Compliance may be demonstrated by measurement of weak acid dissociable cyanide, EPA Method 335.2, or EPA Method OIA 1677.
- [4] Daily maximum or average monthly sample results for individual constituents shall be considered non-compliance with the relevant effluent limits only if they exceed both the effluent limitation and the ML for that constituent, as depicted in Table 4, of the attached Self Monitoring Program.

10. Mercury Mass Limit and Mass Trigger

The Discharger shall demonstrate that the current mercury mass loading to the receiving water does not increase by complying with the following annual mass load and monthly mass trigger.

The attached Fact Sheet describes the calculation of the annual mass load and monthly trigger in more detail.

- a. The 12-month moving average annual load for mercury shall not exceed **0.655 kg/year**. Compliance shall be calculated using moving average flows and concentrations for the entire year (during both discharge and reclamation months).
- b. If the 12-month moving average monthly mass loading for mercury exceeds the trigger value of **0.020 kg/month**, the Discharger shall initiate the actions specified in Provision E.9. This trigger value is based on discharge season data only.
- c. Compliance determinations for annual mass limit and monthly mass trigger shall use the following computations:

$$\text{Annual Mass Emission, kg / year} = \sum (\text{Monthly Mass Emission Rates, kg / month})$$

where

$$\text{Monthly Mass Emission, kg / month} = 0.003785 * \left(\frac{\sum_{i=1}^n C_i}{n} \right) * (\text{Total Monthly Flow, Millions of Gallons})$$

and where:

n = number of samples collected per month;
 C_i = Mercury sample concentrations, µg/L.
 0.003785 = conversion factor, for converting (concentration)·(flow) into kilograms per day (kg/day)

- d. The Discharger shall include a table presenting cumulative total mass loadings for the previous 12 months with each monthly Self-Monitoring Report. Compliance for each month will be determined based on the 12-month moving averages over the previous 12 months of monitoring calculated using the method described in section B.10.c above. The Discharger may use monitoring data collected under accelerated schedules (i.e., special studies) to determine compliance.
- e. The mercury TMDL and WLAs will supersede this interim mass emission limitation once the Board implements them.

C. RECEIVING WATER LIMITS

1. The discharge of waste shall not cause the following conditions to exist in waters of the State at any place:
 - a. Floating, suspended, or deposited macroscopic particulate matter or foam;
 - b. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;

- c. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
 - d. Visible, floating, suspended, or deposited oil or other products of petroleum origin; and/or
 - e. Toxic or other deleterious substances to be present in concentrations or quantities that cause exceedence of the narrative toxicity objective contained in the Basin Plan.
2. The discharge of waste shall not cause the following limits to be exceeded in waters of the State any one place within one foot of the water surface:
 - a. Dissolved Oxygen: 5.0 mg/L, minimum

The median dissolved oxygen concentration for any three consecutive months shall not be less than 80% of the dissolved oxygen content at saturation. When natural factors cause concentrations less than that specified above, then the discharge shall not cause further reduction in ambient dissolved oxygen concentrations.
 - b. Dissolved Sulfide: 0.1 mg/L, maximum
 - c. pH: Variation from normal ambient pH by more than 0.5 pH units.
 - d. Un-ionized Ammonia: 0.025 mg/L as N, annual median

0.16 mg/L as N, max.
 - e. Nutrients: Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses.
3. The discharge shall not cause a violation of any particular water quality standard for receiving waters adopted by the Board or the SWRCB as required by the Clean Water Act and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to Section 303 of the Clean Water Act, or amendments thereto, the Board may revise and modify this Order in accordance with such more stringent standards.

D. BIOSOLIDS/SLUDGE REQUIREMENTS

1. All sludge treatment, processing, storage or disposal activities under the Discharger's control shall be in compliance with current state and federal regulations.
2. Sludge shall not be applied to the dedicated disposal site between October 30 and May 1 unless prior written authorization is obtained from the Executive Officer.
3. Sewage sludge disposed of at the storage lagoons and dedicated disposal site shall be limited to digested sewage sludge generated by the Discharger and sludge from NMWD's water treatment facility unless an exception is authorized by the Executive Officer.

4. Disposal of sludge in the dedicated disposal site shall not adversely impact beneficial uses of the groundwater or Novato Creek.
5. The Discharger shall notify the Board, in writing, of any significant changes in its sludge disposal practices.
6. The treatment, processing, storage or disposal of sludge conducted by the Discharger shall not create a condition of pollution or nuisance as defined in Section 13050 (l) and (m) of the California Water Code.
7. The treatment, processing, storage or disposal of sludge by the Discharger shall not cause waste material to be discharged to, or deposited in, waters of the State. Pooled water or runoff from the disposal area shall not be discharged to adjacent land or ditches discharging to surface waters. Sludge storage facilities shall be operated and maintained in such a manner as to provide adequate protection from surface runoff, erosion, or other conditions, which would cause drainage from the waste materials to escape from the storage facility site(s).
8. Disposal of municipal wastewater solids by surface disposal and operation of a surface disposal site are regulated by the U.S. EPA under the 40 CFR 503 regulations (Standards for The Use or Disposal of Sewage Sludge). Waste discharge requirements for sludge disposal are waived under the condition that the Discharger complies with all provisions of 40 CFR Part 503. As required by Water Code Section 13269, the finding is made that this waiver is not against the public interest, as the activity is adequately regulated by the Federal regulations at 40 CFR Part 503.
9. The Discharger is required to submit an annual report to the U.S. EPA regarding its sewage sludge disposal practices in accordance with the requirements of 40 CFR 503. The Discharger shall submit a copy of this report to the Board by February 28 of the following year.

E. PROVISIONS

1. Permit Compliance and Rescission of Previous Waste Discharge Requirements

The Discharger shall comply with all sections of this Order beginning on the effective date of this NPDES Permit. Requirements prescribed by this Order supersede the requirements prescribed by Order No. 99-036 and Order No. R2-2003-002. Order No. 99-036 and Order No. R2-2003-002 are hereby rescinded upon the effective date of this Order.

2. Copper Study and Schedule - Regional Site-Specific Objective Study for Copper

The Discharger shall continue its participation in the regional discharger-funded effort to develop site-specific saltwater aquatic life-based WQOs for copper in San Francisco Bay north of the Dumbarton Bridge, as described in the copper findings, above. The Discharger shall also participate in the development of Copper Action Plans, acceptable to the Executive Officer, designed to ensure that copper concentrations will not increase unacceptably in the receiving water as a result of controllable discharges. The Action Plans will describe baseline actions for wastewater and storm water dischargers and a program of additional monitoring and actions to be taken by those dischargers, triggered by specified increases in ambient copper concentrations.

3. Cyanide Compliance Schedule and Cyanide SSO Study

The Discharger shall comply with the following tasks and deadlines:

Tasks	Compliance Date
a. <i>Compliance Schedule.</i> The Discharger should track relevant national studies, and participate in regional studies as described in the cyanide findings. The Discharger shall also investigate the relationship between cyanide formation and chlorine dose, as chlorine dosage is reduced under this permit's new bacterial limits. Results from these studies should enable the Board to determine feasibility of compliance with final WQBELS during the next permit reissuance.	Annual progress reports with the first report due November 1, 2005
b. <i>SSO Study.</i> The Discharger shall actively participate in the development of regional SSOs for cyanide.	Annual progress reports by cyanide work group.
c. Conduct evaluation of compliance attainability with appropriate final limitations.	February 1, 2007

4. Pollutant Prevention and Minimization Program (PMP)

- a. The Discharger shall continue to conduct and improve its existing Pollution Prevention Program to reduce loadings of pollutants such as copper, mercury, cyanide, 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide to the WWTPs and therefore to the receiving waters.
- b. The Discharger shall submit an annual report, acceptable to the Executive Officer, no later than February 28th of each year. Annual reports shall cover January through December of the preceding year. Annual reports shall include at least the following information:
 - i. A brief description of its WWTPs, WWTP processes and service area.
 - ii. A discussion of the current pollutants of concern. Periodically, the Discharger shall identify which pollutants are currently a problem or which may be potential future problems, and shall include the reasons why the pollutants were chosen.
 - iii. A discussion of how the Discharger intends to estimate and identify sources of the pollutants. The Discharger shall also identify sources or potential sources not directly within the ability or authority of the Discharger to control such as pollutants in the potable water supply and air deposition.
 - iv. A discussion and prioritization of tasks to address the Discharger's pollutants of concern. The Discharger may implement tasks itself or participate in group, regional, or national tasks that will address its pollutants of concern. Identified tasks shall include timelines for implementing each one. The Discharger is strongly encouraged

to participate in group, regional, or national tasks that will address its pollutants of concern whenever it is efficient and appropriate to do so..

- v. Discussion of the Discharger's outreach efforts to employees. The Discharger shall inform employees about the pollutants of concerns, potential sources, and how they might be able to help reduce the discharge of pollutants of concern into the WWTP. The Discharger may provide a forum for employees to provide input to the Program.
 - vi. Description of the Discharger's continued public outreach program to communicate pollution prevention to its service area. Outreach may include participation in existing community events such as county fairs, initiating new community events such as displays and contests during Pollution Prevention Week, conducting school outreach program, conducting WWTP tours, and providing public information in newspaper articles or advertisements, radio, television stories or spots, newsletters, utility bill inserts, and web site. Information shall be specific to the target audiences. The Discharger shall coordinate with other agencies as appropriate.
 - vii. Discussion of criteria used to measure the Program's and tasks' effectiveness, including establishing criteria to evaluate the effectiveness of its Pollution Prevention Program. This shall also include a discussion of the specific criteria used to measure the effectiveness of each of the tasks in item b. (iv), b. (v), and b. (vi).
 - viii. Documentation of efforts and progress detailing all of the Discharger's activities in the Pollution Prevention Program during the reporting year.
 - ix. Evaluation of Program's and tasks' effectiveness, using the criteria established in b. (vii) to evaluate the Program's and tasks' effectiveness.
 - x. Identification of specific tasks and time schedules for future efforts, detailing how it intends to continue or change its tasks to more effectively reduce the amount of pollutants to the WWTP, and subsequently in its effluent.
- c. According to Section 2.4.5 of the SIP, when there is evidence that a priority pollutant is present in the effluent above an effluent limitation and either:
- i. A sample result is reported as detected, but not quantified (less than the Minimum Level) and the effluent limitation is less than the reported Minimum Level,
 - ii. A sample result is reported as not detected (less than the Method Detection Limit) and the effluent limitation is less than the Method Detection Limit; or,
 - iii. The dioxin TEQ exceeds the WQO (0.014 pg/L); then

the Discharger shall expand its existing Pollution Prevention Program to include the reportable priority pollutant. A priority pollutant becomes a reportable priority pollutant when (1) there is evidence that it is present in the effluent above an effluent limitation and either (c)(i), c(ii), or (c) (iii) is triggered or (2) if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reported Minimum Level.

- d. If triggered by the reasons in c. above, and notified by the Executive Officer, the Discharger's Pollution Prevention Program shall, within 6 months, also include:
 - i. An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling, or alternative measures approved by the Executive Officer when it is demonstrated that source monitoring is unlikely to produce useful analytical data;
 - ii. Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system, or alternative measures approved by the Executive Officer when it is demonstrated that influent monitoring is unlikely to produce useful analytical data;
 - iii. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
 - iv. Development of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
 - v. An annual status report that shall be sent to the Board including:
 - a) All Pollution Prevention monitoring results for the previous year;
 - b) A list of potential sources of the reportable priority pollutant(s);
 - c) A summary of all actions undertaken pursuant to the control strategy; and
 - d) A description of actions to be taken in the following year.
 - vi. To the extent that the requirements of the Pollution Prevention Program and the Pollutant Minimization Program overlap, the Discharger is allowed to continue, modify, or expand its existing Pollution Prevention Program to satisfy the Pollutant Minimization Program requirements.
 - vii. These Pollution Prevention/Pollutant Minimization Program requirements are not intended to fulfill the requirements in The Clean Water Enforcement and Pollution Prevention Act of 1999 (Senate Bill 709).

5. Pretreatment

- a. Pretreatment Program: The Discharger shall implement and enforce its approved pretreatment program in accordance with Federal Pretreatment Regulations (40 CFR 403), pretreatment standards promulgated under Section 307(b), 307(c), and 307(d) of the Clean Water Act, pretreatment requirements specified under 40 CFR 122.44(j), and the requirements in Attachment H, "Pretreatment Requirements." The Discharger's responsibilities include, but are not limited to:
 - i) Enforcement of National Pretreatment Standards in accordance with 40 CFR 403.5 and 403.6;

- ii) Implementation of its pretreatment program in accordance with legal authorities, policies, procedures and financial provisions described in the General Pretreatment regulations (40 CFR 403) and the Discharger's approved pretreatment program;
 - iii) Submission of reports to, the State Board and the Board, as described in Attachment E, "Pretreatment Requirements;"
 - iv) Evaluate the need to revise local limits under 40 CFR 403.5(c)(1); and within 180 days after the effective date of this Order, submit a report acceptable to the Executive Officer describing the changes with a plan and schedule for implementation.
- b. The Discharger shall implement its approved pretreatment program and the program shall be an enforceable condition of this permit. If the Discharger fails to perform the pretreatment functions, the Board, the State Water Resources Control Board, or the U.S. EPA may take enforcement actions against the Discharger as authorized by the Clean Water Act.

6. Whole Effluent Acute Toxicity

The Discharger shall maintain compliance with acute toxicity requirements contained in this Order in accordance with the following:

- a. Determining compliance by measuring survival of test organisms exposed to 96-hour continuous flow-through bioassays. Test organisms shall be fathead minnows unless specified otherwise in writing by the Executive Officer.
- b. All bioassays shall be performed according to the most up-to-date protocols in 40 CFR Part 136, "Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms," currently in its 5th Edition. Upon the Discharger's request with justification, exceptions may be granted to the Discharger by the Executive Officer and the Environmental Laboratory Accreditation Program (ELAP). The Discharger shall comply with future updates as soon as practicable after their adoption.

7. Whole Effluent Chronic Toxicity

The Discharger shall monitor and evaluate the effluent from the treatment plant for chronic toxicity in order to demonstrate compliance with the Basin Plan narrative toxicity objective. Compliance with this requirement shall be demonstrated by the following.

- a. The Discharger shall conduct routine chronic toxicity monitoring in accordance with the SMP of this Order.
- b. If data from routine monitoring exceed either of the following evaluation parameters, then the Discharger shall conduct accelerated chronic toxicity monitoring. Accelerated monitoring shall consist of monitoring at frequency intervals of one half the interval given for routine monitoring in the SMP of this Order.
- c. Chronic toxicity evaluation parameters:
 - i. A three sample median value of 1 TUc; and

- ii. A single sample maximum value of 2 TU_c.
- iii. These parameters are defined as follows:
 - a) Three-sample median: A test sample showing chronic toxicity greater than 1 TU_c represents an exceedence of this parameter, if one of the past two or fewer tests also show chronic toxicity greater than 1 TU_c.
 - b) TU_c (chronic toxicity unit): A TU_c equals 100/NOEL (e.g., If NOEL = 100, then toxicity = 1 TU_c). NOEL is the no observed effect level determined from IC, EC, or NOEC values.
 - c) The IC, EC, NOEL and NOEC, values and their use are defined in Attachment A of the Self-Monitoring Program (SMP).
- d. If data from accelerated monitoring tests are found to be in compliance with the evaluation parameters, then routine monitoring shall be resumed.
- e. If accelerated monitoring tests continue to exceed either evaluation parameter, then the Discharger shall initiate a chronic toxicity reduction evaluation (TRE).
- f. The TRE shall be conducted in accordance with the following:
 - i. The Discharger shall submit a TRE workplan acceptable to the Executive Officer. The Board encourages the Discharger to prepare a generic TRE workplan and keep it on hand should it be needed for a toxicity event. The workplan shall be reviewed and updated as necessary in order to remain current and applicable to the subject discharge and discharge facilities.
 - ii. The TRE shall be initiated within 30 days of the date of completion of the accelerated monitoring test observed to exceed either evaluation parameter.
 - iii. The TRE shall be conducted in accordance with the approved workplan, as it may be amended by the Executive Officer.
 - iv. The TRE needs to be specific to the subject discharge and Discharger facility, and may be in accordance with current technical guidance and reference materials including U.S. EPA guidance materials. TRE should be conducted as a tiered evaluation process, such as summarized below:
 - a) Tier 1 consists of basic data collection (routine and accelerated monitoring).
 - b) Tier 2 consists of evaluation of optimization of the treatment process including operation practices, and in-plant process chemicals.
 - c) Tier 3 consists of a toxicity identification evaluation (TIE).
 - d) Tier 4 consists of evaluation of options for additional effluent treatment processes.

- e) Tier 5 consists of evaluation of options for modifications of in-plant treatment processes.
- f) Tier 6 consists of implementation of selected toxicity control measures, and follow-up monitoring and confirmation of implementation success.
- v. The TRE may be ended at any stage if monitoring finds there is no longer consistent toxicity.
- vi. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity. All reasonable efforts using currently available TIE methodologies should be employed.
- vii. As toxic substances are identified or characterized, the Discharger shall continue the TRE by determining the source(s) and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with chronic toxicity evaluation parameters.
- viii. Many recommended TRE elements parallel required or recommended efforts of source control, pollution prevention and storm water control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements or recommended efforts of such programs may be acceptable to comply with TRE requirements.
- ix. The Board recognizes that chronic toxicity may be episodic and identification of causes of and reduction of sources of chronic toxicity may not be successful in all cases. Consideration of enforcement action by the Board will be based in part on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.
- g. Chronic Toxicity Monitoring Screening Phase Requirements, Critical Life Stage Toxicity Tests and definitions of terms used in the chronic toxicity monitoring are identified in Attachment A of the SMP. The Discharger shall comply with these requirements as applicable to the discharge.

8. Mercury Mass Loading Reduction

If mass loading for mercury exceeds the trigger level specified in Effluent Limit B.10 of this Order, then the following actions shall be initiated and subsequent reports shall include but not be limited to the following:

- a. *Notification.* Any exceedence of the trigger specified in Effluent Limitation B.10.b. shall be reported to the Board in accordance with Section E.6.b. in the Standard Provisions and Reporting Requirements (August, 1993).
- b. *Identification of the problem.* Immediately resample to verify the increase in loading. If resampling confirms that the mass loading trigger has been exceeded, determine whether the exceedence is flow or concentration-related. If the exceedence is flow-related, identify whether it is related to changes in reclamation, increase in the number of sewer connections, increases in infiltration and inflow (I/I), wet weather conditions or unknown

sources. If the exceedence is concentration-related, identify whether it is related to industrial, commercial, residential or unknown sources.

c. *Investigation of corrective action.* Investigate the feasibility of the following actions:

- (1) Reducing inflow and infiltration (I/I)
- (2) Increasing reclamation

Within 60 days after confirmed exceedence of trigger, develop a plan and include time schedule as short as practicable, and acceptable to the Executive Officer to implement all reasonable actions to maintain mercury mass loadings at or below the mass loading trigger contained in Effluent Limitation B.10.b.

d. *Investigation of aggressive prevention/reduction measures.* In the event the exceedence is related to growth and the plan required under (c) above is not expected to keep mercury loads below the mass load trigger, the Discharger shall submit a plan, acceptable to the Executive Officer, including, but not limited to, an initiative to work with the local planning department to investigate the feasibility and potential benefits of requiring water conservation, reclamation, and dual plumbing for new development. This plan should be implemented as soon as practicable.

9. Bacteriological Studies

The Discharger shall propose a confirmation study to be implemented upon approval by the Executive Officer. The confirmation study shall demonstrate that:

- a. the enterococcus limits included in this Order are protective of the designated uses of the receiving water, and
- b. the receiving water adjacent to the combined discharge (E-003) is consistent with the U.S. EPA water contact scenario of "lightly used area," specifically including water quality data.

Upon approval by the Executive Officer, the Discharger shall implement the confirmation study and report its results not later than 1 year from the Executive Officer's approval.

10. Reclamation pond operation

During the wet weather discharge period (November 1 through April 30), treated wastewater from the storage ponds may be discharged directly through the combined outfall, if it meets the requirements of the Discharger's Reclamation Pond Wet Season discharge Sediment Control and Monitoring Plan.

Water held in the reclamation ponds before being discharged through the combined outfall during the dry weather discharge months (May, September, and October) may be discharged if it meets all the requirements in this Order. Pre-discharge monitoring of water held in the reclamation ponds is required during the dry weather discharge period (May 1 – 31 and September 1 – October 31, annually).

11. Compliance schedule for conventional effluent limitations at Ignacio Plant

The Discharger shall submit semiannual progress reports on its attainment of the tasks and time schedule described in Attachment G for the Ignacio plant attaining compliance with the final technology-based effluent limits for Biochemical Oxygen Demand (BOD₅, 20°C) and Total Suspended Solids (TSS) by March 31, 2008. The reports shall be received by the Executive officer by January 31 and July 31, annually. Besides the semiannual reports, the Discharger shall notify the Executive Officer in writing within 30 days of any suspension or redirection of its strategic plan.

12. 303(d)-listed Pollutants Site-Specific Objective and TMDL Status Review

The Discharger shall participate in the development of TMDLs or site-specific objectives for copper, mercury, 4,4'-DDE, 4,4'-DDD, and dieldrin. By January 31 of each year, the Discharger shall submit an update to the Board to document its participation efforts toward development of the TMDL(s) or site-specific objective(s). The Discharger may meet this update requirement by continuing its participation in BACWA's cooperative efforts to accelerate development of Water Quality Attainment Strategies, as described in findings, above. However, should BACWA not submit its required progress reports on time, then the Discharger will remain responsible for the annual progress update. This Order may be reopened in the future to reflect any changes required by TMDL development.

13. Optional Mass Offset

The Discharger may submit to the Board, for approval, a mass offset plan to reduce 303(d)-listed pollutants to the same watershed or drainage basin. The Board may modify this Order to allow an approved mass offset program.

14. Sanitary Sewer Management Plan

The Discharger shall fully participate in BACWA's collaborative program to develop guidelines for sanitary sewer management plans (SSMPs). The Discharger shall develop and implement a Discharger-specific SSMP, acceptable to the Executive Officer, as quickly as feasible once BACWA's guidance is available. As part of its SSMP, the Discharger shall report sanitary sewer overflows (SSOs) electronically as soon as the Board's electronic SSO reporting system is available, even if that capability precedes the development of the Discharger's SSMP.

15. Blending Monitoring Study

The Discharger shall comply with the following tasks and deadlines:

Tasks	Compliance Date
a. <i>Blending Study Plan.</i> The Discharger shall propose a study plan, acceptable to the Executive Officer. The study plan shall propose monitoring effluent for the purpose of demonstrating that TSS is an appropriate indicator of compliance with other effluent limitations during blending events.	6 months following effective date of permit
b. <i>Blending Final Report.</i> The Discharger shall submit a report, acceptable to the Executive Officer. The report shall include an analysis of TSS as an indicator of compliance with effluent limitations, and a recommendation for a TSS trigger value. The purpose of the TSS trigger is for use in triggering additional monitoring (Table 2 and Table 3 of the SMP) during blending events.	June 30, 2006

16. Implementation and Enforcement of Prohibition A.5

- a. *Enforcement consideration.* In any enforcement action, the Board will consider the Discharger's efforts in containing, controlling, and cleaning up SSOs. The Board will also consider the Discharger's efforts in sewer rehabilitation. These considerations are part of the factors required by Section 13327 of the California Water Code.

The Discharger shall make every practicable effort to contain SSOs and to prevent the wastewater from entering storm drains and surface water bodies.

Prohibition A.5. is not violated under either of the following:

- i. If the SSO does not enter a storm drain or surface water body, or
- ii. If the Discharger contains the SSO within the storm drain system pipes, and fully recovers and cleans up the spilled wastewater.

However these incidents of SSOs shall be reported to the Board as SSOs as stipulated in SMP Section V.7.

- b. *Discharges caused by severe natural conditions.* The Board may take enforcement action against the Discharger for any sanitary sewer system discharge caused by natural conditions, unless the Discharger demonstrates through properly signed, contemporaneous operating logs, or other relevant evidence that,

- i.* Relevant sewer maintenance/repair logs including the associated costs of sewer rehabilitation, cleaning/flushing, inspection, and replacement for the pipe section where the SSO occurred; and
- ii.* Information relating to storm event, such as size of the storm, length of such storm during the SSO.

16. Wastewater Facilities, Review and Evaluation, and Status Reports

- a. The Discharger shall operate and maintain its wastewater collection, treatment, and disposal facilities in a manner to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary, in order to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger's service responsibilities.
- b. The Discharger shall regularly review and evaluate its wastewater facilities and operation practices in accordance with section a. above. Reviews and evaluations shall be conducted as an ongoing component of the Discharger's administration of its wastewater facilities.
- c. The Discharger shall provide the Executive Officer, upon his or her request, a report describing the current status of its wastewater facility review and evaluation, including any recommended or planned actions and an estimated time schedule for these actions. The Discharger shall also include, in each Annual Self-Monitoring Report, a description or summary of review and evaluation procedures, and applicable wastewater facility programs or capital improvement projects.

17. Operations and Maintenance Manual, Review and Status Reports.

- a. The Discharger shall maintain an O & M Manual as described in the findings of this Order for the Discharger's wastewater facilities. The O & M Manual shall be maintained in usable condition, and available for reference and use by all applicable personnel.
- b. The Discharger shall regularly review, revise, or update, as necessary, the O & M Manual(s) so that the document(s) may remain useful and relevant to current equipment and operation practices. Reviews shall be conducted annually, and revisions or updates shall be completed as necessary. For any significant changes in treatment facility equipment or operation practices, applicable revisions shall be completed within 90 days of completion of such changes.
- c. The Discharger shall provide the Executive Officer, upon his or her request, a report describing the current status of its operations and maintenance manual, including any recommended or planned actions and an estimated time schedule for these actions. The Discharger shall also include, in each Annual Self-Monitoring Report, a description or summary of review and evaluation procedures, and applicable changes to, its operations and maintenance manual.

18. Contingency Plan, Review and Status Reports

- a. The Discharger shall maintain a Contingency Plan as required by Board Resolution 74-10 (available online—see Standard Language and Other References Available Online, below), and as prudent in accordance with current municipal facility emergency planning. The discharge of pollutants in violation of this Order where the Discharger has failed to develop and/or adequately implement a contingency plan will be the basis for considering such discharge a willful and negligent violation of this Order pursuant to Section 13387 of the California Water Code.
- b. The Discharger shall regularly review, and update as necessary, the Contingency Plan so that the plan may remain useful and relevant to current equipment and operation practices. Reviews shall be conducted annually, and updates shall be completed as necessary.
- c. The Discharger shall provide the Executive Officer, upon his or her request, a report describing the current status of its contingency plan, including any recommended or planned actions and an estimated time schedule for these actions. The Discharger shall also include, in each Annual Self-Monitoring Report, a description or summary of review and evaluation procedures, and applicable changes to, its contingency plan.

19. Self-Monitoring Program

The Discharger shall comply with the Self-Monitoring Program (Attachment C). The Self Monitoring Program may be amended by the Executive Officer pursuant to U.S. EPA regulations 40 CFR 122.63.

20. Standard Provisions and Reporting Requirements

The Discharger shall comply with all applicable items of the Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits, August 1993 (the Standard Provisions - available online – see References Available Online, below), including any amendments thereto. Where provisions or reporting requirements specified in this Order are different from equivalent or related provisions or reporting requirements given in the Standard Provisions, the specifications of this Order shall apply.

21. Change in Control or Ownership

- a. In the event of any change in control or ownership of land or waste discharge facilities presently owned or controlled by the Discharger, the Discharger shall notify the succeeding owner or operator of the existence of this Order by letter, and shall immediately forward a copy of said letter to the Executive Officer.
- b. Any succeeding owner must apply in writing to the Executive Officer requesting transfer of this Order (per Section E.4 of the Standard Provisions) to assume responsibility for and control of operations under this Order. Failure to submit the request shall be considered a violation of the California Water Code for discharging without Waste Discharge Requirements.

22. Permit Reopener

The Board may modify or reopen this Order and Permit prior to its expiration date in any of the following circumstances:

- a. Present or future investigations demonstrate that the discharge(s) governed by this Order and Permit will have, or will cease to have, reasonable potential to cause or contribute to adverse impacts on the receiving water's water quality, beneficial uses, or both;
- b. New or revised WQOs come into effect for the receiving water (whether statewide, regional, or site-specific), requiring modification of effluent limits contained in this Order (Adoption of effluent limitations contained in this Order and Permit is not intended to restrict in any way future modifications based on legally adopted WQOs or as otherwise permitted under Federal regulations governing NPDES permit modifications.);
- c. An adopted TMDL or SSO requires modification of limits contained in this Permit;
- d. Translator or other water quality studies provide a basis for determining that one or more permit conditions should be modified;
- e. An administrative or judicial decision on a separate NPDES Permit or WDR that addresses requirements similar to this discharge; and
- f. As authorized by law.

The Discharger may request permit modification based on b, c, d and e above, and shall include an antidegradation and antibacksliding analysis with any such request.

23. NPDES Permit Effective Date

This Order shall serve as a National Pollutant Discharge Elimination System (NPDES) permit pursuant to Section 402 of the Clean Water Act or amendments thereto, and shall become effective on February 1, 2005, provided the U.S. EPA Regional Administrator has no objection. If the Regional Administrator objects to its issuance, the permit shall not become effective until such objection is withdrawn.

24. Order Expiration and Reapplication

- a. This Order expires on December 31, 2009.
- b. In accordance with Title 23, Chapter 3, Subchapter 9 of the California Administrative Code, the Discharger must file a report of waste discharge no later than 180 days before the expiration date of this Order as application for reissue of this permit and waste discharge requirements. The application shall be accompanied by a summary of all available water quality data including conventional pollutant data from no less than the most recent three years, and of toxic pollutant data no less than from the most recent five years, in the discharge and receiving water. Additionally, the application shall be accompanied with the results of the whole effluent chronic toxicity screening study specified in Part B of the Self-Monitoring Program.

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

I, Bruce Wolfe, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on November 17, 2004.

BRUCE H. WOLFE
EXECUTIVE OFFICER

Attachments:

- A. Discharge Facility Location Map
- B. Discharge Facility Treatment Process Diagram
- C. Self-Monitoring Program, Part B
- D. Fact Sheet
- E. July 22, 2004 *Novato Sanitary District Infeasibility Study*
- F. July 22, 2004 *Novato Sanitary District Copper and Nickel Translator Calculation*
- G. April 28, 2004 *Workplan for Ignacio Treatment Plant, NPDES Permit No. CA0037955*
- H. Pretreatment Program Requirements
- I. The following documents are part of this Permit, but are not physically attached due to volume. They are available on the internet at www.swrcb.ca.gov/rwqcb2/Download.htm
 - Self-Monitoring Program, Part A, adopted August 1993
 - Standard Provisions and Reporting Requirements, August 1993
 - Board Resolution No. 74-1
 - June 11, 2001 Board Staff Report *Statistical Analysis of Pooled Data from Regionwide UltraClean Mercury Sampling for Municipal Dischargers*.
 - August 6, 2001 Board Staff Letter: *Requirement for Priority Pollutant Monitoring in Receiving Water and Wastewater Discharges*

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment A.
Discharge Facility Location Map

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment B.
Discharge Facility Treatment Process Diagram

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment C.
Self-Monitoring Program, Part B

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

SAN FRANCISCO BAY REGION

SELF-MONITORING PROGRAM

FOR

NOVATO SANITARY DISTRICT

NOVATO, MARIN COUNTY

NPDES PERMIT NO. CA0037958

ORDER NO. R2-2004-0093

Consists of:

**Part A, Adopted August 1993
(Not attached)**

And

Part B, Effective February 1, 2005

(Attached)

Table Of Contents

I.	Station Descriptions	3
II.	Schedule Of Sampling, Analyses And Observations	4
III.	Specifications for Sampling and Analysis	9
IV.	Recording Requirements.....	10
V.	Reporting Requirements	10
VI.	Selected Constituents Monitoring	13
VII.	Monitoring Methods And Minimum Detection Levels	13
VIII.	Self-Monitoring Program Certification.....	13
	Enclosure:	13

List of Tables

Table 1.	Schedule Of Influent Sampling, Analyses And Observations.	4
Table 2.	Schedule Of Individual Plants' Effluent Sampling, Analyses And Observations	4
Table 3.	Schedule Of Combined Plants' Effluent Sampling, Analyses And Observations	5
Table 4.	Minimum Levels	7
Table 5.	Pretreatment Monitoring Requirements	8
Table 6.	Additional pollutant monitoring.....	9

I. Station Descriptions

NOTE: A sketch showing the locations of all sampling and observation stations shall be included in the Annual Report, and in the monthly report if stations change.

<u>Station</u>	<u>Description</u>
A. INFLUENT	
A-001	At any point in the Ignacio treatment plant's headworks at which all waste tributary to that plant is present and preceding any phase of treatment.
A-002	At any point in the Novato treatment plant's headworks at which all waste tributary to that plant is present and preceding any phase of treatment.
B. EFFLUENT	
E-001	At any point in the Ignacio treatment plant's outfall between the point of discharge and the point at which all waste tributary to that outfall is present, and where adequate contact with the disinfectant is assured.
E-002	At any point in the Novato treatment plant's outfall between the point of discharge and the point at which all waste tributary to that outfall is present, and where adequate contact with the disinfectant is assured.
E-003	At any point in the dechlorination facilities at which all waste from both treatment plants has been disinfected and dechlorinated.
C. LAND OBSERVATIONS	
P001-1 thru P-001-'n'	Located at the periphery of the Ignacio plant, at equidistant intervals, not to exceed 200 feet. (A sketch showing the locations of these stations will accompany each report).
P002-1 thru P-002-'n'	Located at the periphery of the Ignacio plant, at equidistant intervals, not to exceed 200 feet. (A sketch showing the locations of these stations will accompany each report).
D. OVERFLOWS AND BYPASSES	
OV-1 thru OV-'n'	Bypass or overflows from manholes, pump stations, collection systems or any sludge drying bed areas.
E. SLUDGE	
The Discharger shall continue to analyze sludge on a semi-annual basis for priority pollutant metals and organics.	

II. Schedule Of Sampling, Analyses And Observations

The schedule of sampling, analysis and observation shall be that given in Tables 1, 2, and 3, below. Sampling and analyses specified at E-003 may be physically collected at E-003, or may be reported as flow-weighted averages of the individual plants' results. Sampling and analysis of additional constituents is required pursuant to the Water Board's August 6, 2001 Letter titled *Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy*, as delineated in Table 6, below. This additional pollutant monitoring shall be carried out annually until the Discharger's application for reissuance of this NPDES permit.

During blending events as defined in Provision A.2.b of the Permit, 24-hour composite samples or grabs will be collected daily at the individual plants' outfalls and analyzed for TSS and enterococcus. If the TSS or enterococcus values exceed the limitations contained in the Permit (45 mg/L for TSS, and 276 MPN per 100ml for enterococcus), the effluent will be sampled daily for all constituents listed in Tables 2 and 3 below until the flow detectors indicate there have been no bypass events for 24 hours. If there are no enterococcus exceedences associated with blending events at the Novato plant during the first wet season after permit adoption, the District may apply to the Executive Officer for reduction or elimination of enterococcus sampling during blending events

Table 1. Schedule Of Influent Sampling, Analyses And Observations.

SAMPLING STATION		A-001	A-002
TYPE OF SAMPLE [1]	Notes	C-24 [1] [2]	C-24 [1] [2]
BOD ₅ 20°C, or CBOD (mg/L & kg/d)	[15]	2/W	2/W
Total Suspended Solids (mg/L & kg/d)	[15]	3/W	3/W
Pretreatment Requirements µg/L or ppb	[13]	M	M

Footnote for Table 1.

[1] Influent flow monitoring is not required because neither the Ignacio plant (A-001) nor the Novato Plant (A-002) has influent flow measuring.

Table 2. Schedule Of Individual Plants' Effluent Sampling, Analyses And Observations

SAMPLING STATION		E-001 and E-002		All P	All OV
TYPE OF SAMPLE	Notes	G [1]	C-24 [1] [2]	O [1]	O [1]
Flow Rate (MGD)	[3]		Cont/D		
BOD ₅ 20°C, or CBOD (mg/L & kg/d)	[15]		2/W		
Oil and Grease (mg/L & kg/d)	[4]		M		
Total Suspended Solids (mg/L & kg/d)	[15]		3/W		
pH (s.u.)	[14]	5/W			
Temperature (°C)		5/W			
Standard Observations				M	E
Pretreatment Requirements µg/L or ppb	[13]	M			
Chlorine Dosage, mg/L	[12]	D			

SAMPLING STATION		E-001 and E-002	All P	All OV
TYPE OF SAMPLE	Notes	G [1]	C-24 [1] [2]	O [1]
Enterococcus (MPN/100 ml)	[16]	3/W		

Table 3. Schedule Of Combined Plants' Effluent Sampling, Analyses And Observations

SAMPLING STATION		E-003	All P	All OV
TYPE OF SAMPLE	Notes	G [1]	C-24 [1] [2]	O [1]
Chlorine Residual (mg/L & kg/d)		H or continuous		
Acute Toxicity (% survival)	[6]		M	
Chronic Toxicity	[7]		Q	
Ammonia Nitrogen (mg/L & kg/d)		3/W		
Copper (µg/L)			M	
Lead (µg/L)			M	
Mercury (µg/L)	[9]	M		
Nickel (µg/L)			M	
Cyanide (µg/L)	[10]	M		
4,4'-DDE (µg/L)		2/Y		
4,4'-DDD (µg/L)		2/Y		
Dieldrin (µg/L)		2/Y		
Heptachlor Epoxide (µg/L)		2/Y		
2,3,7,8-TCDD and congeners	[11]	2/Y		

LEGEND FOR TABLES 1, 2, and 3

Types of Samples:

C-24= composite sample, 24 hours (includes continuous sampling, such as for flows)

Cont.= continuous sampling

G= grab sample

O= observation

Frequency of Sampling:

E = Each occurrence

D = Once each day

Cont. = continuous monitoring

Cont/D = continuous monitoring & daily reporting

M = once each month

W = once each week

Y = once each calendar year

2/Y = Two times a year; one in wet season, one in dry season.

H = every hour

Q = once each calendar quarter

(with at least two-month intervals)

Parameter and Unit Abbreviations:

BOD₅ 20°C = Biochemical Oxygen Demand, 5-day, at 20°C

CBOD₅ 20°C = Carbonaceous BOD, 5-day, at 20 °C

TSS = Total Suspended Solids

MGD =million gallons per day

mg/L = milligrams per liter

ml/L-hr = milliliters per liter, per hour

µg/L= micrograms per liter

pg/L = picograms per liter

kg/day = kilograms per day

kg/mo = kilograms per month

FOOTNOTES FOR TABLES 1, 2, and 3

- [1] The Discharger shall use approved USEPA Methods with the lowest Minimum Levels specified in the SIP and described in footnote 1 of effluent limitations B.7, and in the August 6, 2001, letter.
- [2] Composite sampling: 24-hour composites may be made up of discrete grabs collected over the course of a day and volumetrically or mathematically flow-weighted. Samples for inorganic pollutants may be combined prior to analysis. If only one grab sample will be collected, it should be collected during periods of maximum peak flows. Samples shall be taken on random days.
- [3] Flow Monitoring: Effluent flows shall be measured continuously at Outfalls E-001 and E-002, and recorded and reported daily
- [4] Oil & Grease Monitoring: Each Oil & Grease sample event shall consist of a composite sample comprised of three grab samples taken at equal intervals during the sampling date, with each grab sample being collected in a glass container. The grab samples shall be mixed in proportion to the instantaneous flow rates occurring at the time of each grab sample, within an accuracy of plus or minus 5 %. Each glass container used for sample collection or mixing shall be thoroughly rinsed with solvent rinsing as soon as possible after use, and the solvent rinsing shall be added to the composite sample for extraction and analysis.
- [6] Acute Toxicity: If specific identifiable substances in the discharge can be demonstrated by the discharger as being rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written approval from the Executive Officer must be obtained to authorize such an adjustment. An example is pH adjustment to control the formation of unionized ammonia. In this example, the Discharger must first demonstrate that ammonia is the cause of the observed toxicity using phase 3 (confirmation) toxicity identification evaluations. The Discharge must then show that based on the conditions in the receiving water, the ammonia that is in the discharge does not cause any violation of the un-ionized ammonia receiving water limits outside the zone of initial dilution.

Bioassays: Effluent used for fish bioassays must be dechlorinated prior to testing. Monitoring of the bioassay water shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia nitrogen, and temperature. These results shall be reported. If a violation of acute toxicity requirements occurs, a new bioassay test shall be started as soon as practicable and testing should continue back to back until compliance is demonstrated.

- [7] Chronic Toxicity: Chronic toxicity testing shall be performed in accordance with the requirements specified in Section III.B, below. During blending events, the Discharger is not required to monitor for chronic toxicity.

1.

Chronic Toxicity Reporting Requirements

- a. Routine Reporting: Toxicity test results for the current reporting period shall include, at a minimum, for each test:
- (1) Sample date(s)
 - (2) Test initiation date
 - (3) Test species
 - (4) End point values for each dilution (e.g. number of young, growth rate, percent survival)
 - (5) NOEC value(s) in percent effluent
 - (6) IC₁₅, IC₂₅, IC₄₀, and IC₅₀ values (or EC₁₅, EC₂₅ ... etc.) in percent effluent
 - (7) TUC values (100/NOEC, 100/IC₂₅, or 100/EC₂₅)
 - (8) Mean percent mortality (\pm s.d.) after 96 hours in 100% effluent (if applicable)
 - (9) NOEC and LOEC values for reference toxicant test(s)
 - (10) IC₅₀ or EC₅₀ value(s) for reference toxicant test(s)
 - (11) Available water quality measurements for each test (pH, D.O., temperature, conductivity, hardness, salinity, ammonia)
- b. Compliance Summary: The results of the chronic toxicity testing shall be provided in the most recent self-monitoring report and shall include a summary table of chronic toxicity data from at least eleven of the most recent samples. The information in the table shall include the items listed above under Note [7] 2.a, item numbers 1, 3, 5, 6(IC₂₅ or EC₂₅), 7, and 8.

- [9] The Discharger may, at their option, sample mercury either as grab or 24-hr composite. Use ultra-clean sampling (USEPA 1669) to the maximum extent practicable, and ultra-clean analytical methods (USEPA 1631) for mercury monitoring. The Discharger may use alternative methods of analysis (such as USEPA 245), if that alternate method has a Minimum Level of 2 ng/L or less.

- [10] The Discharger may, at their option, analyze for cyanide as Weak Acid Dissociable Cyanide using protocols specified in Standard Method Part 4500-CN-I, USEPA Method OI 1677, USEPA Method 335.2, or equivalent alternatives in latest edition. Alternative methods of analysis must be approved by the Executive Officer.
- [11] Chlorinated Dibenzo-dioxins and Chlorinated Dibenzo-furans shall be analyzed using the latest version of USEPA Method 1613. Alternative methods of analysis must be approved by the Executive Officer. The analysis shall be capable of achieving one half the EPA method 1613 MLs. The Discharger shall also collect four liter samples to lower the detection limit to the greatest extent practicable.
- [12] Chlorine Residual Monitoring. During all times when chlorination is used for disinfection of the effluent, effluent chlorine residual concentrations shall be monitored continuously, or by grab samples taken hourly. Chlorine residual concentrations shall be monitored and reported for sampling points both prior to and following dechlorination. Total chlorine dosage (mg/l & kg/day) shall be recorded on a daily basis.
- [13] Pretreatment Program Requirements: see Table 5, below.
- [14] Daily minimum and maximum for pH shall be reported.
- [15] Percent removal for BOD and TSS (effluent vs. influent) shall also be reported.
- [16] The approved methods for the Enterococcus analysis are Enterolert, Membrane Filtration, or multiple tube fermentation. The Discharger may submit a request to the Executive Officer for a reduction in sampling frequency once it has collected 24 months of data demonstrating consistence compliance with the effluent bacterial limitations.

Table 4. Minimum Levels

For compliance monitoring, analyses shall be conducted using the lowest commercially available and reasonably achievable detection levels. The objective is to provide quantification of constituents sufficient to allow evaluation of observed concentrations with respect to the Minimum Levels given below. All Minimum Levels are expressed as µg/L, approximately equivalent to parts per billion (ppb).

CTR #	Constituent [a]	Types of Analytical Methods [b]						
		GC	GCMS	Color	GFAA	ICPMS	SPGFAA	CVA
6.	Copper					0.5	2	
7.	Lead					0.5		
8.	Mercury[c]							0.002
9.	Nickel				5	1	5	
14.	Cyanide			5				
109.	4,4'-DDE	0.05						
	4,4'-DDD	0.05						
111.	Dieldrin	0.01						
	Heptachlor Epoxide	0.01						
16.	2,3,7,8-TCDD[d]							

Footnotes to Table 4 of Self-Monitoring Program:

- [a] According to the SIP, method-specific factors (MSFs) can be applied. In such cases, this additional factor must be applied in the computation of the reporting limit. Application of such factors will alter the reported ML (as described in section 2.4.1). Dischargers are to instruct laboratories to establish calibration standards so that the ML value is the lowest calibration standard. At no time is the Discharger to use analytical data derived from the extrapolation beyond the lowest point of the calibration curve.
- [b] Laboratory techniques are defined as follows:

GC = Gas Chromatography;
 GCMS = Gas Chromatography/Mass Spectrometry;
 Color = Colorimetric;
 GFAA = Graphite Furnace Atomic Absorption;

ICPMS = Inductively Coupled Plasma/Mass Spectrometry;
 SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e. EPA 200.9); and
 CVAFA = Cold Vapor Atomic Fluorescence.

[c] Use ultra-clean sampling and analytical methods for mercury monitoring per August 6, 2001 Letter issued to Discharger. The ML for mercury is 0.002 µg/L.

[d] The SIP does not contain a ML for this constituent.

Table 5. Pretreatment Monitoring Requirements

Constituents	Sample Locations, Frequency, and Analytical Method.		
	Influent A-001 and A -002	Effluent E-001 and E-002	Sludge [2]
VOC	2/Y 624	2/Y 624	2/Y 8260
BNA	2/Y 625	2/Y 625	2/Y 8260
Metals [1]	M	M	2/Y

Definition of terms in Table 3:

M = once each month

2/Y = twice each calendar year at about 6-month intervals (once in November and once in April)

VOC = volatile organic compounds

BNA = base/neutrals and acids extractable organic compounds

Key to notes used in Table 3:

[1] Same EPA method used to determine compliance with the respective NPDES permit. The parameters are copper, lead, mercury, nickel, silver, zinc, and cyanide.

[2] EPA approved methods.

Table 6. Additional pollutant monitoring.

Constituent	Suggested Analytical Method	Sample Type
Metals (except mercury, and hexavalent chromium)	GFAA or ICP, and Gas hydride AA for As and Se	24 hr composite
Hexavalent chromium ¹	Standard Method 3500	grab
Volatile and semi-volatile organics	EPA 601, 602, 603, 604, 606, 610, 624 ² (HPLC) or equivalent GC/MS method ³	grab
Other organics, chlorinated pesticides and PCBs (w/ TS) ⁴	EPA 625, 608	grab
Organophosphate pesticides	EPA 614	24-hr composite

III. Specifications for Sampling and Analysis

Sampling, analyses and observations, and recording and reporting, of results shall be conducted in accordance with the schedule given in Tables 1, 2, and 3, as applicable, of this SMP, with the following specifications, and with all other applicable requirements given in this SMP. All analyses shall be conducted using analytical methods that are commercially and reasonably available, and that provide quantification of sampling parameters and constituents sufficient to evaluate compliance with applicable effluent limits.

A. Influent Monitoring

Influent monitoring identified in Table 1 of Part B of this Self-Monitoring Program is the minimum required monitoring. Additional sampling and analyses may be required in accordance with Pretreatment Program or Pollution Prevention/Source Control Program requirements.

B. Chronic Toxicity Monitoring Requirements

1. Sampling. The Discharger shall collect 24-hour composite samples of WWTP's effluent at the compliance point station specified in Table 3 of the Self-Monitoring Program, for critical life stage toxicity testing as indicated below. For toxicity tests requiring renewals, 24-hour composite samples collected on consecutive days are required.
2. Test Species: Chronic toxicity shall be monitored by using critical life stage test(s) and the most sensitive test species identified by screening phase testing or previous testing conducted under the ETCP. The Discharger shall conduct routine monitoring with the species approved by the

¹ Total Chromium may be substituted to for Hexavalent Chromium at the discharger's discretion.

² if the method detection limits (MDL) can be demonstrated to fall below the minimum levels (ML) listed in Table 4 for the GC methods (EPA 601 and 602)

³ The equivalent GC/MS method must be able to quantify to an equivalent level as the GC methods listed above.

Executive Officer. At the time of this permit adoption, the approved species is the Water Flea (*Ceriodaphnia dubia*).

3. Conditions for Accelerated Monitoring: The Discharger shall conduct accelerated monitoring when either of the following conditions is exceeded:
 - a. Three sample median value of 1 TUc, or
 - b. Single sample maximum value of 2 TUc.
4. Methodology: Sample collection, handling and preservation shall be in accordance with U.S. USEPA protocols. The test methodology used shall be in accordance with the references cited in this Permit, or as approved by the Executive Officer. A concurrent reference toxicant test shall be performed for each test.
5. Dilution Series: The Discharger shall conduct tests at 6.25 percent effluent as discharged (%), 12.5%, 25%, 50%, and 100%.

IV. Recording Requirements

- A. General Recording Requirements are described in Section E of Part A of the Self-Monitoring Program.
- B. Any bypass, overflow, or significant non-compliance incident shall be recorded according to Sections E.1. and E.2. of Part A.

V. Reporting Requirements

- A. General Reporting Requirements are described in Section E of the Regional Board's *Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits*, dated August 1993, and Part A of the Self-Monitoring Program.
- B. Modifications to Self-Monitoring Program, Part A:
 1. If any discrepancies exist between Part A and Part B of the SMP, Part B prevails.
 2. Section C1: reference to influent samples (for the Novato Plant) excluding sidestreams from sludge storage pond supernatant, digester supernatant, filter backwash, and DAF supernatant. It is not possible to obtain an influent sample that does not contain these sidestreams.
 3. Sections C.3. and C.5. are satisfied by participation in the Regional Monitoring Program.
 4. Modify Section F.1 as follows:

Spill Reports

A report shall be made of any spill of oil or other hazardous material. The spill shall be reported by telephone as soon as possible and no later than 24 hours following occurrence or discharger's knowledge of occurrence. Spills shall be reported by telephone as follows:

During weekdays, during office hours of 8 am to 5 pm, to the Board: Current telephone number: (510) 622 - 2300, (510) 622-2460 (FAX).

During non-office hours, to the State Office of Emergency Services: Current telephone number: (800) 852 - 7550.

A report shall be submitted to the Board within five (5) working days following telephone notification, unless directed otherwise by Board staff. A report submitted by facsimile transmission is acceptable for this reporting. The written report shall contain information relative to: . . .

5. Modify Section F.3 as follows:

Reports of Plant Bypass, Treatment Unit Bypass and Permit Violation

The following requirements apply to all treatment plant bypasses and significant non-compliance occurrences, except for bypasses under the conditions contained in 40 CFR Part 122.41 (m)(4) as stated in Standard Provision A.13. In the event the Discharger violates or threatens to violate the conditions of the waste discharge requirements and prohibitions or intends to experience a plant bypass or treatment unit bypass due to: . . .

6. Modify Section F.4 as follows:

Self-Monitoring Reports

For each calendar month, a self-monitoring report (SMR) shall be submitted to the Regional Board in accordance with the requirements listed in Self-Monitoring Program, Part A. The purpose of the report is to document treatment performance, effluent quality and compliance with waste discharge requirements prescribed by this Order, as demonstrated by the monitoring program data and the Discharger's operation practices. The report shall be submitted to the Board by the first day of the second month after the month being reported on. . . .

[And add at the end of Section F.4 the following:]

- g. The Discharger has the option to submit all monitoring results in an electronic reporting format approved by the Executive Officer. The format currently in use was approved by the Executive Officer in a letter dated December 17, 1999, titled *Official Implementation of Electronic Reporting System (ERS)*. The ERS format includes, but is not limited to, a transmittal letter, summary of violation details and corrective actions, and transmittal receipt. If there are any discrepancies between the ERS requirements and the "hard copy" requirements listed in the SMP, then the approved ERS requirements supercede.

7. Add at the end of Section F.5, Annual Reporting, the following:

- d. A plan view drawing or map showing the Dischargers' facility, flow routing and sampling and observation station locations.

8. Add as Section F.6 the following:

Reports of Overflows

Until the Board completes development of its electronic sanitary sewer overflow reporting system, overflows of sewage from the Discharger's collection system, other than overflows specifically addressed elsewhere in this Order and SMP, shall be reported to the Board as described below. Once the electronic sanitary sewer overflow reporting system is completed, the Discharger shall use it consistent with its requirements.

1. *Overflows in excess of 1,000 gallons*

Overflows in excess of 1,000 gallons shall be reported by telephone and written report, as follows:

- a. Overflows shall be reported by telephone as soon as possible and no later than 24 hours following occurrence or discharger's knowledge of occurrence. Notification shall be made as follows:

Notify the current Board staff inspector, or case handler, by phone conversation or message, or by facsimile (Board Fax number: (510) 622 – 2460).

- i. Notify the State Office of Emergency Services, phone number: (800) 852 - 7550.
- b. Submit a written report of the incident in follow-up to telephone notification. The written report shall be submitted along with the regular self-monitoring report for the reporting period of the incident, unless directed otherwise by Board staff, and shall include the following:
 - Estimated date and time of overflow start and end.
 - Location of overflow (street address or description of location).
 - Estimated volume of overflow.
 - Final disposition of overflowed wastewater (to land, storm drain, surface water body).
 - Include the name of any receiving water body affected.
 - Cause of overflow.
 - Observed impacts to receiving waters if any (e.g., discoloration, fish kill).
 - Corrective actions that were taken to contain, minimize or cleanup the overflow.
 - Future corrective actions planned to be taken to prevent recurrence and time schedule of implementation.
 - Persons or agencies contacted.

2. *Overflows less than 1,000 gallons*

Overflows less than 1,000 gallons shall be reported by written report, as follows:

- a. The Discharger shall prepare and retain records of such overflows, with records available for review by Board staff upon request.
- b. The records for these overflows shall include the information as listed in 1.e, above.
- c. A summary of these overflows shall be submitted to the Board annually, as part of the Discharger's Self-Monitoring Program Annual Report.

VI. Selected Constituents Monitoring

- A. Effluent monitoring shall include evaluation for all constituents listed in Tables 2 and 3 by sampling and analysis of final effluent.
- B. Analyses shall be conducted using the lowest commercially available and reasonably achievable detection levels. The objective is to provide quantification of constituents sufficient to allow evaluation of observed concentrations with respect to respective water quality objectives.

VII. Monitoring Methods And Minimum Detection Levels

The Discharger may use the methods listed in Table 4, above, or alternate test procedures that have been approved by the U.S. EPA Regional Administrator pursuant to 40 CFR 136.4 and 40 CFR 136.5 (revised as of May 14, 1999).

VIII. Self-Monitoring Program Certification

I, Bruce Wolfe, Executive Officer, hereby certify that the foregoing Self-Monitoring Program:

1. Has been developed in accordance with the procedure set forth in this Board's Resolution No. 73-16 in order to obtain data and document compliance with waste discharge requirements established in Board Order No. R2-2004-0093.
2. May be reviewed at any time subsequent to the effective date upon written notice from the Executive Officer or request from the Discharger, and revisions will be ordered by the Executive Officer.
3. Is effective as of February 1, 2005.

Bruce H. Wolfe,
Executive Officer

Enclosure:

Chronic Toxicity – Definition of Terms and Screening Phase Requirements

CHRONIC TOXICITY
DEFINITION OF TERMS & SCREENING PHASE REQUIREMENTS

I. Definition of Terms

- A. No observed effect level (NOEL) for compliance determination is equal to IC₂₅ or EC₂₅. If the IC₂₅ or EC₂₅ cannot be statistically determined, the NOEL shall be equal to the NOEC derived using hypothesis testing.
- B. Effective concentration (EC) is a point estimate of the toxicant concentration that would cause an adverse effect on a quantal, "all or nothing," response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-Kärber. EC₂₅ is the concentration of toxicant (in percent effluent) that causes a response in 25% of the test organisms.
- C. Inhibition Concentration (IC) is a point estimate of the toxicant concentration that would cause a given percent reduction in a non-lethal, non-quantal biological measurement, such as growth. For example, an IC₂₅ is the estimated concentration of toxicant that would cause a 25% reduction in average young per female or growth. IC values may be calculated using a linear interpolation method such as EPA's Bootstrap Procedure.
- D. No observed effect concentration (NOEC) is the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation. It is determined using hypothesis testing.

II. Chronic Toxicity Screening Phase Requirements

- A. The discharger shall perform screening phase monitoring:
1. Subsequent to any significant change in the nature of the effluent discharged through changes in sources or treatment, except those changes resulting from reductions in pollutant concentrations attributable to pretreatment, source control, and waste minimization efforts, or
 2. Prior to Permit reissuance. Screening phase monitoring data shall be included in the NPDES Permit application for reissuance. The information shall be as recent as possible, but may be based on screening phase monitoring conducted within 5 years before the permit expiration date.
- B. Design of the screening phase shall, at a minimum, consist of the following elements:
1. Use of test species specified in Tables 1 and 2 (attached), and use of the protocols referenced in those tables, or as approved by the Executive Officer;
 2. Two stages:
 - a. Stage 1 shall consist of a minimum of one battery of tests conducted concurrently. Selection of the type of test species and minimum number of tests shall be based on Table 3 (attached); and
 - b. Stage 2 shall consist of a minimum of two test batteries conducted at a monthly frequency using the three most sensitive species based on the Stage 1 test results and as approved by the Executive Officer.
 3. Appropriate controls; and
 4. Concurrent reference toxicant tests.
- C. The discharger shall submit a screening phase proposal to the Executive Officer for approval. The proposal shall address each of the elements listed above.

TABLE C 1
CRITICAL LIFE STAGE TOXICITY TESTS FOR ESTUARINE WATERS

SPECIES	SCIENTIFIC NAME	EFFECT	TEST DURATION	REFER-ENCE
alga	(<u>Skeletonema costatum</u>)	growth rate	4 days	1
	(<u>Thalassiosira pseudonana</u>)	growth rate		
red alga	(<u>Champia parvula</u>)	number of cystocarps	7-9 days	3
giant kelp	(<u>Macrocystis pyrifera</u>)	percent germination; germ tube length	48 hours	2
abalone	(<u>Haliotis rufescens</u>)	abnormal shell development	48 hours	2
oyster	(<u>Crassostrea gigas</u>)	abnormal shell development;	48 hours	2
mussel	(<u>Mytilus edulis</u>)	percent survival		2
echinoderms		percent fertilization	1 hour	2
urchins	(<u>Strongylocentrotus purpuratus</u> , <u>S. franciscanus</u>)	percent fertilization	1 hour	2
sand dollar	(<u>Dendraster excentricus</u>)	percent fertilization	1 hour	2
shrimp	(<u>Mysidopsis bahia</u>)	percent survival; growth; fecundity	7 days	3
silversides	(<u>Menidia beryllina</u>)	larval growth rate; percent survival	7 days	3

Toxicity Test References:

1. American Society for Testing Materials (ASTM). 1990. Standard Guide for conducting static 96-hour toxicity tests with microalgae. Procedure E 1218-90. ASTM Philadelphia, PA.
2. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms. USEPA/600/R-95/136. 1995.
3. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to Marine and Estuarine Organisms as specified in 40CFR 136. Currently, this is USEPA/600/4-90/003, July 1994. Later editions may replace this version.

TABLE C 2
CRITICAL LIFE STAGE TOXICITY TESTS FOR FRESH WATERS

SPECIES REFERENCE	(Scientific name)	EFFECT	TEST DURATION	
fathead minnow	(<u>Pimephales promelas</u>)	survival; growth rate	7 days	6
water flea	(<u>Ceriodaphnia dubia</u>)	survival; number of young	7 days	6
alga	(<u>Selenastrum capricornutum</u>)	cell division rate	4 days	6

Toxicity Test Reference:

6. Horning, W.B. and C.I. Weber (eds.). 1989. Short-term methods for estimating the chronic toxicity of effluents and receiving waters to freshwater organisms. Second edition. U.S. EPA Environmental Monitoring Systems Laboratory, Cincinnati, Ohio. EPA/600/4-89/001.

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment D.
Fact Sheet

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD

SAN FRANCISCO BAY REGION

1515 CLAY STREET, SUITE 1400

OAKLAND, CA 94612

(510) 622 – 2300 Fax: (510) 622 - 2460

FACT SHEET

for

NPDES PERMIT and WASTE DISCHARGE REQUIREMENTS for

NOVATO SANITARY DISTRICT

NOVATO, MARIN COUNTY

NPDES Permit No. CA0037958

ORDER NO. R2-2004-0093

PUBLIC NOTICE:

Written Comments

- Interested persons are invited to submit written comments concerning this draft permit.
- Comments must be submitted to the Board no later than 5:00 p.m. on October 25, 2004.
- Send comments to the Attention of Ken Katen.

Public Hearing

- The draft permit will be considered for adoption by the Board at a public hearing during the Board's regular monthly meeting at: Elihu Harris State Office Building, 1515 Clay Street, Oakland, CA; 1st floor Auditorium.
- This meeting will be held on: November 17, 2004, starting at 9:00 am.

Additional Information

- For additional information about this matter, interested persons should contact Regional Board staff member: Mr. Ken Katen, Phone: (510) 622-2485; email: kk@rb2.swrcb.ca.gov

This Fact Sheet contains information regarding a reissuance of waste discharge requirements and National Pollutant Discharge Elimination System (NPDES) permit for the Novato Sanitary District for municipal wastewater discharges. The Fact Sheet describes the factual, legal, and methodological basis for the sections addressed in the proposed permit and provides supporting documentation to explain the rationale and assumptions used in deriving the effluent limitations.

I. INTRODUCTION

- A. On November 24, 2003, the Novato Sanitary District (the Discharger), applied to the Board for reissuance of waste discharge requirements and a permit to discharge treated wastewater to waters of the State and the United States under the National Pollutant Discharge Elimination System (NPDES).
- B. The Discharger owns and operates two municipal wastewater treatment facilities (the Novato and Ignacio plants – collectively the WWTPs) with one combined effluent discharge outfall (E-003) to the intertidal mud flats of San Pablo Bay (the receiving water). The treatment facilities collect sanitary waste from a primarily residential service area serving the Novato area, with a current population of about 60,000. The combined outfall a shallow water discharge, and discharge is prohibited from June 1 through August 31, annually (the non-discharge season). During the non-discharge season, the WWTPs' effluent is reclaimed as described in Section III, below.
- C. The discharger presently discharges an average dry weather flow (ADWF) of 5.4 million gallons per day (MGD), from the WWTPs into San Pablo Bay, a water of the State and the United States.
- D. The Discharger's wastewater conveyance system transports wastewater flows from its service area to the WWTP through a series of gravity sewers and interceptors, pump stations, and force mains that are designed to handle peak wet weather flows. The combined conveyance and collection systems include about 200 miles of major trunk sanitary sewer lines, and 35 wastewater pump stations. The discharger has an ongoing program for preventive maintenance and capital improvements for these sewer lines and pump stations in order to ensure adequate capacity and reliability of the collection system.

II. TREATMENT PROCESS DESCRIPTION

- A. The discharger owns and operates two municipal wastewater treatment facilities: the Ignacio plant, also designated E-001 and the Novato plant, also designated E-002.
- B. The Ignacio Treatment Plant (E-001) utilizes primary clarification, biofiltration, secondary clarification, nitrification, gravity filtration and disinfection with chlorine. The treatment processes vary depending on influent flow:

Design Dry Weather Flow (DDWF) Treatment with all unit processes
(2.02 MGD), and wet weather flows
up to 4.04 MGD

- C. The Novato Treatment Plant (E-002) utilizes primary clarification, activated sludge treatment, secondary clarification, nitrification, gravity filtration, and disinfection with chlorine. The treatment processes vary depending on influent flow. During high flow conditions, the Novato plant blends fully secondary treated wastewater with wastewater that has received primary treatment plus some degree of secondary treatment (see below). This blending is automatically controlled by preset weir elevations and other, similar techniques. By January 1, 2005, the Discharger will have installed flow-

sensing devices in the Novato plant so that blending events can be explicitly identified as they occur. The Discharger is also investigating the use of biochemical oxygen demand (BOD) and total suspended solids (TSS) as surrogate indicators to demonstrate that all effluent limits are met during blending events. The Ignacio plant does not currently blend.

DDWF, 4.53 MGD, and wet
weather flows up to 9 MGD

Treatment with all unit processes

Wet weather flows between 9 MGD
and 16 MGD

Primary treatment plus gravity filtration and
disinfection

Wet weather flows above 16 MGD

Gravity filtration plus disinfection

- D. During the discharge season, the WWTPs discharge the treated, disinfected, and dechlorinated wastewater (the subject discharge) through one combined effluent outfall (E-003) to the intertidal mud flats of San Pablo Bay, a water of the State and the United States, adjacent to the former Hamilton Air Force Base. The treated wastewater is discharged through a multi-port diffuser about 950 feet offshore at Latitude 122 degrees 29 minutes 24 seconds, Longitude 38 degrees 03 minutes 36 seconds. The discharge diffuser is located in the intertidal zone and is submerged at the +1 foot Mean Lower Low Water (MLLW) tidal elevation and above. At tidal elevations lower than the +1 foot MLLW, the outfall is exposed and the distance from the end of the diffuser to the San Pablo Bay water line ranges from 1000 to 3500 feet, depending on tidal conditions. The quality of the discharge is depicted in Tables 1 and 2, below. Tables 1 and 2 depict only the constituents reported as detected in the monitoring data for the period October 1999 – April 2004.

Table 1. Effluent Discharge Description for Individual Plants (Oct 1999 – April 2004)

Parameter	Novato Plant		Ignacio Plant	
	Median	Maximum	Median	Maximum
Biochemical Oxygen Demand (BOD ₅) (mg/L)	16	28	45.5	87
BOD ₅ Monthly Removal (%)	95.4	99.0 ^[1]	91.7	97.6 ^[1]
Total Suspended Solids (TSS) (mg/L)	3.6	120	22	122
TSS Monthly Removal (%)	97.3	99.6 ^[1]	93.4	98.8 ^[1]
Settleable Solids (ml/l-hr)	0.05	0.8	0.05	0.8
Oil and Grease (mg/L)		8.0		8.0
Residual Chlorine (mg/L)	0.0	2.2	0.0	2.2 ^[2]
pH (s.u.)	7.9	8.5 ^[3]	7.1	10.1 ^[3]
Total coliform (mpn/100 ml)	3001	6000 ^[4]	3001	6000 ^[4]

Footnotes for Table 1.

[1] These values represent the maximum of monthly removal percentages for BOD and TSS.

[2] These values are for the combined effluent from both plants; individual plant effluent is not dechlorinated.

[3] This represents the maximum value for pH.

[4] This represents the maximum of the 5-sample moving median reported values.

Table 2. Effluent Discharge Description for Combined Discharge from Both Plants.

Parameter	Median	Maximum (ug/L)
Bis (2-Ethylhexyl) Phthalate	3.1	6.6
2,4,6-Trichlorophenol		2.5*
Bromodichloromethane	5.2	18
Chloroform	12.4	34.1
Dibromochloromethane	3.0	5.3
Toluene	0.6	1.2
MTBE	0.7	1.3
Diethyl Phthalate	9.2	0.8
Bromoform	0.3	0.4

*Single detected value for 2,4,6-Trichlorophenol

- E. The U.S. Environmental Protection Agency (U.S. EPA) and the Board have classified this discharge as a major discharge.
- F. Both plants have primary anaerobic digesters for sludge digestion. The Novato plant has a secondary anaerobic digester, followed by storage ponds for thickening. The Ignacio plant's primary anaerobic digester is followed by storage ponds for thickening. The thickened sludge from both plants is applied on a 14.4 acre dedicated land disposal site at the reclamation area. Sludge storage and disposal are subject to regulation by the U.S. EPA pursuant to Title 40, Code of Federal Regulations, Part 503 (40 CFR Part 503)

III. WATER RECLAMATION

- A. When not discharging to San Pablo Bay, the Discharger reclaims its treated wastewater pursuant to the reclamation requirements contained in Board Order No. 92-065. During the non-discharge season, the Discharger collects and holds the WWTPs' effluent in ponds for reclamation. Reclamation is carried out by sprinkler irrigation of 820 acres of Discharger-controlled pasturelands used for beef cattle grazing and irrigated hay production. The Discharger also uses its reclaimed water to maintain a wildlife management pond as required by Board Order No. 92-065. The Discharger is also subject, together with North Marin Water District, to the Board's Order No. 96-011, *General Water Reuse Requirements for Municipal Wastewater Agencies*.
- B. Although the formal discharge prohibition lasts for 3 months annually, the Discharger typically reclaims wastewater and irrigates five or more months per year. The non-discharge season is limited to three months because the combined outfall discharges to San Pablo Bay's intertidal area. The summer prohibition is limited to three months because the subject discharge, to San Pablo Bay's intertidal area, has a minimal impact immediately before and after the dry weather season because some dilution occurs, though less than 10 to 1, year round during most years.
- C. During the wet weather discharge period (November 1 through April 30), treated wastewater from the storage ponds may be discharged directly through the combined outfall, if it meets the requirements of the Discharger's Reclamation Pond Wet Season Discharge Sediment Control and Monitoring Plan. This Plan was approved by the Executive Officer in October 1999 and is adequate to prevent entrainment of pond sediments into the discharge.

- D. The Discharger monitors the quality of water held in the reclamation ponds prior to discharge during the dry weather discharge period (May 1 – 31 and September 1 – October 31, annually).

IV. RECEIVING WATERS

- A. *Beneficial Uses.* Table 2-7 of the Board's June 21, 1995, *Water Quality Control Plan San Francisco Bay Basin (Region 2)* (the Basin Plan), and observation of known uses of the San Pablo Bay (the receiving water) in the vicinity of the subject discharge, have identified the following beneficial uses for San Pablo Bay:

- Commercial and Sport Fishing
- Estuarine Habitat
- Industrial Service Supply
- Fish Migration
- Navigation
- Preservation of Rare and Endangered Species
- Water Contact Recreation
- Non-contact Recreation
- Shell Fish Harvesting
- Fish Spawning
- Wildlife Habitat.

B. Salinity

1. The Basin Plan states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water shall be considered in determining the applicable Water Quality Objectives (WQOs). Freshwater objectives apply to discharges to waters that both lie outside the zone of tidal influence and have salinities lower than 5 parts per thousand (ppt) at least 75 percent of the time. Saltwater objectives shall apply to discharges to waters with salinities greater than 5 ppt at least 75 percent of the time. For discharges to waters with salinities in between the two categories or tidally influenced freshwaters that support estuarine beneficial uses, the objectives shall be the lower of the salt or freshwater objectives, the latter calculated based on ambient hardness, for each substance.
2. The U.S. EPA's May 18, 2000 *Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California* (the California Toxics Rule – the CTR) states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water shall be considered in determining the applicable water quality criteria (WQCs). The CTR further states that freshwater criteria apply to discharges to waters with salinities equal to or less than one ppt at least 95 percent of the time. Saltwater criteria apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to water with salinities in between these two categories, or to tidally influenced freshwaters that support estuarine beneficial uses, the criteria shall be the lower of the salt or freshwater criteria, the latter calculated based on ambient hardness, for each substance.
3. The receiving waters for the subject discharge are the waters of San Pablo Bay. The Basin Plan specifically identifies San Pablo Bay as estuarine [Basin Plan Table 2-6, pg. 2-21]. Therefore, the applicable WQCs or WQOs are the lower of the marine and freshwater WQOs or WQCs.

C. Hardness

Hardness-dependant WQOs/WQCs were adjusted using a hardness of 138 milligrams per liter (mg/l). This is the only relevant hardness value observed at the RMP San Pablo Bay monitoring station (designated BD 20) during the period from March 4, 1993 through July 17, 2000. Of the 22 total RMP samples collected at that station during that period, 7 samples were analyzed for hardness. Of those 7, 6 had hardness exceeding 400 mg/l. The CTR states [Section F.2.f - Hardness, page 31692], that criteria derivations are most accurate when hardness values are between 25 mg/L and 400 mg/L. Therefore, Board staff eliminated all hardness values above 400 mg/L, which left only the single value of 138 mg/L, observed on January 27, 1997. Since there is only a single applicable value, it was used as the ambient receiving water hardness.

D. Dilution.

1. The subject discharge does not receive an initial dilution of 10:1 at all times because the discharge diffuser is located in the intertidal zone in the San Pablo Bay mud flats, and is submerged when the tides is at the +1 foot Mean Lower Low Water (MLLW) tidal elevation and above. At lower tidal elevations, the outfall is exposed and the distance from the end of the diffuser to the San Pablo Bay water line can range from 1000 to 3500 feet.
2. The Discharger has conducted dilution studies using a dye study and water flow modeling. There are still outstanding technical issues regarding these studies (see Section IV.C.3, below). Therefore, consistent with the requirements of Section 1.3 of the State Water Resources Control Board's March 2, 2000 *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*, this Order does not grant dilution credit for the subject discharge.
3. The outstanding technical issues regarding dilution studies include:
 - dye studies may not account for cumulative effects from other discharges.
 - they may not last long enough to fully assess whether a portion of the discharge has a long residence time and is not flushed out of the system, so that some portion – possibly a small part – of the discharge would make up part of the dilution water.
 - Based on the above, the assumption that a dye study measures only the initial dilution with “clean” dilution water may be incorrect because the actual dilution includes both “clean” dilution water and some amount of original discharge that resides in the system.
 - Neither models nor dye studies may have adequately considered the effects of other nearby discharge sources, or the cumulative effect of discharges from other major dischargers to San Francisco Bay system. Although these effects may be accounted for by factoring local background concentration in calculating the limitations, accurate characterization of local background levels is subject to uncertainties resulting from the interaction of tidal flushing and seasonal fresh water outflows described above.
4. The mixing zone is further limited for discharges of persistent pollutants because discharges to San Francisco Bay waters are not completely mixed discharges as defined by the SIP. Thus, the dilution credit should be determined using site-specific information for incompletely mixed discharges. The SIP Section 1.4.2.2 specifies that the Board “significantly limit a mixing zone and dilution credit as necessary... For example, in determining the extent of ... a mixing zone or dilution credit, the Board shall consider the presence of pollutants in the discharge that are ... persistent.” The SIP defines persistent pollutants to be “substances for which degradation or

decomposition in the environment is nonexistent or very slow.” The pollutants at issue here are persistent pollutants (i.e. mercury, 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide). The dilution studies that estimate actual dilution do not address the effects of these persistent pollutants in the Bay environment, such as their long-term effects on sediment concentrations.

V. GENERAL RATIONALE AND REGULATORY BASES

Water quality objectives (WQOs), water quality criteria (WQC), effluent limitations, and calculations contained in this Order are based on:

- the Federal *Water Pollution Control Act*, Sections 301 through 305, and 307, and amendments thereto, as applicable (the Clean Water Act – the CWA);
- the Board’s June 21, 1995 *Water Quality Control Plan San Francisco Bay Basin (Region 2)* (the Basin Plan), and amendments thereto, as subsequently approved by the State Water Resources Control Board (the State Board), the Office of Administrative Law (OAL) and the U.S. EPA;
- the State Water Resource Control Board’s (the State Board’s) March 2, 2000 *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (the State Implementation Plan - the SIP), as subsequently approved by the OAL and the U.S. EPA;
- the U.S. EPA’s May 18, 2000 *Water Quality Standards; Establishment of Numeric Criteria for Priority Toxic Pollutants for the State of California* (the California Toxics Rule – the CTR);
- the U.S. EPA’s National Toxics Rule as promulgated [Federal Register Volume 57, 22 December 1992, page 60848] and subsequently amended (the NTR);
- the U.S. EPA’s *Quality Criteria for Water* [EPA 440/5-86-001, 1986], and subsequent amendments, (the U.S. EPA Gold Book);
- applicable Federal Regulations [40 CFR Parts 122 and 131];
- 40 CFR Part 131.36(b) and amended [Federal Register Volume 60, Number 86, 4 May 1995, pages 22229-22237];
- the U.S. EPA’s December 10, 1998 *National Recommended Water Quality Criteria* compilation [Federal Register Vol. 63, No. 237, pp. 68354-68364];
- the U.S. EPA’s December 27, 2002 *Revision of National Recommended Water Quality Criteria* compilation [Federal Register Vol. 67, No. 249, pp. 79091-79095]; and
- guidance provided with State Board actions remanding permits to the Board for further consideration.

VI. SPECIFIC RATIONALE

Specific factors affecting development of limitations and requirements in the proposed Order are discussed as follows:

A. Recent Plant Performance

Section 402(o) of CWA and 40 CFR § 122.44(l) require a re-issued NPDES permit contain water quality-based effluent limitations (**WQBELs**) that are at least as stringent as those in the previous permit. The SIP specifies that interim performance-based effluent limitations, if required, must be based on the more stringent of either current treatment facility performance or previous permit limitations (unless anti-backsliding requirements are met). Board staff exercised BPJ, as defined above, to establish recent plant performance as it applies to the WWTPs. Board staff considered effluent monitoring data collected during the discharge season from October 1999 through April 2004 as representative of recent plant performance.

B. Impaired Water Bodies in 303(d) List

On June 6, 2003, the U.S. EPA approved a revised list of impaired water bodies prepared by the State pursuant to the provision of Section 303(d) of the federal Clean Water Act (the 303(d) list) requiring identification of specific water bodies where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. The 303(d) list includes San Pablo Bay as impaired by chlordanes, DDT, diazinon, dieldrin, dioxin compounds, exotic species, furan compounds, mercury, nickel, PCBs, dioxin-like PCBs, and selenium.

The SIP requires that final effluent limitations for all 303(d)-listed pollutants will be based on total maximum daily loads (**TMDLs**) and their associated wasteload allocations (**WLA**). The SIP and federal regulations also require that final concentration limitations be included for all pollutants with reasonable potential. The SIP requires that, where the Discharger has demonstrated infeasibility to meet the final limitations, interim concentration limitations will be established in the permit together with a compliance schedule to remain in effect until final effluent limitations are adopted. The SIP also requires the inclusion of appropriate provisions for waste minimization and source control as a condition for granting a compliance schedule.

C. Basis for Prohibitions

1. Prohibition A.1 (no discharges other than as described in the permit): This prohibition is based on the California Water Code that requires filing of a report of waste discharge before a permit to discharge can be granted.
2. Prohibition A.2 (no bypass or overflow): This prohibition is based on the previous Order and 40 CFR Part 122.41(m)(4).
3. Prohibition A.3 (flow limit): This prohibition is based on the reliable treatment capacity of the plant. Exceedence of the treatment plant's average dry weather flow design capacity may result in lowering the reliability of compliance with water quality requirements, unless the Discharger demonstrates otherwise through an antidegradation study. This prohibition is based on 40 CFR 122.41(l).
4. Prohibition A.4 (dry weather discharge): This prohibition is unchanged from the previous Order. The exception to the shallow water discharge prohibition is based on the Discharger's implementation of an approved reclamation program and, no discharge is allowed between June 1 and August 31, annually, when all treated wastewater is reclaimed.
5. Prohibition A.5 (no discharge of untreated or partially treated sewage, no discharge of disinfection products, such as chlorine): This prohibition is based on the Clean Water Act, which prohibits discharges of wastewater that does not meet secondary treatment standards as specified in 40 CFR 133. Additionally, the Basin Plan prohibits discharge of raw sewage or any waste

failing to meet waste discharge requirements to any waters of the Basin Plan. The Basin Plan contains a toxicity objective stating “All waters shall be maintained free of toxic substances in concentrations that are lethal to or produce other detrimental responses to aquatic organisms.” Chlorine is lethal to aquatic life.

D. Basis for Effluent Limitations

1. Effluent Limitations B.1: These technology-based and other limitations are representative of, and are intended to ensure, adequate and reliable secondary level wastewater treatment. During wet weather (November 1 - April 30 annually) the discharge is subject to the requirements for secondary plants that are at least as stringent as the Basin Plan requirements [Basin Plan Chapter 4, pg 4-8, and Table 4-2, at pg 4-69] and described by the U.S. EPA at 40 CFR 133.102. This Order requires that the discharge meet more stringent technology-based limits during dry weather (May 1 - 31 and September 1 - October 31 annually) to protect the beneficial uses of the receiving water from threats or impacts caused by the discharge. These more stringent dry weather technology based limits are needed because during the drier, warmer months, the receiving water is subject to greater oxygen demand from increased phytoplankton activity, there are reduced dissolved oxygen levels due to elevated temperature, and there is reduced flushing of San Pablo Bay from freshwater inflows (from local creeks or the Sacramento-San Joaquin Delta). Compliance at the Novato plant has been demonstrated by existing plant performance. The Ignacio plant has been unable to attain compliance with the more stringent technology-based dry weather limits, and is under a compliance schedule to attain them, and IPBLs until they can be achieved.
2. Effluent Limitation B.2 (pH): This effluent limitation is unchanged from the previous permit. The limitation is based on the Basin Plan [Basin Plan Chapter 4, Table 4-2], which is derived in turn from federal requirements [40 CFR 133.102]. Compliance has been demonstrated by existing plant performance.
3. Effluent Limitation B.3 (bacteriological). The previous Order included total coliform limitations. The U.S. EPA’s May, 2002 draft implementation guidance for bacteriological water quality criteria recommended either enterococcus or *E. coli*, or both together, as superior to total or fecal coliform as bacteriological indicators for human health pathogenic risk. This recommendation was based on the fact that there are multiple sources of coliform bacteria, including humans, and research results showing that many of these forms are unrelated to human pathogens or risk potential. A growing number of studies (including the Santa Monica Bay study [R. Haile, et al. *The health effects of swimming in ocean water contaminated by storm drain runoff*. Epidemiology 10(4): 355-363 (1999).]) have indicated that enterococcus and/or *E. coli* counts correlate more significantly than coliform counts with human health problems than coliform counts, and serve as a more accurate indicator of human health risk potential from water contact. Therefore, this Permit contains alternate enterococcus bacteriological limits. Enterococcus compliance may be demonstrated using any analytical method approved by the Executive Officer.
4. Effluent Limitation B.4 (chlorine residual): This effluent limit is unchanged from the previous NPDES permit. The limitation is based on the Basin Plan [Table 4-2, Pg. 4-69]. Compliance has generally been demonstrated by existing plant performance
5. Effluent Limitation B.5 (BOD and TSS monthly average 85 percent removal): These are standard secondary treatment requirements and permit effluent limitations based on Basin Plan requirements [Table 4-2, pg. 4-69], derived in turn from federal requirements [40 CFR 133.102; definition in 133.101]. These limitations are different from the previous NPDES permit in that

they are based on concentration as the unit of measure, rather than weight. This change is implemented to make this requirement consistent with 40 CFR 133.101 and 133.102. Compliance has been demonstrated by existing plant performance.

6. Effluent Limitation B.6 (ammonia): The monthly effluent limitation is unchanged from the existing NPDES permit, and compliance has been demonstrated by existing plant performance. The annual average ammonia effluent limitation is discontinued because the Board feels that the monthly effluent limitation is adequately protective.
7. Effluent Limitation B.7 (Whole Effluent Acute Toxicity): The Basin Plan specifies a narrative objective for toxicity, requiring that all waters shall be maintained free of toxic substances in concentrations that are lethal to, or produce other detrimental response in, aquatic organisms. Detrimental responses include, but are not limited to: decreased growth rate, decreased reproductive success of resident or indicator species, and/or significant alternations in population, community ecology, or receiving water biota. These effluent toxicity limitations are necessary to ensure that this objective is protected. The whole effluent acute toxicity limitations for an eleven-sample median and an eleven-sample 90th percentile value are consistent with the previous Order and are based on the Basin Plan [Table 4-4, pg. 4–70]. This Order requires acute toxicity testing to be carried out consistent with the requirements of the U.S. EPA’s “Methods for Measuring The Acute Toxicity of Effluents and Receiving Water To Freshwater and Marine Organisms.” The most current requirements are the 5th Edition (EPA-821-R-02-012), and the Discharger shall implement succeeding editions as soon as practicable after their adoption by U.S. EPA.
8. Effluent Limitation B.8 (Whole Effluent Chronic Toxicity): The chronic toxicity objective/limitation is based on the Basin Plan’s narrative toxicity objective on page 3-4.
9. Effluent Limitation B.9 (Toxic Substances):
 - a. Reasonable Potential Analysis (RPA)

The CFR [40 CFR 122.44(d)(1)(i)] requires NPDES permits to include WQBELs for all pollutants “which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard” (have reasonable potential). Thus, assessing whether a pollutant has reasonable potential is the fundamental step in determining whether or not a WQBEL is required. The following sections describe the process and results of an RPA of the WWTPs’ effluent for the pollutants identified in the Basin Plan and the CTR.

- i) *WQOs and WQCs*: The RPA uses Basin Plan WQOs, including narrative toxicity objectives in the Basin Plan, and applicable WQCs in the CTR and NTR. The Basin Plan objectives and CTR/NTR criteria are shown in Attachment A of this Fact Sheet. Pursuant to SIP Section 1.3, the RPA did not include dilution for any pollutants, as discussed in Section IV.C, above.
 - ii) *Methodology* : The RPA uses the methods and procedures prescribed in SIP Section 1.3. Board staff analyzed the effluent and background data and the nature of facility operations to determine if the discharge has reasonable potential to cause or contribute to exceedences of applicable WQOs or WQCs. Attachment C of this Fact Sheet shows the step-wise process described in Section 1.3 of the SIP.
 - b. *Effluent and background data*: The RPA is based on effluent data collected by the Discharger from October 1999 through April 2004 for metals and certain organic priority pollutants (see

Attachment B of this Fact Sheet), and on receiving water ambient background data at RMP Station BD20 (the San Pablo Bay RMP station) from 1990 through 2000 as the most representative currently available background data. However, a data gap remains as to the ambient background conditions for the discharge into the intertidal mudflats of San Pablo Bay. San Pablo Bay station RMP data were used for this permit reissuance because this is the best available information representing ambient background condition for this discharge. The Discharger's outfall is located in the mudflats along the western edge of San Pablo Bay; and the San Pablo Bay RMP station is located in the center of San Pablo Bay. Therefore, there is significant distance from the discharge outfall to the RMP Station. For future permit reissuance, the Board may require better characterization of ambient background conditions near the outfall if such data are needed.

- c. *Site Specific Translators* This Order employs site-specific translators for the nickel and copper WQCs used in the RPA. The translators are derived from data presented in the Discharger's July 23, 2004, *Novato Sanitary District Copper and Nickel Translator Calculation* (the translator study), incorporated here by reference. The translator study compiled dissolved and total metal data from four monitoring stations in San Pablo Bay. The four monitoring stations used provide adequate geographic and temporal coverage for the portions of San Pablo Bay adjacent to the discharge. The study calculated translators using methods provided in U.S. EPA guidance, including direct calculation ($\text{translator} = (\text{dissolved fraction})/(\text{total metal})$), and performing a regression analysis of any correlation between translator values and Total Suspended Solids (TSS) in the receiving water. The regression analysis demonstrated an acceptable correlation between TSS and translator values for copper, but not for nickel. Therefore, for consistency, the directly computed translators were used for both copper and nickel. The RPA used site-specific translators for copper (0.73 acute, 0.39 chronic) and nickel (0.65 acute, 0.27 chronic).
- d. *RPA Triggers*: Three triggers apply in determining reasonable potential:
- 1) The first trigger is activated if the MEC is greater than the lowest applicable WQO ($\text{MEC} \geq \text{WQO}$), which has been adjusted for pH and translator data, if appropriate. If the MEC is greater than the adjusted WQO, then that pollutant has reasonable potential, and a WQBEL is required.
 - 2) The second trigger is activated if the observed maximum ambient background concentration (B) is greater than the adjusted WQO ($B > \text{WQO}$), and either:
 - a) the MEC is less than the adjusted WQO ($\text{MEC} < \text{WQO}$), or
 - b) the pollutant was not detected in any of the effluent samples and all of the detection levels are greater than or equal to the adjusted WQO.If B is greater than the adjusted WQO, then a WQBEL is required.
 - 3) The third trigger is activated under certain circumstances if a review of other information determines that a WQBEL is required to protect beneficial uses, even if both MEC and B are less than the WQO.
- e. *RPA determination*: The RPA indicated that there is reasonable potential for: copper, lead, mercury, nickel, cyanide, TCDD TEQ, 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide, as depicted in Table 2, below. A complete RPA results table is included in Attachment C of this Fact Sheet.

f. Summary of Reasonable Potential Results

CTR #	Constituent name	Governing Criterion, µg/l	RPA Trigger	Reason
6	Copper	6.58	1	MEC => C [16.340 ug/l vs 6.575 ug/l]
7	Lead	4.79	2	B > C [6.460 ug/l vs 4.794ug/l]
8	Mercury (303d listed)	0.03	1	MEC => C [0.046 ug/l vs 0.025 ug/l]
9	Nickel	26.30	2	B > C [30.000 ug/l vs 26.296ug/l]
14	Cyanide	1.00	1	MEC => C [7.317 ug/l vs 1.000 ug/l]
16	2,3,7,8 TCDD (303d listed)	0.00	3	RP by Trigger III and Staff BPJ
109	4,4'-DDE (linked to DDT)	0.00	2	B > C [0.001159 ug/l vs 0.000590ug/l]
110	4,4'-DDD	0.00	2	B > C [0.001159 ug/l vs 0.000840ug/l]
111	dieldrin (303d listed)	0.00	2	B > C [0.000237 ug/l vs 0.000140ug/l]
118	heptachlor epoxide	0.00	2	B > C [0.000121 ug/l vs 0.000110ug/l]

g. *Constituents with limited data:* Reasonable potential could not be determined for some organic priority pollutants due to the lack of data. The Board's August 6, 2001 Letter to all permittees required the Discharger to initiate or continue to monitor for those pollutants in this category, using analytical methods that provide the best detection limits reasonably feasible. Table 6 of the SMP, requires two additional monitoring events for these pollutants before the Discharger applies for reissuance of this NPDES permit, and Board staff will reassess those pollutants RP at that time.

h. *Permit reopener:* The permit includes a reopener provision to allow numeric effluent limitations to be added for any constituent that in the future exhibits reasonable potential to cause or contribute to exceedence of a WQO or WQCs. This determination, based on monitoring results, will be made by the Board.

i. Mass Emission Limitations for Mercury

The Order contains a mass emission limitation for mercury because the Board has determined that there is no additional assimilative capacity for mercury in the San Francisco Bay system. This determination is consistent with SIP Section 2.1.1 requirements that the Board consider whether additional assimilative capacity exists for 303(d)-listed bioaccumulative pollutants. This determination also considered the fact that a fish consumption advisory currently exists to protect human health from elevated mercury concentrations in fish taken from San Francisco Bay. The mass trigger is calculated using the ultra-clean data collected from May 1999 through November 2003 as it reflects the WWTPs' performance. The mass trigger is a reflection of (1) better mercury effluent data (sampling and analytical techniques have improved); and (2) better flow data (43 months of actual effluent discharged to receiving water).

j. Final Water Quality-Based Effluent Limitations

Final WQBELs were developed for the toxic and priority pollutants that were determined to have reasonable potential. In this document, "final WQBELs" means final effluent limitations that were calculated based on appropriate WQOs or WQCs using the appropriate procedures specified in SIP Section 1.4 (See Attachment D of this Fact Sheet). For the purpose of the Proposed Order, final WQBELs refer to all non-interim effluent limitations. The governing WQOs or WQCs used for each pollutant with reasonable potential are depicted in Table 3, above. The determination of governing WQOs or WQCs is detailed in Attachment 1 of this Fact Sheet.

k. Comparison to Previous Permit Limitations

The effluent limitations contained in the existing NPDES permit for silver and zinc have been discontinued because the current RPA indicated they do not have reasonable potential, and therefore, no final WQBELs are required. Their discontinuation is exempt from antibacksliding and antidegradation, to the extent they would be applicable, because the current RPA constitutes new information that was not available when the existing NPDES permit was adopted, and the receiving water is in attainment for silver and zinc. The interim performance based effluent limit (IPBL) for copper contained in this NPDES permit is more stringent than the interim limit contained in the existing NPDES permit. For mercury, the concentration-based IPBL and mass emission limits are based on the previous NPDES permit, as amended. The mercury mass trigger was recalculated based on recent plant performance data, as depicted in Attachment 5. The IPBL for cyanide is higher than that contained in the existing NPDES permit because new information (i.e., results of collaborative cyanide studies) has become available since the existing NPDES permit was adopted. The existing NPDES permit did not include effluent limitations for 4,4'-DDE, 4,4'-DDD, dieldrin or heptachlor epoxide, and they are included in this Order because the RPA indicated they have reasonable potential due to ambient background levels in the receiving water.

l. Feasibility of Complying With Final Limitations for Lead and Nickel

Board staff conducted a statistical analysis of lead and nickel data for wet weather discharge of combined effluent to evaluate the feasibility of attaining immediate compliance with the final WQBELs. The statistical analysis computed the median, 95th percentile, and 99.87th percentile values of the data, as depicted in Attachments 6 and 7. The statistical analysis shows that the median, 95th percentile, and 99.87th percentile values are all below the MDELs for both lead and nickel. This indicates that immediate compliance with those final WQBELs is feasible.

m. Interim Limitations

Pursuant to the SIP, this Order establishes numeric IPBLs for copper, cyanide, mercury, 4,4'-DDE, dieldrin, and heptachlor epoxide. Both the SIP and the Basin Plan require dischargers to demonstrate the infeasibility of achieving immediate compliance with new limits to qualify for a compliance schedule. On July 27, 2004, the Discharger submitted its Feasibility Study (the feasibility study), asserting infeasibility to immediately comply with the final WQBELs for copper, mercury, cyanide, 4,4'-DDE, 4,4'-DDD, dieldrin and heptachlor epoxide. Board staff have analyzed the Discharger's data for copper, mercury, and cyanide and confirmed the assertion of infeasibility for those pollutants. For 4,4'-DDE, 4,4'-DDD, dieldrin and heptachlor epoxide, current analytical technologies do not permit detection of those compounds, if present, at levels low enough to determine compliance with the final WQBELs, and the assertion of infeasibility is confirmed for those pollutants. Interim effluent limitations were derived for these constituents.

Justification for including these IPBLs is based partly on the Discharger's source control and pollution minimization efforts in the past and continuation of those efforts in the present and future. The interim effluent concentration limitations for copper and cyanide are based on recent plant performance. The interim monitoring requirement for dioxin TEQ is based on the previous permit daily average effluent limitations. The concentration-based mercury IPBL is based on the 2001 Board staff report *Statistical Analysis of Pooled Data from Regionwide UltraClean Mercury Sampling for Municipal Dischargers*. The mass-based IPBL is continued from the existing NPDES permit, and the mass-based mercury triggers are recomputed from

recent plant performance, and are consistent with anticipated WLAs for the mercury TMDL. The interim limitations for 4,4'-DDE, 4,4'-DDD, dieldrin, and heptachlor epoxide are based on their respective MLs as set out in the SIP [pages 4-1 through 4-5]. The interim limitations are also discussed in more detail below.

n. Feasibility Evaluation

- i) Board staff reviewed the feasibility study's assertions that it is infeasible to immediately comply with the WQBELs calculated according to SIP Section 1.4 for copper, mercury, cyanide, 4,4'-DDE, dieldrin, and heptachlor epoxide.

Board staff statistically analyzed recent WWTP copper and mercury performance data to validate the assertion of infeasibility for them, as depicted in Table 4, below. Based on that statistical analysis, the Board concurs with the Infeasibility study's assertion of infeasibility regarding copper and mercury. Therefore, pursuant to SIP requirements, this Order continues the existing compliance schedules for copper and mercury and establishes interim numeric limitations and interim requirements to control these metals, based on the specific bases described below.

Table 3. Results of feasibility analysis for copper and mercury.

Constituent	AMEL, µg/L	95 th Percentile, µg/L	MDEL, µg/L	99 th Percentile, µg/L	Immediate Compliance Feasible? (Y/N)
Copper	4.4	18.7	6.4	15.6	No
Mercury*	0.021	0.036	0.039	0.048	No

This Order establishes an interim performance-based mercury mass limit in addition to the interim mercury concentration limits, to maintain the discharge's current mass loadings of mercury, a 303(d)-listed bioaccumulative pollutant, into San Pablo Bay. This interim performance-based mass limitation is based on the existing NPDES permit.

Specific bases for these interim limits are described in the findings for each pollutant and in Section m., below. The Board may take appropriate enforcement actions if interim limits and requirements are not met.

This Order requires continued monitoring for cyanide and selected semivolatiles as a condition of establishing the interim numeric interim limits and compliance schedules for them.

o. Further Discussion and Rationales of Interim Effluent Limitations

- i) Copper: This Order contains a copper IPBL because the Discharger has demonstrated and the Board verified that it is infeasible for the WWTPs to meet the final effluent limitations calculated according to the SIP, 6.4 µg/L maximum daily effluent limit (MDEL) and 4.4 µg/L average monthly effluent limit (AMEL). The SIP requires the interim numeric effluent limitation for the pollutant be based on either current treatment facility performance, or on the previous Order's limitation, whichever is more stringent. Board staff's statistical analysis indicates the 99.87th percentile value of the WWTPs' recent copper effluent data is 19 µg/L,

which is lower than the 22 µg/L IPBL developed for the current NPDES Permit. Therefore, this Order establishes the copper IPBL as 19 g/L. To comply with the SIP, this Order establishes the IPBL at 19 µg/L as a daily maximum.

- ii) Mercury: This Order contains a mercury IPBL because the Discharger has demonstrated and the Board verified that it is infeasible for the WWTPs to meet the final effluent limitations calculated according to the SIP, 0.039 µg/L MDEL and 0.021 µg/L AMEL. The SIP requires the interim numeric effluent limitation for the pollutant be based on either current treatment facility performance, or on the previous Order's limitation, whichever is more stringent. The SIP requires the interim numeric effluent limitation for the pollutant be based on either current treatment facility performance, or on the previous Order's limitation, whichever is more stringent. The performance-based effluent limitations, 0.023 µg/L for advanced secondary treatment plants and 0.087 µg/L for secondary treatment plants, were calculated statistically using ultra-clean mercury concentration data (*Staff Report: Statistical Analysis of Pooled Data from Region-wide Ultra-clean Sampling, 2000*). The Discharger operates secondary treatment plants, so the appropriate concentration-based mercury IPBL is 0.087 µg/L. This is the same concentration-based IPBL contained in the existing NPDES permit.

This Order continues the previous NPDES permit's interim mass-based mercury effluent limitation of 0.655 kilograms per year (kg/yr), and establishes a newly-calculated interim mass-based mercury trigger value of 0.020 kilograms per month (kg/mo). The trigger value is based on a statistical analysis of recent plant performance. Specifically, the running 12-month mass loading averages for the WWTPs were calculated for the period October 1999 through April 2004, and the 99.87th percentile value of the running 12-month average mass loadings was calculated, as shown in Attachment 5 of this Fact Sheet. This value is the interim mass-based mercury trigger. The Board has determined that this mass-based trigger approach is appropriate for the following reasons:

- a. recent monitoring data show very low levels of mercury in the discharge, well below the applicable WQC,
- b. the interim concentration-based limitation will ensure that mercury levels remain low in the discharge,
- c. the Discharger will continue to identify and, to the extent feasible, address mercury sources under its pollution prevention program,
- d. the interim mass limitation based on the design flow will preclude any significant increases in mass loadings from the WWTP.

Overall, the Discharger already has minimized mercury influent loadings to the treatment plant and provided for a high level of mercury removal in the treatment process. The Board anticipates that it is unlikely that the TMDL will require additional reductions in mercury loadings beyond current treatment levels.

- iv) Cyanide: An interim effluent limitation is given for cyanide since the Discharger has demonstrated and the Board verified that it is infeasible for the WWTPs to meet the final effluent limitations calculated according to the SIP (AMEL and MDEL of 1.0) or the current SIP minimum level of 5.0 µg/l. The final WQBEL may be recalculated based on a cyanide SSO. Since the Discharger cannot comply with the cyanide WQBELs or ML, this Order establishes an IPBL for cyanide, based on the 99.87th percentile value of recent performance

data. Statistical analysis of recent cyanide effluent data indicates a 99.87th percentile value of 9.2 µg/L. This Order establishes the 9.2 µg/L cyanide IPBL, even though it is higher than the previous NPDES Permit's 5µg/L limit, because antibacksliding does not apply for the following reasons:

- 1) The proposed final WQBEL set forth in the findings is more stringent than the WQBEL specified in the previous permit,
 - 2) As set forth in the State Board Order WQ 2001-06, antibacksliding does not apply to the interim limitations in a compliance schedule and the proposed interim *performance-based* limit is not "comparable" to the prior *water quality*-based limit of the previous permit, and
 - 3) Even if antibacksliding and antidegradation policies apply to interim limitations under CWA 402(o)(2)(c), a less stringent limitation is necessary because of factors over which the Discharger has no control – specifically, the fact that cyanide appears to be byproduct of the required effluent disinfection.
- iii) 4,4'-DDE, 4,4'-DDD, dieldrin and Heptachlor: Interim effluent limitations are given for these pollutants because it is infeasible for the Discharger to demonstrate, or the Board to determine, immediate compliance with the final WQBELs (4,4'-DDE: MDEL -0.00059 µg/L, AMEL - 0.00029 µg/L; 4,4'- DDD: MDEL - 0.00169, AMEL - 0.00084; dieldrin: MDEL – 0.00029 µg/L, AMEL – 0.00014 µg/L; and heptachlor Epoxide: MDEL - 0.00022 µg/L and AMEL – 0.00011 µg/L.) newly calculated in accordance with the SIP. This is because all effluent samples are non-detect and the detection limits are far above the WQBELs. Since the Discharger cannot immediately demonstrate compliance with the final limits, the interim limitations are set at current performance, which is the levels at which the Discharger can demonstrate compliance, the current method limits (MLs) as delineated in the SIP: 4,4'-DDE- 0.05 µg/L, 4,4'-DDD – 0.0g µg/L, dieldrin - 0.01 µg/L and heptachlor epoxide - 0.01 µg/L. These IPBLs are taken as daily maximums. Because the previous NPDES permit did not contain limits for 4,4'-DDE, 4,4'-DDD, dieldrin and heptachlor, antibacksliding does not apply to these interim limits.
- v) Dioxins and Furans: The Discharger has demonstrated, and the Board verified, that it is infeasible for the Discharger to achieve immediate compliance with the final WQBELs for dioxin and furan compounds (AMEL of 0.014 pg/L and MDEL of 0.028 pg/L) newly calculated in accordance with the SIP. However, this Order does not contain interim limits for dioxins and furans because the current method detection limits are far above the final effluent limits. Although the SIP does not contain minimum levels for dioxins and furan compounds, Section 2.4.3 (1.) of the SIP requires the Board to establish an ML in the discharger's permit if the SIP's Appendix 4 does not contain an ML for the pollutant under. Therefore, this Order requires the Discharger to investigate the feasibility and reliability of increasing sample volumes to lower the detection limits for dioxin and furan compounds.
- p. Attainability of Interim Limitations
- i) Copper: During the period October 1999 through April 2004, the WWTPs' effluent MEC for copper was 16.34 µg/L. Since all effluent copper values were below the 19 µg/L IPBL, it is feasible for the WWTPs to comply with the IPBL.
 - ii) Mercury: During the period May 1999 through April 2004, the Discharger's combined effluent mercury concentrations ranged from 0.008 µg/L to 0.101 µg/L and averaged 0.021

µg/L. Although the mercury MEC exceeds the IPBL, Board staff's evaluation of the subject discharge data indicate that the concentration-based IPBL is attainable. During that same time period, the 12-month moving average mercury mass emissions ranged from 0.16 kg/yr (0.013 kg/mo) to 0.23 kg/yr (0.019 kg/mo). Based on these results, the annual average mass loading limit and trigger values should be attainable by the WWTPs.

- iv) Cyanide - During the period November 1998 through December 2002, the MEC for cyanide was 7.3 µg/L. Board staff's evaluation of the subject discharge data indicates that it is feasible for the WWTP to comply with the 9.2 µg/L IPBL.
- v) 4,4'-DDE, 4,4'-DDD, dieldrin and heptachlor epoxide - None of these compounds were detected in samples collected from the WWTPs' effluent in the period October 1999 – April 2004. The lowest detection limits for those samples were all below the relevant MLs, indicating the Discharger can comply with the IPBLs.

F. Basis for Receiving Water Limitations

1. Receiving water limitations C.1, C.2, and C.3 (conditions to be avoided): These limitations are based on the narrative/numerical objectives contained in Chapter 3 of the Basin Plan, pages 3-2 – 3-5.
2. Receiving water limitation C.4 (compliance with State Law): This requirement is in the previous permit, requires compliance with Federal and State law, and is self-explanatory.
3. Receiving water limitation C.5 (treatment plant operation): This requirement is in the previous permit, requires compliance with Federal and State law, and is self-explanatory.

G. Basis for Sludge Management Practices

These requirements are based on Table 4.1 of the Basin Plan and 40 CFR 503.

H. Basis for Self-Monitoring Requirements

The SMP includes monitoring at individual plants' discharge points for conventional pollutants and at the combined outfall for non-conventional and toxic pollutants, and acute and chronic toxicity. The monitoring frequency for TSS is maintained at three (3) times per week since the Board believes that daily performance monitoring is appropriate for major POTWs. The Basin Plan Amendment adopted by the Board on January 21, 2004, (the Amendment) removed the settleable matter effluent limitations for secondary sewage treatment plants because it was not an appropriate indicator of sewage treatment plants' performance. Although the Amendment does not become effective until it is approved by the Office of Administrative Law, this Order does not impose settleable matter limits, based on the same rationale as the Amendment's removal of them. Should this change not be approved by the Office of Administrative Law, the Board will amend this Order to reinstate the settleable matter limits, as appropriate. This Order requires monthly monitoring for copper, mercury and cyanide to demonstrate compliance with the IPBLs. This Order requires monthly monitoring for lead and nickel to demonstrate compliance with final effluent limitations. Additionally, this Order requires twice yearly monitoring for 4,4'-DDE, 4,4'-DDD, dieldrin, heptachlor epoxide and dioxins and furan compounds to determine compliance with effluent limitations since these pollutants have little data with either limited or no detected values in the effluent during the period October 1999 through April 2004. Moreover, the Discharger shall collect twice yearly monitoring for all the 2,3,7,8-TCDD congeners, as further explained under the heading **Basis for the Lower Detection Limit Study for Dioxin TEQ**.

I. Basis for Provisions

- i) Provision E.1. (Permit Compliance and Rescission of Previous Permit): Time of compliance is based on 40 CFR 122. The basis of this Order superceding and rescinding the previous permit Order is 40 CFR 122.46.
- ii) Provision E.2 (Regional Copper Study and Schedule): This provision, based on BPJ, requires the Discharger to continue its participation in the regional discharger-funded effort to develop site-specific saltwater aquatic life-based WQOs for copper in San Francisco Bay north of the Dumbarton Bridge.
- iii) Provision E.3 (Cyanide Compliance Schedule and Cyanide SSO Study): This provision, based on BPJ, requires the Discharger to characterize background ambient cyanide concentrations and to participate in an on-going group effort to develop an SSO for cyanide.
- iv) Provision E.4 (Pollution Prevention and Pretreatment Program): This provision is based on the Basin Plan, pages 4-25 – 4-28, and the SIP, Section 2.1.
- v) Provision E.5 (Pretreatment Program): This provision is based on 40 CFR Part 403.
- vi) Provision E.6 (Whole Effluent Acute Toxicity): This provision establishes conditions by which compliance with permit effluent limitations for acute toxicity will be demonstrated. Under this Order, the Discharger is required to use the most up-to-date protocols in 40 CFR Part 136, currently in “Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms,” 5th Edition
- vi) Provision E.7 (Whole Effluent Chronic Toxicity): This provision establishes conditions and protocols by which compliance with the Basin Plan narrative WQO for toxicity will be demonstrated. Conditions include required monitoring and evaluation of the effluent for chronic toxicity and numerical values for chronic toxicity evaluation to be used as 'triggers' for initiating accelerated monitoring and toxicity reduction evaluation(s). This provision also requires the Discharger to conduct a screening phase monitoring requirement and implement toxicity identification and reduction evaluations when there is consistent chronic toxicity in the discharge. New testing species and/or test methodology may be available before the next permit renewal. Characteristics, and thus toxicity, of the process wastewater may also have been changed during the life of the permit. This screening phase monitoring is important to help determine which test species is most sensitive to the toxicity of the effluent for future compliance monitoring. The proposed conditions in the draft permit for chronic toxicity are based on the Basin Plan narrative WQO for toxicity, Basin Plan effluent limitations for chronic toxicity (Basin Plan, Chapter 4), the U.S. EPA and SWRCB Task Force guidance, applicable federal regulations [40 CFR 122.44(d)(1)(v)], and BPJ.
- vii) Provision E.8 (Whole Effluent Chronic Toxicity): This provision establishes conditions and protocols by which compliance with the Basin Plan narrative WQO for toxicity will be demonstrated. Conditions include required monitoring and evaluation of the effluent for chronic toxicity and numerical values for chronic toxicity evaluation to be used as 'triggers' for initiating accelerated monitoring and toxicity reduction evaluation(s). This provision also requires the Discharger to conduct a screening phase monitoring requirement and implement toxicity identification and reduction evaluations when there is consistent chronic toxicity in the discharge. New testing species and/or test methodology may be available before the next permit renewal. Characteristics, and thus toxicity, of the process wastewater may also have been

changed during the life of the permit. This screening phase monitoring is important to help determine which test species is most sensitive to the toxicity of the effluent for future compliance monitoring. The proposed conditions in the draft permit for chronic toxicity are based on the Basin Plan narrative WQO for toxicity, Basin Plan effluent limitations for chronic toxicity (Basin Plan, Chapter 4), the U.S. EPA and SWRCB Task Force guidance, applicable federal regulations [40 CFR 122.44(d)(1)(v)], and BPJ.

- viii) Provision E.8 (Advanced Mercury Source Reduction Project): This provision, requires the Discharger to implement an Advanced Mercury Source Control Program throughout its service area that will within the first three years of the program increase the collection of fluorescent light tubes 5%. This provision is based on Section 2.1.1 of the SIP.
- ix) Provision E.9. (Bacteriological Studies): Consistent with the Basin Plan and U.S. EPA guidance, this provision requires the Discharger to conduct a confirmation study to demonstrate that the enterococcus limitations included in the Order are protective of all of the designated uses of the receiving waters, and must verify the “light contact” recreational use scenario upon which the limitations are based.
- x) Provision E.10 (Reclamation Pond Operation): The provision implements the sampling requirements in the Discharger’s Reclamation Pond Wet Season Discharge Sediment Control Monitoring Plan.
- xi) Provision E.11. (Compliance Schedule for Conventional Effluent Limitations at Ignacio Plant): The Ignacio Plant is currently unable to attain the technology-based effluent limitations for BOD and TSS for discharge during the dry-weather season (May, September, and October annually). The Discharger has committed to upgrade or replace the Ignacio Plant so that the more stringent dry weather technology-based effluent limitations will be attained. This Order continues the previous NPDES permit’s compliance schedule, until March 31, 2008.
- xii) Provision E.12. (303(d)-listed Pollutants Site-Specific Objective and TMDL Status Review): Consistent with the SIP, the Discharger shall participate in the development of TMDLs and SSOs for mercury, selenium, 4,4’-DDE, dieldrin, dioxin, and PCBs. By January 31 of each year, the Discharger shall submit an update to the Board to document progress made on source control and pollutant minimization measures and development of TMDL or SSO. Regional Board staff shall review the status of TMDL development. This Order may be reopened in the future to reflect any changes required by TMDL development.
- xiii) Provision E.13. (Optional mass Offset): This option is provided to encourage the Discharger to further implement aggressive reduction of mass loads to San Pablo Bay.
- xiv) Provision E.14 (Sanitary Sewer Management Plan): This provision requires the Discharger to actively participate in the BACWA and Water Board collaborative effort to address SSOs. The effort is consistent with Board Resolution No: R2-2003-0095.
- xv) Provision E.15 (Blending Monitoring Study). This provision is based on BPJ. It requires the Discharger to evaluate TSS as an indicator of compliance with effluent limitations during blending events. Furthermore, the provision requires the Discharger to recommend an appropriate TSS trigger value. The TSS trigger value will be used to require additional monitoring (Table 2 and Table 3 of the SMP) during blending events.

- xvi) Provision E.16 (Implementation and Enforcement of Prohibition A.5): The provision is based on 40 CFR 122.41(n) regarding treatment plant upset and affirmative defense.
- xvii) Provision E.17. (Wastewater Facilities, Review and Evaluation, Status Reports): This provision is based on the previous Order and the Basin Plan.
- xviii) Provision E.18. (Operations and Maintenance Manual and Reliability Report), and E.19 (Contingency Plan Update): These provisions are based on the Basin Plan, the requirements of 40 CFR 122, and the previous permit.
- xix) Provision E.20. (Self-Monitoring Program): The Discharger is required to conduct monitoring of the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are contained in the Self Monitoring Program (SMP) of the Permit. This provision requires compliance with the SMP, and is based on 40 CFR 122.44(i), 122.62, 122.63 and 124.5. The SMP is a standard requirement in almost all NPDES permits issued by the Board, including this Order. It contains definitions of terms, specifies general sampling and analytical protocols, and sets out requirements for reporting of spills, violations, and routine monitoring data in accordance with NPDES regulations, the California Water Code, and Board's policies. The SMP also contains a sampling program specific for the facility. It defines the sampling stations and frequency, the pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs for them.
- xx) Provision E.21 (Standard Provisions and Reporting Requirements): The purpose of this provision is require compliance with the standard provisions and reporting requirements given in this Board's document titled *Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits, August 1993* (the Standard Provisions), or any amendments thereafter. That document is incorporated in the permit as an attachment to it. Where provisions or reporting requirements specified in the permit are different from equivalent or related provisions or reporting requirements given in the Standard Provisions, the permit specifications shall apply. The standard provisions and reporting requirements given in the above document are based on various state and federal regulations with specific references cited therein.
- xxi) Provisions E.22 (Change in Control or Ownership): This provision is based on 40 CFR 122.61.
- xxii) Provision E.23 (Permit Reopener): This provision is based on 40 CFR 123.
- xxiii) Provision E.24 (NPDES Permit /the U.S. EPA concurrence): This provision is based on 40 CFR 123.
- xxiv) Provisions E.25 (Permit Expiration and Reapplication): This provision is based on 40 CFR 122.46(a).

IV. WASTE DISCHARGE REQUIREMENT APPEALS

Any person may petition the State Water Resources Control Board to review the decision of the Board regarding the Waste Discharge Requirements. A petition must be made within 30 days of the Board public hearing.

V. ATTACHMENTS

- Attachment 1. RPA Results for Priority Pollutants
- Attachment 2. Data Used For Reasonable Potential Analysis
- Attachment 3. Results of Reasonable Potential Analysis
- Attachment 4. Calculation of Final WQBELs
- Attachment 5. Mercury Mass Limit Calculations
- Attachment 6. Lead Compliance Feasibility Analysis
- Attachment 7. Nickel Compliance Feasibility Analysis

Attachment 1

Determination of Governing WQOs and WQCs

1 of 2

2 of 2

Attachment 2

Data Used For Reasonable Potential Analysis

CTR No.	Constituent name	EFFLUENT DATA					BACKGROUND DATA (B)				
		Effluent Data Available (Y/N)?	Are all data points non-detects (Y/N)?	If all data points ND Enter the min detection limit (MDL) (ug/L)	Enter the pollutant effluent detected max conc (ug/L)	Input Check	B Available (Y/N)?	Are all B non-detects (Y/N)?	If all data points ND Enter the min detection limit (MDL) (ug/L)	Enter the Detected Maximum Background Conc	Input Check
1	Antimony					Check input	N				
2	Arsenic	Y			4	Check input	Y	N		4.6	
3	Beryllium					Check input	N				
4	Cadmium	Y			0.2	Check input	Y	N		0.235	
5a	Chromium (III)					Check input	Y	N		40.7	
5b	Chromium (VI)	Y			5	Check input	N				
6	Copper	Y			16.34	Check input	Y	N		14.3	
7	Lead	Y			3	Check input	Y	N		6.46	
8	Mercury	Y			0.0462	Check input	Y	N		0.0881	
9	Nickel	Y			6.4858	Check input	Y	N		30	
10	Selenium	Y			1	Check input	Y	N		0.33	
11	Silver	Y			1.55	Check input	Y	N		0.059	
12	Thallium					Check input	N				
13	Zinc	Y			56	Check input	Y	N		35	
14	Cyanide	Y			7.317	Check input	N				
15	Asbestos					Check input	N				
16	2,3,7,8 TCDD					Check input	N				
17	Acrolein	Y	Y	1			N				
18	Acrylonitrile	Y	Y	1			N				
19	Benzene	Y	Y	0.27			N				
20	Bromoform	Y			0.4754	Check input	N				
21	Carbon Tetrachloride	Y	Y	0.42			N				
22	Chlorobenzene	Y	Y	0.19			N				
23	Chlorodibromomethane	Y			5.1187	Check input	N				
24	Chloroethane	Y	Y	0.34			N				
25	2-Chloroethylvinyl ether	Y	Y	0.31			N				
26	Chloroform	Y			31.9643	Check input	N				
27	Dichlorobromomethane	Y			16.785	Check input	N				
28	1,1-Dichloroethane	Y	Y	0.28			N				
29	1,2-Dichloroethane	Y	Y	4.25			N				
30	1,1-Dichloroethylene	Y	Y	0.37			N				
31	1,2-Dichloropropane	Y	Y	0.2			N				
32	1,3-Dichloropropylene	Y	Y	0.2			N				
33	Ethylbenzene	Y	Y	0.3			N				
34	Methyl Bromide	Y	Y	0.42			N				
35	Methyl Chloride	Y	Y	0.36			N				
36	Methylene Chloride	Y	Y	0.38			N				
37	1,1,2,2-Tetrachloroethane	Y	Y	0.3			N				
38	Tetrachloroethylene	Y	Y	0.32			N				
39	Toluene	Y			1.2789	Check input	N				
40	1,2-Trans-Dichloroethylene	Y	Y	0.3			N				
41	1,1,1-Trichloroethane	Y	Y	0.35			N				
42	1,1,2-Trichloroethane	Y	Y	0.27			N				
43	Trichloroethylene	Y	Y	0.29			N				
44	Vinyl Chloride	Y	Y	0.34			N				
45	2-Chlorophenol					Check input	N				
46	2,4-Dichlorophenol					Check input	N				
47	2,4-Dimethylphenol					Check input	N				
48	2-Methyl- 4,6-Dinitrophenol					Check input	N				
49	2,4-Dinitrophenol					Check input	N				
50	2-Nitrophenol					Check input	N				
51	4-Nitrophenol					Check input	N				
52	3-Methyl 4-Chlorophenol					Check input	N				
53	Pentachlorophenol	Y	Y	0.4			N				
54	Phenol					Check input	N				
55	2,4,6-Trichlorophenol	Y	Y	0.2			N				
56	Acenaphthene	Y	Y	0.17			Y	N		0.007	
57	Acenaphthylene	Y	Y	0.03			Y	N		0.0004	
58	Anthracene	Y	Y	0.03			Y	N		0.00002	
59	Benzidine					Check input	N				
60	Benzo(a)Anthracene	Y	Y	0.12			Y	N		0.00033	
61	Benzo(a)Pyrene	Y	Y	0.09			Y	N		0.00032	
62	Benzo(b)Fluoranthene	Y	Y	0.11			Y	N		0.00053	
63	Benzo(ghi)Perylene	Y	Y	0.06			Y	N		0.000864	
64	Benzo(k)Fluoranthene	Y	Y	0.16			Y	N		0.000326	
65	Bis(2-Chloroethoxy)Methane					Check input	N				
66	Bis(2-Chloroethyl)Ether					Check input	N				
67	Bis(2-Chloroisopropyl)Ether					Check input	N				
68	Bis(2-Ethylhexyl)Phthalate					Check input	N				
69	4-Bromophenyl Phenyl Ether					Check input	N				
70	Butylbenzyl Phthalate					Check input	N				
71	2-Chloronaphthalene					Check input	N				
72	4-Chlorophenyl Phenyl Ether					Check input	N				
73	Chrysene	Y	Y	0.14			Y	N		0.00043	
74	Dibenzo(a,h)Anthracene	Y	Y	0.04			Y	N		0.000032	
75	1,2-Dichlorobenzene	Y	Y	0.12			N				

CTR No.	Constituent name	EFFLUENT DATA					BACKGROUND DATA (B)				
		Effluent Data Available (Y/N)?	Are all data points non-detects (Y/N)?	If all data points ND Enter the min detection limit (MDL) (ug/L)	Enter the pollutant effluent detected max conc (ug/L)	Input Check	B Available (Y/N)?	Are all B non-detects (Y/N)?	If all data points ND Enter the min detection limit (MDL) (ug/L)	Enter the Detected Maximum Background Conc	Input Check
76	1,3-Dichlorobenzene	Y	Y	0.16			N				
77	1,4-Dichlorobenzene	Y	Y	0.12			N				
78	3,3 Dichlorobenzidine					Check input	N				
79	Diethyl Phthalate					Check input	N				
80	Dimethyl Phthalate					Check input	N				
81	Di-n-Butyl Phthalate					Check input	N				
82	2,4-Dinitrotoluene					Check input	N				
83	2,6-Dinitrotoluene					Check input	N				
84	Di-n-Octyl Phthalate					Check input	N				
85	1,2-Diphenylhydrazine					Check input	N				
86	Fluoranthene	Y	Y	0.03			Y	N		0.002	
87	Fluorene	Y	Y	0.02			Y	N		0.01	
88	Hexachlorobenzene	Y	Y	0.4			Y	N		0.000073	
89	Hexachlorobutadiene					Check input	N				
90	Hexachlorocyclopentadiene					Check input	N				
91	Hexachloroethane					Check input	N				
92	Indeno(1,2,3-cd)Pyrene	Y	Y	0.04			Y	N		0.000473	
93	Isophorone					Check input	N				
94	Naphthalene	Y	Y	0.05			Y			0.0012	Check input
95	Nitrobenzene					Check input	N				
96	N-Nitrosodimethylamine					Check input	N				
97	N-Nitrosodi-n-Propylamine					Check input	N				
98	N-Nitrosodiphenylamine					Check input	N				
99	Phenanthrene	Y	Y	0.03			Y			0.0014	Check input
100	Pyrene	Y	Y	0.03			Y	N		0.0016	
101	1,2,4-Trichlorobenzene					Check input	N				
102	Aldrin	Y	Y	0.03			N				
103	alpha-BHC	Y	Y	0.03			N				
104	beta-BHC	Y	Y	0.001			N				
105	gamma-BHC	Y	Y	0.001			N				
106	delta-BHC	Y	Y	0.001			N				
107	Chlordane	Y	Y	0.005			Y	N		0.000344	
108	4,4'-DDT	Y	Y	0.001			Y	N		0.000416	
109	4,4'-DDE (linked to DDT)	Y	Y	0.001			Y	N		0.001159	
110	4,4'-DDD	Y	Y	0.001			Y	N		0.001159	
111	Dieldrin	Y	Y	0.002			Y	N		0.000237	
112	alpha-Endosulfan	Y	Y	0.002			Y	N		0.000017	
113	beta-Endosulfan	Y	Y	0.001			Y	N		0.000059	
114	Endosulfan Sulfate	Y	Y	0.001			Y	N		0.0001433	
115	Endrin	Y	Y	0.002			Y	N		0.000073	
116	Endrin Aldehyde	Y	Y	0.002			N				
117	Heptachlor	Y	Y	0.003			Y			0.000017	Check input
118	Heptachlor Epoxide	Y	Y	0.002			Y			0.000121	Check input
119-125	PCBs sum	Y	Y	0.03			N				
126	Toxaphene	Y	Y	0.2			Y	Y	Unk		
	Tributyltin					Check input	N				
	Total PAHs	Y	Y		0	Check input	Y	N		0.008	
	Chlorpyrifos		y	0.04			Y			0.000734	
	Diazinon		y	0.04							

Attachment 3

Results of Reasonable Potential Analysis

Reasonable Potential
Analysis Results

Beginning		Step 2	Step 3					Step 4		Step 2	Step 3		Step 4.	Step 5.	Step 6.	Step 7 & 8.	Combined Effluent
	Constituent name	C (µg/L) Lowest (most stringent) Criteria (Enter "No Criteria" for no criteria)	Effluent Data Available?	Are all data points non-detects?	Minimum MDL (µg/L) if all data ND.	Enter the pollutant effluent detected max conc (µg/L)	If all data points are ND and MinDL>C, interim monitoring is required	Maximum Pollutant Concentration (MEC) (µg/L) (MEC= detected max value; if all ND & MDL < C then MEC = MDL)	Y if MEC >= C, effluent limitation is required; 2. If MEC < C, go to Step 5	Background Data Available?	Are all B data points non-detects?	If all data points ND Enter the min detection limit (MDL) (µg/L)	Enter the pollutant B detected max conc (µg/L)	If all B is ND, is MDL < C? (If Y, Go To Step 7)	If B < C, effluent limitation is required	7) Review other information in the SIP page 4. Y if other information indicates limits are required. If information is unavailable or insufficient: B) the RWQCB shall establish interim monitoring requirements.	RPA Result
A	B	C	D	E	F	G	H	I	J	K	L	M	N	O	P	Q	S
1	Antimony	4300					No Effluent Data									No detected value of B, Step 7	
2	Arsenic ⁵	36	Y			4		MEC<C, go to Step 5		Y				4.6		B<C, Step 7	
3	Beryllium	No Criteria					No Criteria									No Criteria	
4	Cadmium ⁵	1.46064715	Y			0.2		MEC<C, go to Step 5		Y				0.235		B<C, Step 7	
5a	Chromium (III)	269.460219					No Effluent Data			Y				40.7		B<C, Step 7	
5b	Chromium (VI) ⁵	11	Y			5		MEC<C, go to Step 5								No detected value of B, Step 7	
6	Copper ⁵	6.575	Y			16.34		Y		Y				14.3		Y	Y
7	Lead ⁵	4.79413809	Y			3		MEC<C, go to Step 5		Y				8.46		Y	Y
8	Mercury (303d listed) ⁵	0.025	Y			0.0462		Y		Y				0.0861		Y	Y
9	Nickel ⁵	26.2962963	Y			6.4858		MEC<C, go to Step 5		Y				30		Y	Y
10	Selenium (303d listed) ⁵	5	Y			1		MEC<C, go to Step 5		Y				0.33		B<C, Step 7	
11	Silver ⁵	2.23529412	Y			1.55		MEC<C, go to Step 5		Y				0.059		B<C, Step 7	
12	Thallium	6.3					No Effluent Data									No detected value of B, Step 7	
13	Zinc ⁵	58	Y			56		MEC<C, go to Step 5		Y				35		B<C, Step 7	
14	Cyanide ⁵	1	Y			7.317		Y								No detected value of B, Step 7	Y
15	Asbestos	No Criteria					No Criteria									No Criteria	
16	2,3,7,8 TCDD (303d listed)	1.4E-08					No Effluent Data									No detected value of B, Step 7	Y
17	Aroclor	780	Y	Y	1		MDL<=C, MDL=MEC	1		MEC<C, go to Step 5						No detected value of B, Step 7	
18	Acrylonitrile	0.66	Y	Y	1		MDL > C, Interim Monitor, Go To Step 5									No detected value of B, Step 7	
19	Benzene	71	Y	Y	0.27		MDL<=C, MDL=MEC	0.27		MEC<C, go to Step 5						No detected value of B, Step 7	
20	Bromofom	360	Y			0.4754		0.4754		MEC<C, go to Step 5						No detected value of B, Step 7	
21	Carbon Tetrachloride	4.4	Y	Y	0.42		MDL<=C, MDL=MEC	0.42		MEC<C, go to Step 5						No detected value of B, Step 7	
22	Chlorobenzene	21000	Y	Y	0.19		MDL<=C, MDL=MEC	0.19		MEC<C, go to Step 5						No detected value of B, Step 7	
23	Chlorodibromomethane	34	Y			5.1187		5.1187		MEC<C, go to Step 5						No detected value of B, Step 7	
24	Chloroethane	No Criteria	Y	Y	0.34		No Criteria	0.34		No Criteria						No Criteria	No Criteria
25	2-Chloroethylvinyl ether	No Criteria	Y	Y	0.31		No Criteria	0.31		No Criteria						No Criteria	No Criteria
26	Chloroform	No Criteria	Y			31.9643		No Criteria		No Criteria						No Criteria	No Criteria
27	Dichlorobromomethane	46	Y			16.785		16.785		MEC<C, go to Step 5						No detected value of B, Step 7	
28	1,1-Dichloroethane	No Criteria	Y	Y	0.28		No Criteria	0.28		No Criteria						No Criteria	No Criteria
29	1,2-Dichloroethane	99	Y	Y	4.25		MDL<=C, MDL=MEC	4.25		MEC<C, go to Step 5						No detected value of B, Step 7	
30	1,1-Dichloroethylene	3.2	Y	Y	0.37		MDL<=C, MDL=MEC	0.37		MEC<C, go to Step 5						No detected value of B, Step 7	
31	1,2-Dichloropropane	39	Y	Y	0.2		MDL<=C, MDL=MEC	0.2		MEC<C, go to Step 5						No detected value of B, Step 7	
32	1,3-Dichloropropylene	1700	Y	Y	0.2		MDL<=C, MDL=MEC	0.2		MEC<C, go to Step 5						No detected value of B, Step 7	
33	Ethylbenzene	29000	Y	Y	0.3		MDL<=C, MDL=MEC	0.3		MEC<C, go to Step 5						No detected value of B, Step 7	
34	Methyl Bromide	4000	Y	Y	0.42		MDL<=C, MDL=MEC	0.42		MEC<C, go to Step 5						No detected value of B, Step 7	
35	Methyl Chloride	No Criteria	Y	Y	0.36		No Criteria	0.36		No Criteria						No Criteria	No Criteria
36	Methylene Chloride	1600	Y	Y	0.38		MDL<=C, MDL=MEC	0.38		MEC<C, go to Step 5						No detected value of B, Step 7	
37	1,1,2,2-Tetrachloroethane	11	Y	Y	0.3		MDL<=C, MDL=MEC	0.3		MEC<C, go to Step 5						No detected value of B, Step 7	
38	Tetrachloroethylene	8.85	Y	Y	0.32		MDL<=C, MDL=MEC	0.32		MEC<C, go to Step 5						No detected value of B, Step 7	
39	Toluene	200000	Y			1.2789		1.2789		MEC<C, go to Step 5						No detected value of B, Step 7	
40	1,2-Trans-Dichloroethylene	140000	Y	Y	0.3		MDL<=C, MDL=MEC	0.3		MEC<C, go to Step 5						No detected value of B, Step 7	
41	1,1,1-Trichloroethane	No Criteria	Y	Y	0.35		No Criteria	0.35		No Criteria						No Criteria	No Criteria
42	1,1,2-Trichloroethane	42	Y	Y	0.27		MDL<=C, MDL=MEC	0.27		MEC<C, go to Step 5						No detected value of B, Step 7	
43	Trichloroethylene	81	Y	Y	0.29		MDL<=C, MDL=MEC	0.29		MEC<C, go to Step 5						No detected value of B, Step 7	
44	Vinyl Chloride	525	Y	Y	0.34		MDL<=C, MDL=MEC	0.34		MEC<C, go to Step 5						No detected value of B, Step 7	
45	2-Chlorophenol	400					No Effluent Data									No detected value of B, Step 7	
46	2,4-Dichlorophenol	790					No Effluent Data									No detected value of B, Step 7	
47	2,4-Dimethylphenol	2300					No Effluent Data									No detected value of B, Step 7	
48	2-Methyl- 4,6-Dinitrophenol	755					No Effluent Data									No detected value of B, Step 7	
49	2,4-Dinitrophenol	14000					No Effluent Data									No detected value of B, Step 7	
50	2-Nitrophenol	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
51	4-Nitrophenol	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
52	3-Methyl 4-Chlorophenol	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
53	Pentachlorophenol	7.9	Y	Y	0.4		MDL<=C, MDL=MEC	0.4		MEC<C, go to Step 5						No detected value of B, Step 7	
54	Phenol	4600000					No Effluent Data									No detected value of B, Step 7	
55	2,4,6-Trichlorophenol	6.5	Y	Y	0.2		All ND MDL<=C, MDL=MEC	0.2		MEC<C, go to Step 5						No detected value of B, Step 7	
56	Acenaphthene	2700	Y	Y	0.17		All ND MDL<=C, MDL=MEC	0.17		MEC<C, go to Step 5		Y		0.007		B<C, Step 7	
57	Acenaphthylene	No Criteria	Y	Y	0.03		No Criteria	0.03		No Criteria		Y		0.0004		No Criteria	No Criteria
58	Anthracene	110000	Y	Y	0.03		All ND MDL<=C, MDL=MEC	0.03		MEC<C, go to Step 5		Y		0.00002		B<C, Step 7	
59	Benidine	0.00054					No Effluent Data									No detected value of B, Step 7	
60	Benzo(a)Anthracene	0.049	Y	Y	0.12		MDL > C, Interim Monitor, Go To Step 5			Y				0.00033		B<C, Step 7	
61	Benzo(a)Pyrene	0.049	Y	Y	0.09		MDL > C, Interim Monitor, Go To Step 5			Y				0.00032		B<C, Step 7	
62	Benzo(b)Fluoranthene	0.049	Y	Y	0.11		MDL > C, Interim Monitor, Go To Step 5			Y				0.00053		B<C, Step 7	
63	Benzo(ghi)Perylene	No Criteria	Y	Y	0.06		No Criteria	0.06		No Criteria				0.000864		No Criteria	No Criteria
64	Benzo(k)Fluoranthene	0.049	Y	Y	0.16		MDL > C, Interim Monitor, Go To Step 5			Y				0.000326		B<C, Step 7	
65	Bis(2-Chloroethoxy)Methane	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
66	Bis(2-Chloroethoxy)Ether	1.4					No Effluent Data									No detected value of B, Step 7	
67	Bis(2-Chloroisopropoxy)Ether	170000					No Effluent Data									No detected value of B, Step 7	
68	Bis(2-Ethylhexyl)Phthalate	5.9					No Effluent Data									No detected value of B, Step 7	
69	4-Bromophenyl Phenyl Ether	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
70	Butylbenzyl Phthalate	5200					No Effluent Data									No detected value of B, Step 7	
71	2-Chloronaphthalene	4300					No Effluent Data									No detected value of B, Step 7	
72	4-Chlorophenyl Phenyl Ether	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
73	Chrysene	0.049	Y	Y	0.14		MDL > C, Interim Monitor, Go To Step 5				Y			0.00043		B<C, Step 7	
74	Dibenz(a,h)Anthracene	0.049	Y	Y	0.04		All ND MDL<=C, MDL=MEC	0.04		MEC<C, go to Step 5		Y		0.000032		B<C, Step 7	
75	1,2-Dichlorobenzene	17000	Y	Y	0.12		All ND MDL<=C, MDL=MEC	0.12		MEC<C, go to Step 5						No detected value of B, Step 7	
76	1,3-Dichlorobenzene	2600	Y	Y	0.16		All ND MDL<=C, MDL=MEC	0.16		MEC<C, go to Step 5						No detected value of B, Step 7	
77	1,4-Dichlorobenzene	2600	Y	Y	0.12		All ND MDL<=C, MDL=MEC	0.12		MEC<C, go to Step 5						No detected value of B, Step 7	
78	3,3-Dichlorobenzidine	0.077					No Effluent Data									No detected value of B, Step 7	
79	Diethyl Phthalate	120000					No Effluent Data									No detected value of B, Step 7	
80	Dimethyl Phthalate	2900000					No Effluent Data									No detected value of B, Step 7	
81	D,n-Butyl Phthalate	12000					No Effluent Data									No detected value of B, Step 7	
82	2,4-Dinitrotoluene	0.1					No Effluent Data									No detected value of B, Step 7	
83	2,6-Dinitrotoluene	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
84	D,n-Octyl Phthalate	No Criteria					No Criteria			No Criteria						No Criteria	No Criteria
85	1,2-Diphenylhydrazine	0.54					No Effluent Data									No detected value of B, Step 7	

Reasonable Potential
Analysis Results

Beginning		Step 2	Step 3				Step 4	Step 2	Step 3		Step 4.	Step 5.	Step 6.	Step 7 & 8.	Combined Effluent
	C (µg/L)					Maximum Pollutant Concentration (MEC) (µg/L)	MEC vs. C						B vs. C	f) Review other information in the SIP page 4. Y if other information indicates limits are required. If information is unavailable or insufficient: B) the RWQCB shall establish interim monitoring requirements.	RPA Result
Constituent name	Lowest (most stringent) Criteria (Enter "No Criteria" for no criteria)	Effluent Data Available?	Are all data points non-detects?	Minimum MDL (µg/L) if all data ND	Enter the pollutant effluent detected max conc (µg/L)	If all data points are ND and MinDL<C, interim monitoring is required	(MEC= detected max value; if all ND & MDL<C then MEC = MDL)	Y if If MEC >= C, effluent limitation is required. 2. If MEC<C, go to Step 5	Background Data Available?	Are all B data points non-detects?	If all data points ND Enter the min detection limit (MDL) (µg/L)	Enter the pollutant B detected max conc (µg/L)	If all B is ND, is MDL<C? (If Y, Go To Step 7)		
86 Fluoranthene	370	Y	Y	0.03	All ND MDL<=C, MDL=MEC	0.03	MEC<C, go to Step 5	Y				0.002	B<C, Step 7		
87 Fluorene	14000	Y	Y	0.02	All ND MDL<=C, MDL=MEC	0.02	MEC<C, go to Step 5	Y				0.01	B<C, Step 7		
88 Hexachlorobenzene	0.00077	Y	Y	0.4	MDL > C, Interim Monitor, Go To Step 5			Y				0.000073	B<C, Step 7		
89 Hexachlorobutadiene	50				No Effluent Data								No detected value of B, Step 7		
90 Hexachlorocyclopentadiene	17000				No Effluent Data								No detected value of B, Step 7		
91 Hexachloroethane	8.9				No Effluent Data								No detected value of B, Step 7		
92 Indeno[1,2,3-cd]Pyrene	0.049	Y	Y	0.04	All ND MDL<=C, MDL=MEC	0.04	MEC<C, go to Step 5	Y				0.000473	B<C, Step 7		
93 Isophorone	600				No Effluent Data								No detected value of B, Step 7		
94 Naphthalene	No Criteria	Y	Y	0.05	No Criteria	0.05	No Criteria	Y				0.0012	No Criteria	No Criteria	
95 Nitrobenzene	1900				No Effluent Data								No detected value of B, Step 7		
96 N-Nitrosodimethylamine	8.1				No Effluent Data								No detected value of B, Step 7		
97 N-Nitrosodi-n-Propylamine	1.4				No Effluent Data								No detected value of B, Step 7		
98 N-Nitrosodiphenylamine	16				No Effluent Data								No detected value of B, Step 7		
99 Phenanthrene	No Criteria	Y	Y	0.03	No Criteria	0.03	No Criteria	Y				0.0014	No Criteria	No Criteria	
100 Pyrene	11000	Y	Y	0.03	All ND MDL<=C, MDL=MEC	0.03	MEC<C, go to Step 5	Y				0.0016	B<C, Step 7		
101 1,2,4-Trichlorobenzene	No Criteria				No Criteria		No Criteria						No Criteria	No Criteria	
102 Aldrin	0.00014	Y	Y	0.03	MDL > C, Interim Monitor, Go To Step 5								No detected value of B, Step 7		
103 alpha-BHC	0.013	Y	Y	0.03	MDL > C, Interim Monitor, Go To Step 5								No detected value of B, Step 7		
104 beta-BHC	0.046	Y	Y	0.001	All ND MDL<=C, MDL=MEC	0.001	MEC<C, go to Step 5	Y					No detected value of B, Step 7		
105 gamma-BHC	0.063	Y	Y	0.001	All ND MDL<=C, MDL=MEC	0.001	MEC<C, go to Step 5	Y					No detected value of B, Step 7		
106 delta-BHC	No Criteria	Y	Y	0.001	No Criteria	0.001	No Criteria						No Criteria	No Criteria	
107 Chlordane (303d listed)	0.00059	Y	Y	0.005	MDL > C, Interim Monitor, Go To Step 5			Y				0.000344	B<C, Step 7		
108 4,4'-DDT (303d listed)	0.00059	Y	Y	0.001	MDL > C, Interim Monitor, Go To Step 5			Y				0.000416	B<C, Step 7		
109 4,4'-DDE (linked to DDT)	0.00059	Y	Y	0.001	MDL > C, Interim Monitor, Go To Step 5			Y				0.001159	Y	Y	
110 4,4'-DDD	0.00084	Y	Y	0.001	MDL > C, Interim Monitor, Go To Step 5			Y				0.001159	Y	Y	
111 Dieldrin (303d listed)	0.00014	Y	Y	0.002	MDL > C, Interim Monitor, Go To Step 5			Y				0.000237	Y	Y	
112 alpha-Endosulfan	0.0087	Y	Y	0.002	All ND MDL<=C, MDL=MEC	0.002	MEC<C, go to Step 5	Y				0.000017	B<C, Step 7		
113 beta-Endosulfan	0.0087	Y	Y	0.001	All ND MDL<=C, MDL=MEC	0.001	MEC<C, go to Step 5	Y				0.000059	B<C, Step 7		
114 Endosulfan Sulfate	240	Y	Y	0.001	All ND MDL<=C, MDL=MEC	0.001	MEC<C, go to Step 5	Y				0.0001433	B<C, Step 7		
115 Endrin	0.0023	Y	Y	0.002	All ND MDL<=C, MDL=MEC	0.002	MEC<C, go to Step 5	Y				0.000073	B<C, Step 7		
116 Endrin Aldehyde	0.81	Y	Y	0.002	All ND MDL<=C, MDL=MEC	0.002	MEC<C, go to Step 5	Y					No detected value of B, Step 7		
117 Heptachlor	0.00021	Y	Y	0.003	MDL > C, Interim Monitor, Go To Step 5			Y				0.000017	B<C, Step 7		
118 Heptachlor Epoxide	0.00011	Y	Y	0.002	MDL > C, Interim Monitor, Go To Step 5			Y				0.000121	Y	Y	
119-125 PCBs sum (2)	0.00017	Y	Y	0.03	MDL > C, Interim Monitor, Go To Step 5			Y	Y	Unk		Y	No detected value of B, Step 7		
126 Toxaphene	0.0002	Y	Y	0.2	MDL > C, Interim Monitor, Go To Step 5			Y	Y	Unk			No detected value of B, Step 7		
Tributyltin	0.01				No Effluent Data								No detected value of B, Step 7		
Total PAHs	15	Y	Y		MDL > C, Interim Monitor, Go To Step 5			Y				0.008	B MDL>C, Monitoring Required	0	
a. The most stringent of salt and fresh water criteria were selected for this analysis.															
b. According to Table 1 of Section (b)(1) of CTR (40CFR 131.38), those criteria should use Basin Plan objectives; criteria for Se and CN are specified by the NTR.															
c. Criteria for copper is taken from CTR. CTR criteria for copper is expressed as dissolved metals. The copper criterion in the table is adjusted by dividing a factor of 0.83 to convert the dissolved to total metal concentration.															
The freshwater criteria for Selenium is taken from NTR.															
d. Acronyms in the "Final Result" column: Ud: Cannot determine reasonable potential due to the absence of data, or because Minimum DL is greater than water quality objective or CTR criteria															

Attachment 4
Calculation of Final WQBELs

Data Initialization:			Dilution:		0										
			No. Samples Per Month:		4										
Beginning			Aquatic Criteria Available? (Min. if Y)	Human Health Criteria Available?	Applicable Acute WQO	Applicable Chronic WQO	Bckkgnd Data Available? Max If Avail.	Acute ECA	Chronic ECA	Human Health ECA	CV, by SIP Guidance	Acute ECA (Sigma^2)	Acute ECA Sigma	Chronic ECA (Sigma^2)	Chronic ECA Sigma
	Constituent name	RP?													
6	Copper ^c	Y	6.575342466	N	6.575342466	12.28449962	14.3	6.575342466	12.28449962	No HH Criteria	0.280630704	0.075806293	0.275329427	0.019497088	0.139631975
7	Lead ^b	Y	4.794138094	N	123.0257818	4.794138094	6.46	123.0257818	4.794138094	No HH Criteria	0.994228718	0.687375931	0.829081378	0.220839047	0.469935152
8	Mercury (303d listed) ^b	Y	0.025	0.051	2.1	0.025	0.0881	2.1	0.025	0.051	0.5070037	0.228769895	0.47829896	0.062282717	0.249565056
9	Nickel ^b	Y	26.2962963	4600	113.8461538	26.2962963	30	113.8461538	26.2962963	4600	0.315931887	0.095140127	0.308447932	0.024646991	0.156993603
14	Cyanide ^b	Y	1	220000	1	1	N	1	1	220000	0.37251782	0.129948316	0.360483448	0.034104167	0.184673135
109	4,4'-DDE (linked to DDT)	Y	0.00059	0.00059	0.00059	0.001159	0.00059	0.00059	0.00059	0.00059	0.6	0.3074847	0.554513029	0.086177696	0.293560379
110	4,4'-DDD	Y	0.00084	No Acute	No Chronic	0.001159	No Acute	No chronic	0.00084	0.6	0.3074847	0.554513029	0.086177696	0.293560379	
111	Dieldrin (303d listed)	Y	0.0019	0.00014	0.24	0.0019	0.000237	0.24	0.0019	0.00014	0.6	0.3074847	0.554513029	0.086177696	0.293560379
118	Heptachlor Epoxide	Y	0.0036	0.00011	0.053	0.0036	0.000121	0.053	0.0036	0.00011	0.6	0.3074847	0.554513029	0.086177696	0.293560379
Beginning		Acute ECA Multiplier	Chronic ECA Multiplier	Acute LTA	Chronic LTA	AMEL Sigma^2	AMEL Sigma	MDEL Multiplier	AMEL Multiplier	MDEL	AMEL	MDEL Human Health	AMEL Human Health	Daily Maximum	Monthly Average
	Constituent name														
6	Copper ^c	0.547434149	0.729763018	3.599567008	8.964773519	0.019497088	0.139631975	1.826703726	1.246009513	6.575	4.485	No HH Criteria	No HH Criteria	6.6	4.5
7	Lead ^b	0.204997946	0.374317976	25.22003257	1.794532068	0.220839047	0.469935152	4.878097657	1.939875511	8.754	3.481	No HH Criteria	No HH Criteria	8.8	3.5
8	Mercury (303d listed) ^b	0.368564911	0.577326703	0.773986314	0.014433168	0.062282717	0.249565056	2.713226271	1.461397484	0.039	0.021	0.094686	0.051000	0.039	0.021
9	Nickel ^b	0.511770075	0.702687067	58.26305475	18.47806733	0.024646991	0.156993603	1.954002486	1.278811309	36.106	23.630	7028.723766	4600.000000	36	24
14	Cyanide ^b	0.461390583	0.661994767	0.461390583	0.661994767	0.034104167	0.184673135	2.167361095	1.332071465	1.000	0.615	357953.348170	220000.000000	1.0	0.6
109	4,4'-DDE (linked to DDT)	0.321083214	0.527433444	0.000189439	0.000311186	0.086177696	0.293560379	3.114457427	1.552424614	0.001	0.000	0.001184	0.000590	0.00059	0.00029
110	4,4'-DDD	0.321083214	0.527433444	No Acute	No Chronic	0.086177696	0.293560379	3.114457427	1.552424614	No Acute	No Chronic	0.001685	0.000840	0.0017	0.00084
111	Dieldrin (303d listed)	0.321083214	0.527433444	0.077059971	0.001002124	0.086177696	0.293560379	3.114457427	1.552424614	0.003	0.002	0.000281	0.000140	0.00028	0.00014
118	Heptachlor Epoxide	0.321083214	0.527433444	0.01701741	0.00189876	0.086177696	0.293560379	3.114457427	1.552424614	0.006	0.003	0.000221	0.000110	0.00022	0.00011

Attachment 5
Mercury Mass Limit Calculations

MERCURY MASS LIMIT COMPUTATIONS

Date [1]	Total Flow, Q, MGD [1]	Mercury Concentration, C, ug/l [1]	Mass = Q X C, g/day	12-Month Avg. Load, MAML, g/day [2]	Natural log of MAML (ln MAML)
May-99	5.90	0.016	0.348		
Jun-99	5.60	0.022	0.470		
Jul-99	5.45	0.021	0.443		
Sep-99	5.33	0.018	0.373		
Oct-99	5.17	0.013	0.250		
Nov-99	5.33	0.014	0.285		
Dec-99	5.55	0.015	0.314		
Jan-00	5.84	0.020	0.435		
Feb-00	7.28	0.008	0.222		
Mar-00	9.76	0.044	1.609		
Apr-00	6.08	0.027	0.616		
May-00	5.74	0.033	0.712	0.506	(0.6805)
Jun-00	5.57	0.017	0.367	0.508	(0.6774)
Jul-00	5.46	0.020	0.410	0.503	(0.6873)
Aug-00	5.28	0.024	0.488	0.507	(0.6798)
Sep-00	5.31	0.018	0.371	0.507	(0.6801)
Oct-00	5.33	0.011	0.212	0.503	(0.6865)
Nov-00	0.00	0.000	0.000	0.480	(0.7347)
Dec-00	5.21	0.101	1.987	0.619	(0.4795)
Jan-01	6.19	0.013	0.302	0.608	(0.4977)
Feb-01	8.75	0.015	0.492	0.630	(0.4613)
Mar-01	7.92	0.018	0.526	0.540	(0.6157)
Apr-01	5.57	0.017	0.365	0.519	(0.6553)
May-01	5.58	0.022	0.464	0.499	(0.6959)
Jun-01	5.42	0.020	0.406	0.502	(0.6893)
Jul-01	5.12	0.020	0.379	0.499	(0.6946)
Aug-01	5.05	0.023	0.435	0.495	(0.7036)
Sep-01	5.24	0.026	0.513	0.507	(0.6800)
Oct-01	5.05	0.016	0.299	0.514	(0.6658)
Nov-01	5.15	0.012	0.238	0.534	(0.6278)
Dec-01	8.97	0.020	0.688	0.425	(0.8546)
Jan-02	13.85	0.017	0.898	0.475	(0.7441)
Feb-02	6.19	0.017	0.398	0.467	(0.7606)
Mar-02	6.43	0.046	1.129	0.572	(0.5584)
Apr-02	5.51	0.027	0.555	0.530	(0.6349)
May-03	6.70	0.014	0.347	0.519	(0.6554)
Nov-03	4.83	0.011	0.202	0.499	(0.6955)
Avg	6.02	0.021			

Statistical analysis of 12-month moving average mass loads (MAMLs)

Count, n, of 12-month MAMLs	26
Maximum 12-month MAMLs	0.630 grams per day (g/day)
Maximum 12-month MAMLs	0.019 kilograms per month (kg/mo)
Average 12-month MAML	0.518 g/day 0.016 kg/Mo
Data distribution of 12-month MAMLs	ln-normal per MiniTab analysis
Standard Deviation, ln(MAML)	0.086
Mean, ln(MAML)	-0.661
Mean + 3 STDEV, ln(MAML)	-0.405
e-exponentiated [Mean+3 STDEV, ln(MAML)]	0.667 g/day
99.87th percentile of 12-month MAMLs	0.020 kg/mo

Mercury Mass Emission Trigger =	0.020	1
--	--------------	----------

Notes:

- [1] Information from the Annual Reports and Self-Monitoring Reports
 [2] MA [Hg] load in g/d is the moving average mercury load in grams per day.
 This calculation is the product of the moving average flow, mercury concentration, and a unit-conversion multiplier of 3.785.

Attachment 6
Lead Compliance Feasibility Analysis

Sampling Point	Constituent	Date	Result	Units
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	1/5/2000	3.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	2/8/2000	3.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	3/7/2000	3.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	4/7/2000	3.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	5/3/2000	3.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	1/3/2001	3.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	3/6/2001	2.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	4/7/2001	0.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	11/5/2001	0.3300	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	1/3/2002	0.6500	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	2/9/2002	0.3500	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	3/7/2002	0.4800	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	4/2/2002	0.5100	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	1/1/2003	0.3500	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Lead	5/1/2003	0.2900	ug/l
		Median	0.65	
		95th P'ctile	3.00	
		99.87th P'ctile	3.00	

Attachment 7
Nickel Compliance Feasibility Analysis

Sampling Point	Constituent	Date	Result	Units
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	5/4/1999	5.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	1/5/2000	5.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	2/8/2000	6.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	3/7/2000	5.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	4/7/2000	4.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	5/3/2000	4.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	1/3/2001	5.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	3/6/2001	5.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	4/7/2001	5.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	11/5/2001	2.4000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	1/3/2002	5.8000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	2/9/2002	3.5000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	3/7/2002	4.0000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	4/2/2002	4.2000	ug/l
E-003 Wet Weather Eff Daily Maximum ug/l	Nickel	1/1/2003	4.8000	ug/l
		Median	5.00	
		95th P'ctile	5.87	
		99.87th P'ctile	6.00	

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment E.
July 22, 2004 *Novato Sanitary District Infeasibility Study*

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment F.

July 22, 2004 *Novato Sanitary District Copper and Nickel Translator Calculation*

Novato Sanitary District
NPDES Permit No. CA0037958
Order No: R2-2004-0093

Attachment G.

April 28, 2004 Workplan for Ignacio Treatment Plant, NPDES Permit No. CA0037955

Attachment H
Pretreatment Program Requirements

Pretreatment Program Provisions

1. The Discharger shall implement all pretreatment requirements contained in 40 CFR 403, as amended. The Discharger shall be subject to enforcement actions, penalties, and fines as provided in the Clean Water Act (33 USC 1351 et seq.), as amended. The Discharger shall implement and enforce its Approved Pretreatment Program or modified Pretreatment Program as directed by the Board's Executive Officer or the EPA. The EPA and/or the State may initiate enforcement action against an industrial user for noncompliance with applicable standards and requirements as provided in the Clean Water Act.
2. The Discharger shall enforce the requirements promulgated under Sections 307(b), 307(c), 307(d) and 402(b) of the Clean Water Act. The Discharger shall cause industrial users subject to Federal Categorical Standards to achieve compliance no later than the date specified in those requirements or, in the case of a new industrial user, upon commencement of the discharge.
3. The Discharger shall perform the pretreatment functions as required in 40 CFR Part 403 and amendments or modifications thereto including, but not limited to:
 - i) Implement the necessary legal authorities to fully implement the pretreatment regulations as provided in 40 CFR 403.8(f)(1);
 - ii) Implement the programmatic functions as provided in 40 CFR 403.8(f)(2);
 - iii) Publish an annual list of industrial users in significant noncompliance as provided per 40 CFR 403.8(f)(2)(vii);
 - iv) Provide for the requisite funding and personnel to implement the pretreatment program as provided in 40 CFR 403.8(f)(3); and
 - v) Enforce the national pretreatment standards for prohibited discharges and categorical standards as provided in 40 CFR 403.5 and 403.6, respectively.
4. The Discharger shall submit annually a report to the EPA Region 9, the State Board and the Regional Board describing its pretreatment program activities over the previous twelve months. In the event that the Discharger is not in compliance with any conditions or requirements of the Pretreatment Program, the Discharger shall also include the reasons for noncompliance and a plan and schedule for achieving compliance. The report shall contain, but is not limited to, the information specified in Appendix A entitled, "Requirements for Pretreatment Annual Reports," which is made a part of this Order. The annual report is due on the last day of February each year.
5. The Discharger shall submit semiannual pretreatment reports to the EPA Region 9, the State Board and the Board describing the status of its significant industrial users (SIUs). The report shall contain, but is not limited to, the information specified in Appendix B entitled, "Requirements for Semiannual Pretreatment Reports," which is made part of this Order. The semiannual reports are due July 31st (for the period January through June) and January 31st (for the period July through December) of each year. The Executive Officer may exempt a Discharger from the semiannual reporting requirements on a case by case basis subject to State Board and EPA's comment and approval.

6. The Discharger may combine the annual pretreatment report with the semiannual pretreatment report (for the July through December reporting period). The combined report shall contain all of the information requested in Appendices A and B and will be due on January 31st of each year.
7. The Discharger shall conduct the monitoring of its treatment plant's influent, effluent, and sludge as described in Appendix C entitled, "Requirements for Influent, Effluent and Sludge Monitoring," which is made part of this Order. The results of the sampling and analysis, along with a discussion of any trends, shall be submitted in the semiannual reports. A tabulation of the data shall be included in the annual pretreatment report. The Executive Officer may require more or less frequent monitoring on a case by case basis.

APPENDIX A

REQUIREMENTS FOR PRETREATMENT ANNUAL REPORTS

The Pretreatment Annual Report is due each year on the last day of February. [If the annual report is combined with the semiannual report (for the July through December period) the submittal deadline is January 31st of each year.] The purpose of the Annual Report is 1) to describe the status of the Publicly Owned Treatment Works (POTW) pretreatment program and 2) to report on the effectiveness of the program, as determined by comparing the results of the preceding year's program implementation. The report shall contain at a minimum, but is not limited to, the following information:

1) **Cover Sheet**

The cover sheet must contain the name(s) and National Pollutant Discharge Elimination Discharge System (NPDES) permit number(s) of those POTWs that are part of the Pretreatment Program. Additionally, the cover sheet must include: the name, address and telephone number of a pretreatment contact person; the period covered in the report; a statement of truthfulness; and the dated signature of a principal executive officer, ranking elected official, or other duly authorized employee who is responsible for overall operation of the POTW (40 CFR 403.12(j)).

2) **Introduction**

The Introduction shall include any pertinent background information related to the Discharger, the POTW and/or the industrial user base of the area. Also, this section shall include an update on the status of any Pretreatment Compliance Inspection (PCI) tasks, Pretreatment Performance Evaluation tasks, Pretreatment Compliance Audit (PCA) tasks, Cleanup and Abatement Order (CAO) tasks, or other pretreatment-related enforcement actions required by the Regional Board or the EPA. A more specific discussion shall be included in the section entitled, "Program Changes."

3) **Definitions**

This section shall contain a list of key terms and their definitions that the Discharger uses to describe or characterize elements of its pretreatment program.

4) **Discussion of Upset, Interference and Pass Through**

This section shall include a discussion of Upset, Interference or Pass Through incidents, if any, at the POTW(s) that the Discharger knows of or suspects were caused by industrial discharges. Each incident shall be described, at a minimum, consisting of the following information:

- a) a description of what occurred;
- b) a description of what was done to identify the source;
- c) the name and address of the IU responsible
- d) the reason(s) why the incident occurred;
- e) a description of the corrective actions taken; and

- f) an examination of the local and federal discharge limits and requirements for the purposes of determining whether any additional limits or changes to existing requirements may be necessary to prevent other Upset, Interference or Pass Through incidents.

5) **Influent, Effluent and Sludge Monitoring Results**

This section shall provide a summary of the analytical results from the “Influent, Effluent and Sludge Monitoring” as specified in Appendix C. The results should be reported in a summary matrix that lists monthly influent and effluent metal results for the reporting year.

A graphical representation of the influent and effluent metal monitoring data for the past five years shall also be provided with a discussion of any trends.

6) **Inspection and Sampling Program**

This section shall contain at a minimum, but is not limited to, the following information:

- a) Inspections: the number of inspections performed for each type of IU; the criteria for determining the frequency of inspections; the inspection format procedures;
- b) Sampling Events: the number of sampling events performed for each type of IU; the criteria for determining the frequency of sampling; the chain of custody procedures.

7) **Enforcement Procedures**

This section shall provide information as to when the approved Enforcement Response Plan (ERP) had been formally adopted or last revised. In addition, the date the finalized ERP was submitted to the Regional Board shall also be given.

8) **Federal Categories**

This section shall contain a list of all of the federal categories that apply to the Discharger. The specific category shall be listed including the subpart and 40 CFR section that applies. The maximum and average limits for the each category shall be provided. This list shall indicate the number of Categorical Industrial Users (CIUs) per category and the CIUs that are being regulated pursuant to the category. The information and data used to determine the limits for those CIUs for which a combined waste stream formula is applied shall also be provided.

9) **Local Standards**

This section shall include a table presenting the local limits.

10) **Updated List of Regulated SIUs**

This section shall contain a complete and updated list of the Discharger’s Significant Industrial Users (SIUs), including their names, addresses, and a brief description of the individual SIU’s type of business. The list shall include all deletions and additions keyed to the list as submitted in the previous annual report. All deletions shall be briefly explained.

11) **Compliance Activities**

- a) **Inspection and Sampling Summary:** This section shall contain a summary of all the inspections and sampling activities conducted by the Discharger over the past year to gather information and data regarding the SIUs. The summary shall include:
- (1) the number of inspections and sampling events conducted for each SIU;
 - (2) the quarters in which these activities were conducted; and
 - (3) the compliance status of each SIU, delineated by quarter, and characterized using all applicable descriptions as given below:
 - (a) in consistent compliance;
 - (b) in inconsistent compliance;
 - (c) in significant noncompliance;
 - (d) on a compliance schedule to achieve compliance, (include the date final compliance is required);
 - (e) not in compliance and not on a compliance schedule;
 - (f) compliance status unknown, and why not.
- b) **Enforcement Summary:** This section shall contain a summary of the compliance and enforcement activities during the past year. The summary shall include the names of all the SIUs affected by the following actions:
- (1) Warning letters or notices of violations regarding SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
 - (2) Administrative Orders regarding the SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
 - (3) Civil actions regarding the SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
 - (4) Criminal actions regarding the SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.

- (5) Assessment of monetary penalties. Identify the amount of penalty in each case and reason for assessing the penalty.
- (6) Order to restrict/suspend discharge to the POTW.
- (7) Order to disconnect the discharge from entering the POTW.

12) **Baseline Monitoring Report Update**

This section shall provide a list of CIUs that have been added to the pretreatment program since the last annual report. This list of new CIUs shall summarize the status of the respective Baseline Monitoring Reports (BMR). The BMR must contain all of the information specified in 40 CFR 403.12(b). For each of the new CIUs, the summary shall indicate when the BMR was due; when the CIU was notified by the POTW of this requirement; when the CIU submitted the report; and/or when the report is due.

13) **Pretreatment Program Changes**

This section shall contain a description of any significant changes in the Pretreatment Program during the past year including, but not limited to: legal authority, local limits, monitoring/inspection program and frequency, enforcement protocol, program's administrative structure, staffing level, resource requirements and funding mechanism. If the manager of the pretreatment program changes, a revised organizational chart shall be included. If any element(s) of the program is in the process of being modified, this intention shall also be indicated.

14) **Pretreatment Program Budget**

This section shall present the budget spent on the Pretreatment Program. The budget, either by the calendar or fiscal year, shall show the amounts spent on personnel, equipment, chemical analyses and any other appropriate categories. A brief discussion of the source(s) of funding shall be provided.

15) **Public Participation Summary**

This section shall include a copy of the public notice as required in 40 CFR 403.8(f)(2)(vii). If a notice was not published, the reason shall be stated.

16) **Sludge Storage and Disposal Practice**

This section shall have a description of how the treated sludge is stored and ultimately disposed. The sludge storage area, if one is used, shall be described in detail. Its location, a description of the containment features and the sludge handling procedures shall be included.

17) **PCS Data Entry Form**

The annual report shall include the PCS Data Entry Form. This form shall summarize the enforcement actions taken against SIUs in the past year. This form shall include the following information: the POTW name, NPDES Permit number, period covered by the report, the number of SIUs in significant noncompliance (SNC) that are on a pretreatment compliance schedule, the number of notices of violation and administrative orders issued against SIUs, the number of civil

and criminal judicial actions against SIUs, the number of SIUs that have been published as a result of being in SNC, and the number of SIUs from which penalties have been collected.

18) **Other Subjects**

Other information related to the Pretreatment Program that does not fit into one of the above categories should be included in this section.

Signed copies of the reports shall be submitted to the Regional Administrator at USEPA, the State Water Resources Control Board and the Regional Board at the following addresses:

Regional Administrator
United States Environmental Protection Agency
Region 9, Mail Code: WTR-7
Clean Water Act Compliance Office
Water Division
75 Hawthorne Street
San Francisco, CA 94105

Pretreatment Program Manager
Regulatory Unit
State Water Resources Control Board
Division of Water Quality
1001 I Street
Sacramento, CA 95814

Pretreatment Coordinator
NPDES Permits Division
SF Bay Regional Water Quality Control Board
1515 Clay Street, Suite 1400
Oakland, CA 94612